

KBM
QUALITY REGULATIONS
FOR
MECHANICAL EQUIPMENT

Edition 6.0, 2011-02-15

The Swedish Nuclear Power Companies have jointly produced this document.
Any revision of this document must be approved by mutual consultation
between the companies

Approved:

Göran Ekbohm, FKA, Erik Lindén, OKG, Anders Richnau
Licensee administrators of the PAKT-documents

TABLE OF CONTENTS

0	INTRODUCTION	6
0.1	Background	6
0.2	Objective	6
0.3	Application	6
0.3.1	Surface treatment.....	7
0.3.2	HVAC (Heating, Ventilation, Air Conditioning)	7
0.3.3	Lifting equipment	7
0.3.4	Structural parts	7
1	GENERAL REQUIREMENTS FOR QUALITY AND AUTHORISATION	8
1.1	General	8
1.1.1	Area of application.....	8
1.2	Definitions and Abbreviations	9
1.3	General Quality and Inspection Regulations	12
1.3.1	General Regulations – the purchaser’s and supplier’s Commitment	12
1.3.2	Regulations, Codes and Standards	13
1.3.3	Design specifications and design criteria	13
1.3.4	Division into Quality Classes	14
1.3.5	Documentation for Manufacturing, Installation or Repair	14
1.3.6	General Inspection Requirements, Examination Procedures and Procedures	14
1.3.7	Materials.....	15
1.3.8	Manufacturing Inspection.....	15
1.3.9	Inspection of Installation and Repair of Deficiency in the Plant	16
1.3.10	Deviations	16
1.3.11	Documentation	16
1.4	Requirements for manufacturer’s Quality Assurance and Accreditation	18
1.4.1	General	18
1.4.2	Quality System and Quality Plans.....	18
1.4.3	Accreditation.....	19
1.4.4	Assessment of Supplier.....	21
1.5	Rules for Type Inspection Certificate	21
1.5.1	General	21
1.5.2	Scope	22
1.5.3	Obtaining of Type Inspection Certificate	22
1.5.4	Purchasing according to Type Inspection Certificate	22
1.5.5	Documentation	22
1.6	Authorisation for Welding and other Joining Methods	22
1.6.1	General	22
1.6.2	Authorisation requirements for manufacturers and companies that are welding	22
1.6.3	Requirements for qualification of welding procedure.....	23
1.6.4	Requirements for certification of welders	24
1.6.5	Personnel qualification for welding at installation and repair	25
1.7	Licensee’s approval of companies performing heat treatment at manufacture and installation	26
1.7.1	General	26
1.7.2	Authorisation requirements.....	26
1.7.3	Scope	26
1.8	Authorisation for testing and inspection	26
1.8.1	Authorisation to act as an Accredited Laboratory, Accredited Certification or Inspection Body.....	Error! Bookmark not defined.
1.8.2	General for authorisation for testing and inspection.....	26
1.8.3	Authorisation for testing at manufacturing of material and shapes	27

1.8.4	Authorisation for testing at manufacture of mechanical equipment	27
1.8.5	Authorisation for NDT at installation and repairs of deficiencies in the plant	28
2	GENERAL INSPECTION REQUIREMENTS AND INSPECTION PROCEDURES	29
2.1	Description of general inspection requirements and inspection procedures	29
2.1.1	General	29
2.1.2	General inspection requirements, division and content.....	30
2.1.3	Descriptions of the inspection procedures	33
2.1.4	Designations for extent of inspection and supervision	34
2.1.5	Scope of the inspection	35
2.1.6	Abbreviations for NDT Methods.....	36
2.1.7	Certificate of Compliance.....	37
2.1.8	Register of applicable regulations, codes and standards	38
2.2	Index of general inspection requirements	41
2.2.1	General inspection requirements prior to manufacture, installation and repair	41
2.2.2	Pressure-retaining equipment or components	41
2.2.3	General inspection requirements at manufacture, welding and other joining	42
2.2.4	General inspection requirements for completed mechanical device or part of device	43
2.2.5	General inspection requirements – installation or repair	43
2.2.6	General inspection requirements – Installed system or part of system or repair	43
2.3	Index for applicable inspection procedures	43
2.3.1	Descriptions of inspection procedures – Prescribed or inspection and testing according to code	44
2.3.2	Descriptions of inspection procedure – Other inspection and testing	45
3	INSPECTION PRIOR TO MANUFACTURING, INSTALLATION AND REPAIR OF INSTALLED EQUIPMENT	46
3.1	General inspection requirements prior to manufacturing and installation IP-100 – IP-102	46
3.1.1	General inspection requirements prior to manufacturing and installation IP-100	46
3.1.2	General inspection requirements prior to manufacturing and installation - IP-101	49
3.1.3	General inspection requirements prior to manufacturing and installation IP-102	51
3.2	General inspection requirements prior to repairs of mechanical equipment - IP-103.....	53
3.2.1	General inspection requirements prior to repair of deficiencies induced by operation of the plant - IP-103	53
3.3	Specification – Inspection prior to manufacturing, installation or repair of installed equipment.....	55
3.3.1	Introduction	55
3.3.2	Basic documentation to be prepared by the purchaser or licensee	55
3.3.3	Basic documentation to be compiled by the supplier or manufacturer.....	57
4	MANUFACTURE INSPECTION	62
4.1	General material inspection requirements IP-200	63
4.1.1	Pressure retaining equipment or parts thereof – IP 201 to 209	63
4.1.2	Load bearing devices and device parts – IP 221 to 222.....	78
4.1.3	Internal parts in mechanical equipment – IP 230	80
4.1.4	Internals in reactor pressure vessels and Steam Generators – IP 240	81
4.2	General inspection requirements – Manufacture/Joining – IP 300	82
4.2.1	Mechanical equipment and parts thereof – IP 300	82

4.3	General inspection requirements – Finished mechanical equipment or subassembly IP 400	86
4.3.1	Finished mechanical equipment or subassembly – IP 400	86
5	INSTALLATION AND REPAIR INSPECTION.....	93
5.1	General requirements – Installation or repair IP-500	93
5.1.1	Testing and inspection at welding.....	93
5.1.2	Other inspection at installation ⁶	93
5.2	General inspection requirements – Installed system or part of system or repair IP-600.....	95
5.2.1	Pipes and piping.....	95
5.2.2	Pipe hangers	Error! Bookmark not defined.
5.2.3	Quality Control Documentation.....	95

APPENDIX:

- Appendix 1 Description of Inspection procedures (Compulsory Inspection)
- Appendix 2 Inspection Procedures (Other Inspections)

LIST OF REVISIONS – KBM

Edition	Reason for revision	Applicable pages	Date
2	Thorough revision due to the regulations issued by the Swedish nuclear power inspectorate regarding revision of "the regulations (SKIFS 1994:1) Mechanical Equipment in Nuclear Plants", SKIFS 1996:1 and revisions due to aspects from review of issue 1 performed by licensees and SAQ Nuclear Engineering Inspection Limited	Revision of the entire document	1997-05-01
3	Thorough revision	The entire document	1999-10-01
4	Thorough revision due to SKIFS 2000:2 and aspects from the licensees and DNV Nuclear Technology	The entire document	2001-04-01
5	Thorough revision due to SKIFS 2005:2 and gained experiences.	The entire document	2008-01-08
6.0	General update	The entire document	2011-02-15

0 INTRODUCTION

0.1 Background

The PAKT documents (PBM1, PBM2, ABM, KBM, TBM, TBY and PAKT list of definitions) shall be updated on periodically basis. At the revisions new standards and experiences gained to be implemented into the documents.

Quality Regulations for Mechanical Equipment “KBM” is an implementing document jointly created by the Swedish nuclear power licensees and this document constitutes a common interpretation in order to fulfil:

- The requirements of the regulation SSMFS 2008:13 issued by the Swedish Radiation Safety Authority
- The requirements of the regulations AFS 1999:4, AFS 1993:41 (rewritten in AFS 1994:53) and AFS 2005:2 upon design and manufacturing of pressurised equipment. These regulations are issued by the Occupational Safety and Health Board.
- The licensee’s own requirements, and
- The level of testing, inspection and reporting considered necessary by the licensees for an Accredited Inspection Body to certify the conformance with the requirements in SSMFS 2008:13.

This regulation can also be used as guideline for other applications than those included above.

0.2 Objective

The objective with KBM is that the licensees shall use the regulations for:

- Purchasing of mechanical equipment
- In-house manufacturing of mechanical equipment,
- Purchasing of installations and repairs,
- Installations or repairs under own management.

0.3 Application

KBM shall be used together with the licensee’s common technical regulations, TBM and TBY. In addition, when the equipment also contains electrical parts, technical regulations, TBE, and inspection regulations, KBE, for electrical equipment shall be used.

For work assignments within 0.3.1 – 0.3.4 below, a combination of KBM and nuclear plant specific quality documents may state the levels of regulations.

Work assignments within 0.3.1 – 0.3.4 are normally outside the jurisdiction of SSMFS 2008:13.

0.3.1 Surface treatment

For surface treatment, there are common technical regulations (TBY) for the licensees.

0.3.2 HVAC (Heating, Ventilation, Air Conditioning)

A common licensees work has commenced for HVAC. Until further notice, nuclear plant specific quality documents shall be applied.

0.3.3 Lifting equipment

For lifting equipment, the licensee's common quality documents will eventually be developed. Until then, the following may be regarded as a guideline.

Upon purchasing of new or major alterations of existing lifting equipment (cranes, hoists and lifting equipment) the basic requirements are stated in following regulations:

- AFS 2008:3 + AFS 2009:5 – Machinery.
- AFS 2003:6 – Inspection of lifting equipment and certain other technical equipment
- BFS 1994: 25 – The National Board of Housing, Building and Planning's regulations and common advises about hoists and some other motor-driven equipment.

For lifting equipment above where accidents / incidents could affect the nuclear safety, a higher safety philosophy is required. Examples of this are found in reports issued by NRC, NUREG-0554 and NUREG-0612.

For requirements and extent of inspection, KTA-standards may serve as guidance.

In areas where accidents/incidents may cause radioactive discharge/contamination in the nuclear plant or loss of cooling to irradiated fuel, KTA 3902 §4:2 and KTA 3903 §4:2 may serve as guidance.

In cases where accidents/ incidents may cause activity discharge/contamination exposure to third part, KTA 3902 §4:3 and KTA 3903 §4:2 may serve as guidance.

0.3.4 Building parts

For requirements concerning civil work a common licensee's document "DRB:2001" is developed.

1 GENERAL REQUIREMENTS FOR QUALITY AND AUTHORISATION

1.1 General

These quality regulations constitute a joint implementation document for the Swedish licensees. The purpose of the document is to interpret The Swedish Radiation Safety Authority (SSM) regulations regarding mechanical parts in certain nuclear plants, SSMFS 2008:13.

Mechanical equipment in any of the quality classes 1-4 or 4A shall be designed, manufactured, installed and inspected according to SSMFS 2008:13, 4th chapter, 4-12 §§.

For design and manufacturing of pressure retaining devices in quality class 4, where deficiencies or malfunction not can cause discharge of radioactive substances the regulations AFS 1999:4 (PED), AFS 1993:41 (rewritten in AFS 1994:53) and AFS 2005:2 issued by the Swedish Work Environment Inspection are valid. In addition SSMFS 2008:13, 4th chapter, 4§ along with the licensee's possible additional requirements to be considered.

For design and manufacturing of pressure retaining devices in quality classes 4 where deficiencies or malfunction can cause discharge of radioactive substances the regulation SSMFS 2008:13 is valid. The extent of inspection and testing shall correspond to quality class 4A.

The Accredited Inspection Body's (AIB) participation at inspection and testing of installation, repairs, exchanges, modifications and extension of equipment is governed by the inspection class divisioning as per AFS 2005:3. In inspection class A and B, AIB participates to necessary extent. In inspection class C, the inspection and testing is performed as in house inspection. For installations in quality class 4A, the same extent of inspection and testing as for quality class 4 inspection class A applies.

Changes of a nuclear plant's operational conditions, including increase of the power, are in terms of requirements regarded as physical plant changes.

1.1.1 Area of application

The Nuclear Plants affected by these regulations are:

- Forsmark 1, 2 and 3
- Oskarshamn 1, 2 and 3
- Ringhals 1, 2, 3 and 4

The quality regulations apply to design and manufacturing of such mechanical equipment being part of the primary system or in the containment barrier or in the safety, operational and auxiliary systems in nuclear plant reactors. The quality regulations also apply to mechanical equipment for reactivity control and maintaining of criticality safety.

The quality regulations do not apply to:

- moving machine internals in pumps, turbines, motors and generators
- lifting equipment and lifting tools
- mechanical parts in nuclear fuel clusters

- containers used for transport of nuclear substances and nuclear waste
- mechanical equipment used for handling, processing, storing or final disposal of nuclear waste along with such containers intended for nuclear waste

The Quality Regulations are neither valid for:

- Atmospheric tanks intended for inflammable liquid, for which regulations have been issued with support of the regulation (SFS 1988:1145) regarding inflammable and explosive goods
- Piping for inflammable liquid for which regulations have been issued, supported by the regulation regarding inflammable goods, and which are used between components that are neither pressure vessels nor vacuum vessels
- Such mechanical equipment being integrated parts of a reactor containment

The regulations may in applicable parts be used for safety classified HVAC (Heat, Ventilation, Air Conditioning) not covered by SSMFS 2008:13 and where each nuclear plant has developed quality regulations.

The regulations can in applicable parts be used as guidance for the preparation of documents for mechanical equipment not formally included in the regulations.

For core control equipment extent of inspection and testing corresponding to quality class 2 should be used.

1.2 Definitions and Abbreviations

For the “PAKT documents” (PBM1, PBM2, ABM, KBM and TBM) the licensees have jointly produced a list of definitions that is presented in a separate document “PAKT definitions”.

Abbreviations

In these regulations the following abbreviations are used:

ABM	General Regulations for Mechanical Equipment
AFS	The Swedish Work Environment Authority’s Statue Book
AV	The Swedish Work Environment Authority
AIB	Accredited Inspection Body according to SSMFS (see AK)
AIS	Guidelines for non-mechanical safety equipment, Issued by the Pressure Vessel Standardisation
AK	Accredited Inspection Body according to SSMFS, also “AIB”
AL	Accredited Laboratory
AO	Notified Body according to AFS accredited according SS-EN ISO/IEC 17020
ANS	American Nuclear Society
ANSI	American National Standards Institute

ASME	The American Society of Mechanical Engineers
BWR	Boiling Water Reactor
bk	Inspection class, also “ic”
CFR	Codes of Federal Regulations
DN	Nominal size according to SS-EN ISO 6708
DUP	Detailed Ultrasonic Testing Procedure
HAZ	Heat Affected Zone
HVAC	Heating Ventilation Air Condition
IGSCC	Intergranular Stress Corrosion Cracking
ic	Inspection class (see “bk”)
ISI	In-Service Inspection
KBM	Quality Regulations for Mechanical Equipment
KFM	Mechanical Design Criteria
KO	Qualification Body
KTA	Der Kerntechnische Ausschuss
LOCA	Loss of Coolant Accident
NDT	Non-destructive test
NPS	Nominal Pipe Size
PAKT	Common abbreviation for the documents PBM1, PBM2, ABM, KBM, TBM, TBY and the PAKT list of definitions
PBM	Regulations for In-service inspection
PED	Pressure Equipment Directive, 97/23/EG
PWR	Pressurised Water Reactor
RCPB	Reactor Coolant Pressure Boundary
SAR	Safety Analysis Report
SG	Steam Generator
SIS	Swedish Standards Institute
SSMFS	The Swedish Radiation Safety Authority Regulations
STAFS	Statute-book of The Board of Technical Inspection
SWEDAC	The Board for accreditation and technical inspection
TBM	Technical Regulations for Mechanical Equipment

TBY	Technical Regulations for Surface Protection
TH	Licensee (of Nuclear Facility)
TM	Technical Justification

1.3 General Quality and Inspection Regulations

1.3.1 General Regulations – the purchaser’s and supplier’s Commitment

The purchaser shall furnish documentation for the supplier’s undertaking by specifying the requirements through the following documents:

- Technical Regulations – TBM and TBY
- Quality Regulations - KBM
- Information regarding relevant quality class, and when applicable, function class
- General inspection requirements including related inspection procedures
- Other requirements related to components

The purchaser shall ensure that the relevant quality control documents satisfies and complies with the relevant authority requirements.

Unless otherwise specified, the purchaser shall defray all costs related to third party review made by an Accredited Inspection Body and he shall also ensure that it is ordered.

The supplier shall, unless otherwise specified, defray all costs related to all other third party inspection from used Accredited Laboratory and Accredited Bodies during manufacturing and installation.

The supplier shall, unless otherwise specified, defray the costs related to third party inspection, caused by repairs, repeated inspections, processing of deviations or and/or down-time caused by the supplier during manufacturing and installation.

The supplier shall ensure that detailed manufacturing- and inspection documentation is prepared and sent to the purchaser for review and approval.

Unless otherwise agreed, the purchaser is responsible for the review by the Accredited Inspection Body.

The supplier shall ensure that all approved documentation for manufacturing and inspection is listed in a separate document, stating the title and valid version of the approved documents. The list of approved documents shall be kept up to date by the supplier and be included in the final quality control documentation.

The supplier shall be responsible and administer the inspection and records that are required in accordance with the approved manufacturing and inspection documentation. The supplier shall notify the Accredited Inspection Body whenever stated in the inspection documentation.

The supplier shall carry out and defray all inspection necessary for assuming full responsibility for the quality of the product.

Suppliers shall possess and follow a well-recognised quality assurance system, see.1.4.2.

For manufacturing, installation and repair in quality class 1-3 and function class 1E, the supplier shall be assessed and approved according to 1.4.

The purchaser shall be entitled to attend the supplier's inspection work without cost and also to carry out his own inspections.

The purchaser shall be entitled to participate, on special request, in discussions of inspection matters that are held between the supplier and inspection companies and subcontractors engaged by him.

Approval obtained from the purchaser and engaged inspection companies does not exempt the supplier from contractual obligations and liability for the quality of the product.

The supplier must be prepared, on special order, to carry out additional inspection above and beyond the original agreement.

The supplier shall give the purchaser the name of the person he has put in charge of the inspection work.

The supplier shall, on the purchaser's request, report the result of his assessments of the subcontractors.

1.3.2 Regulations, Codes and Standards

The supplier and the purchaser shall commonly agree to the standards, codes and regulations that shall apply for the order. Both parts shall approve possible deviations from the agreement at the time of ordering and if applicable, be approved/reviewed by prescribing authority or AIB.

1.3.3 Design specifications and design criteria

The design specification and design criteria (KFM) thereto shall in connection with ordering of replacement equipment, installation work or repairs, be established by the licensee.

For installation of equipment in quality classes 1-4, 4A where SSMFS 2008:13, 4th chapter, 4§ is applicable, the design criteria included in the design specifications shall be safety reviewed and notified to the Swedish Radiation Authority (SSM).

For the design of replacement parts, that are mainly identical to the parts intended to be replaced, design verification could be performed by demonstrating that the replacement parts, as a minimum, fulfils the original strength requirements.

At work where the design criteria remain unaltered, the design criteria in force including the reply from SSM shall be reported to the assigned Accredited Inspection Body.

Further details regarding design specifications and design criteria are to be found in Technical Regulations – TBM.

1.3.4 Division into Quality Classes

The division in quality classes governs the design requirements and quality assurance measures for mechanical equipment.

For each respective nuclear plant the division into quality classes is evident from the flow charts and classification lists that are based on requirements and principles in the nuclear plant specific Safety Analysis Report (SAR) for each plant. These requirements and principles for the divisioning into quality classes shall be notified to and accepted by SSM for each nuclear plant.

Division into function classes is evident from each nuclear plant's classification lists in force.

At nuclear plant modifications where new systems or parts of systems are added, these will be classified according to the requirements and principles in the Safety Analysis Report (SAR) for each plant.

For further details regarding classification, see the Technical Regulations – TBM Attachment 3.

1.3.5 Documentation for Manufacturing, Installation or Repair

Before starting manufacturing, installation or repair of deficiencies in the nuclear plant, the supplier shall furnish the purchaser with applicable documents such as drawings, calculations, procedures, procedure qualifications, inspection documentation etc. for review and approval (for a more detailed description of the required documentation see section 3).

The documentation shall be based on and include the data requested according to the technical regulations (TBM) and quality regulations (KBM), specified by the purchaser.

Unless otherwise agreed, the purchaser / licensee shall after his approval be responsible that the documentation, to the required extent, is third party-reviewed by an Accredited Inspection Body.

1.3.6 General Inspection Requirements, Examination Procedures and Description

The supplier shall transfer relevant and applicable inspection requirements into detailed inspection documents (inspection plan) for the manufacturing, installation and repair of deficiencies in the nuclear plant. The inspections and tests that are considered necessary by the supplier to achieve full responsibility shall also be included.

The supplier shall further prepare written procedures in the cases this is prescribed in these regulations or in the purchase order. The written procedures shall fulfil and include the data, which is requested in the description of the inspection procedures included in these regulations (KBM).

In the cases where procedure qualification is required, the qualification reports shall be enclosed.

For more detailed description of the necessary documentation, see chapter 3.

Before the work is initiated, above mentioned documentation shall be reviewed and approved by the purchaser.

After the purchaser has approved the documentation, he shall, unless otherwise agreed, arrange that the documentation will be third party-reviewed by an Accredited Inspection Body.

Deviation from the requirement of preparing detailed quality control documentation and written procedures is not allowed without a written permission from the purchaser. The supplier is responsible to apply for such permission from the purchaser.

1.3.7 Materials

Material shall be selected in accordance with applicable regulations, agreement, and/or directions in the purchaser's Technical Regulations -TBM.

The supplier shall ensure that testing, inspection, marking and documentation of material is carried out to the extent and in accordance with the procedures stipulated in the approved inspection documentation.

The supplier is responsible for the marking to be transferred in such a manner that all identification of material against relevant inspection reports will be ensured.

The supplier shall ensure that the material's dimensions and surface finish meets the requirements that are specified in codes and technical regulations and otherwise conform to the requirements of the purchaser.

Repair of parent metal, by welding is only permitted after written consent from the purchaser. If repair by welding is accepted by the purchaser, a procedure for repair shall be prepared, in which requirements for testing, inspection, welding procedure, welding procedure qualification, possible heat treatment and other requirements shall be specified.

The procedure shall be reviewed and approved by the purchaser and if applicable also by AIB before commencement of the repair is permitted.

1.3.8 Manufacturing Inspection

Prior to the start of manufacture, the supplier shall check that drawings, inspection plans and other relevant documents are reviewed and approved by the purchaser and in applicable cases by AIB. The supplier's inspection plans shall be prepared in such a way that produced items and sub assemblies may be approved prior to installation and that associated certificate from AIB and licensee is issued prior to the installation.

The supplier and the purchaser shall upon order agree who to order, pay for and suborder a possible third-part examination. This is also valid for who shall pay for a possible re-inspection.

The supplier is responsible for submitting notification for manufacturing inspection in due time as agreed in the order.

Unless otherwise stated, the supplier shall be responsible for and pay for all testing and inspection according to the approved inspection plan and also be responsible for the documentation thereto.

During ongoing manufacturing, the supplier shall furnish the purchaser with the documents requested by the purchaser needed to follow the manufacturing.

The purchaser shall inspect the final product and the documentation thereto to be reviewed and approved by the purchaser.

If, for reasons of access, the equipment cannot be inspected at a later time, the supplier shall contact the purchaser and agree on a suitable time for inspection.

After final inspection of the product, all pertinent records shall be submitted to the supplier for review and approval.

If so required, inspection and review of inspection records shall also be performed by an Accredited Inspection Body prior to the installation of the equipment in the nuclear plant. This can either be performed as a delivery inspection at the supplier's facilities or as a site receiving inspection at the nuclear plant.

1.3.9 Inspection of Installation and Repair of Deficiency in the Nuclear Plant

Prior to start of installation or repair of deficiency, the governing inspection documents to be approved by the purchaser and in applicable cases by AIB.

The supplier and the purchaser shall upon order, agree who shall order, pay for and suborder possible third party inspection. This is also valid for whom to pay for possible re-inspection.

1.3.10 Deviations

The supplier shall obtain the purchaser's written approval of any deviations from the KBM and TBM requirements, or by the purchaser previously approved documentation or other requirements stated in the order.

After the review and possible approval of the deviation, the purchaser applies for any disposition that may be required by authorities and the Accredited Inspection Body.

In the deviation report, the supplier shall clearly describe the nature of the deviation and suggest corrective action.

The supplier shall also report the corrective actions he considers to take for preventing recurrence.

The deviation report shall be issued and signed in accordance with the supplier's quality assurance system.

All deviations shall be processed, corrected and approved before the relevant work operations are finalised.

The supplier shall ensure that all the deviations are currently registered.

Deviation reports shall be included in the final quality control documentation.

Unless otherwise agreed, the supplier is responsible for all the inspection costs related to deviations caused by the supplier.

1.3.11 Documentation

The supplier shall in a clear manner compile records for the review, testing and inspection included in the order and stipulated in the inspection plans.

A document list shall be included and contain:

- Governing documentation for manufacturing
- Documentation for manufacturing
- Applicable certificates and reports prepared during the work
- Any deviation reports

The supplier shall ensure that the final documentation package such as drawings, inspection plans, procedures, qualification programmes, qualification reports, test reports, certificates etc, are signed and approved by the manufacturer.

The documentation shall be signed by the purchaser or his representative and/or the Accredited Inspection Body to the extent prescribed in the inspection plan.

The supplier shall ensure that certificates are traceable against the inspection plan and the item to which the certificate pertains. The certificates can be made traceable against the inspection plan by specification of a consecutive number on the certificate. This consecutive number is noted in the inspection plan for the inspection activity and item to which the certificate pertains.

It must be evident that the manufacturer has reviewed and approved the quality control documentation.

The supplier shall also certify that the product and the executed work is approved and fulfils the requirements of the supplier and the purchaser.

At manufacturing of material and components the purchaser shall in cooperation with the supplier ensure that the Accredited Inspection Body issues certificates of compliance with the requirements according to the inspection plans.

The supplier shall file radiographs and other testing and manufacturing records for material and components in an expedient manner and keep them available to the purchaser for at least 10 years after delivery. If the supplier must discontinue the filing, the purchaser shall be notified, even after the 10-year period. Alternatively, radiographs and documents may be turned over to the purchaser for filing.

Unless otherwise agreed, the supplier shall provide the purchaser with the quality control documentation when materials and components are delivered.

After the installation or repair work, the supplier shall turn over the quality control documentation to the purchaser for approval and filing.

The supplier shall state that he has inspected the installation according to the drawings and reviewed and approved the quality control documentation.

The purchaser shall at the receipt inspection of material and components review and approve the quality control documentation, submitted by the supplier.

As an alternative to receipt inspection, material and components can be approved by the purchaser as delivery inspection at the manufacturer.

Prior to installation in the nuclear plant or if possible prior to turn over to storage, inspection and review of inspection records shall whenever required also be performed by an Accredited Inspection Body.

The purchaser shall whenever required, after his own review and approval of the installation or repairs arrange that an appointed, Accredited Inspection Body can issue a certificate of compliance with the stipulated requirements.

1.4 Requirements for manufacturer's Quality Assurance and Accreditation

1.4.1 General

The Swedish licensees have established a common system for assessment of suppliers. The requirements for quality assurance have hereby been formalised to enable every single licensee to apply the same or equal requirements on the supplier's quality system.

For quality class 1-3 methods and procedures for performing and reporting of assessment of the suppliers shall be common between the licensees in order to wherever applicable fulfil the IAEA codes and guidelines for quality assurance of the safety in the nuclear plants and other nuclear plants, IAEA Safety series No 50-C/SG-Q. (See SSMFS 2008:13 General advices to 5 chap 3§).

Reports from performed quality audits are submitted to the other licensees. Reports received from other licensees are evaluated and approved for own use providing that the audit contains the requirements stipulated for their own nuclear plants.

The data from this register is only available to the licensee's authorized staff.

1.4.2 Quality System and Quality Plans

The suppliers and their subcontractors shall have and follow a quality assurance system that meets the requirements in applicable parts of SS-EN ISO 9000 series, or another equal, acknowledged standard. When additional quality plans are required for specific projects, these are to follow the guidelines of SS-ISO 10006 "Quality management systems – Guidelines for quality management in projects" or similar.

The above requirement is applicable at purchasing of material, shapes, mechanical equipment, components and services, as well for single parts thereof as for total commitments in quality class 1-4.

To an applicable extent the following documentation shall be submitted to the purchaser:

- A registered copy of the supplier's quality manual.
- A copy of the supplier's certification of the quality system.
- A copy of possible subcontractor's certificates of certifying their quality systems.
- A copy of the certificate or type approval certificate, issued by Accredited Certification Body or Accredited Inspection Bodies.

Essential changes within the organisation and routines of the company which can affect the quality shall be reported to the purchaser as long as the purchaser is a registered proprietor of the supplier's quality manual.

1.4.3 Accreditation

General:

- "Certificate of compliance with the stipulated requirements" is issued by an Accredited Inspection Body that is accredited according to the SSM regulations.
- Testing in the course of repairs of deficiencies in the nuclear plant, installation and in service inspection shall be carried out by an Accredited Laboratory in the position of third party.
- Testing in the course of manufacturing shall be performed by Accredited Laboratories in the position of third party or as in-house inspection randomly supervised by an Accredited Body, A, L or K depending on the type of testing. (Symbols for inspection and testing are defined under 2.1.4). Executing staff shall fulfil the requirements according to 1.8.4. For testing in the course of manufacturing according to PED in quality class 4, NDT performed by staff with competence according to SS-EN 473 may be accepted.
- Providing that the manufacturer applies a quality system, certified by an Accredited Body in the position of third party, for the testing activities, testing in conjunction with manufacturing of material and shapes can be performed as in-house inspection.
- In Sweden pressure testing with gas requires accreditation according to AFS 2006:8.
- Testing as above is defined as non destructive testing (NDT) and mechanical testing of material.

1.4.3.1 *Requirements for Accredited Body in the position of third party*

Accredited bodies in the position of third party are defined as bodies performing certification or inspection services and laboratories performing testing assignments.

A copy of the certificate of accreditation issued by SWEDAC or similar foreign authority shall be sent to the purchaser.

1.4.3.2 *Requirements for Accredited Laboratories in the position of third party within Sweden*

Testing Laboratories performing prescribed NDT and services at material laboratories shall be accredited by SWEDAC for the activities in question. In addition, for testing in the course of installation, repair of deficiencies and in service inspections, these Testing Laboratories shall be accredited in the position as a third party.

Laboratories accredited by SWEDAC for testing in the course of repair of installed equipment and installations, shall at least fulfil the requirements in SS-EN ISO/IEC 17025 and be accredited to SWEDAC's regulations in force, STAFS for testing laboratories and also fulfil requirements from SSM (SSM requirements please see 2.1.8).

1.4.3.3 Requirements for Accredited Laboratories in the position of third party in a foreign country

At manufacturing in a foreign country foreign Testing Laboratories are permitted to perform the testing, providing they are accredited according to requirements similar to the Swedish under 1.4.3.2. This means that the laboratories shall be accredited for the task in question by an organisation that fulfils and apply regulations corresponding to the requirements of the standard SS-EN-ISO/IEC 17025.

1.4.3.4 Requirements for Accredited Inspection Body and Certification Body in the position of third party within Sweden

Accredited Inspection Body that will perform inspection and issue certificate of conformance to the requirements of regulations shall be accredited by SWEDAC for the complete category 1 according to STAFS 1999:4 and other relevant STAFS regulations and also the requirements stated by SSM. (SSM requirements under 2.1.7) In KBM, this body is denoted "K".

Accredited Certification Bodies performing services such as; certification of quality systems and certification of personnel for joining of material and testing, shall be accredited by SWEDAC and at least fulfil the requirements in SS-EN-ISO/IEC 17021/17024.

1.4.3.5 Requirements for Accredited Inspection Body and Certification Body in the position of third party in a foreign country

At manufacturing in foreign country, foreign inspection and certification bodies are permitted to perform the inspection and certification services, if they are according to requirements similar to the Swedish under 1.4.3.4. This means that they shall be accredited for the tasks in question by an organisation that fulfils and apply regulations corresponding to the requirements in SS-EN ISO/IEC 17011.

Inspection Bodies shall be accredited for the tasks in question according to regulations corresponding to SS-EN ISO/IEC 17020.

Certification Bodies shall be accredited for the tasks in question according to regulations corresponding to SS-EN ISO/IEC 17021/17024.

For further information about European co-operation for Accreditation (EA), see their homepage www.european-accreditation.org.

1.4.3.6 Requirements concerning Notified Body

Body for review inspection or surveillance fulfilling the requirements for notified body according to AFS 1999:4.

In KBM this body is denoted "A".

The Notified Body shall be accredited according to SS-EN ISO/IEC 17020.

1.4.4 Assessment of Supplier**1.4.4.1 Assessment**

Assessment of suppliers shall be performed by the licensee and reported to the register of suppliers. The assessment of the supplier may among other things govern the licensee's judgement of extent of inspection.

The evaluation shall be based on:

- Own or others quality audits
- Existing certificates of quality systems
- Existing certificates of accreditation
- Existing "Type Inspection Certificate" or certification of series production
- The licensee's experiences of manufacturers and suppliers

1.4.4.2 Register of suppliers

The register of suppliers shall specify the goods and services each company is approved for. Upon request from the Accredited Inspection Body, it shall be possible to present extract from performed assessments of suppliers.

The following information shall be possible to extract:

- Possible limitations, which must be considered in the course of purchasing
- Services/products that the company can perform/deliver
- Manufacturer's certifications of quality systems. Extent of certification. The Certification Body that performed the certification and the name of the National Accreditation Body that accredited the Certification Body
- The mechanical equipment the type inspection certificates or certifications of series production are valid for
- The companies that have an inspection organisation with the necessary technical resources and staff authorized for NDT level II SS-EN 473 or equivalent
- Experiences of the suppliers
- The validity of assessments, certifications and accreditations

1.5 Rules for Type Inspection Certificate**1.5.1 General**

Type inspection certificate can replace individually issued certificates of compliance for series manufactured equipment, components and stock shapes.

The certificate is an agreement between the manufacturer in question and an Accredited Inspection Body. The agreement regulates conditions regarding design, manufacturing, inspection, testing, marking and documentation and the regularity in the follow-up of quality assessments.

In order to make the purchaser/licensee accepting the type approval certificate process for purchasing, the manufacturer, design, manufacturing, inspection, marking and

documentation shall satisfy the basic requirements in these quality regulations. The purchaser shall verify the credibility.

1.5.2 Scope

Equipment, which can be covered by type inspection certificates, is specified below.

Type inspection certificates can be issued for series production of (SSMFS 2008:13, 5 chap. 3§):

- small pipe fittings ($DN \leq 50 / 2''$ NPS), with ancillaries in quality class 1-4
- other mechanical equipment for the system in quality class 3-4
- seamless and longitudinally welded pipes for systems in quality class 1-4 manufactured by continuous automatic welding providing the pipes are fully tested
- pipe hangers/supports in quality classes 1-4

1.5.3 Obtaining of Type Inspection Certificate

Type inspection certificate can be issued for series manufactured equipment, which after review of documentation for design, manufacturing and inspection, demonstrates that the requirements in SSMFS 2008:13 are fulfilled.

An Accredited Inspection Body shall issue the type inspection certificate.

1.5.4 Purchasing according to Type Inspection Certificate

For purchasing of equipment according to type inspection certificate the purchaser is responsible to ensure that the equipment according to the type inspection certificate fulfils all the requirements of KBM and TBM, this applies from the design criteria up to final marking and documentation.

The purchaser shall define the relevant design criteria, such as load basis, design pressure, design temperature, quality class, materials etc.

If the purchaser has requirements in addition to these stated in the type certificate, this shall be specified.

1.5.5 Documentation

The necessary quality control documentation according to the type inspection certificate shall be delivered together with possible other documentation requested in the order.

1.6 Authorisation for Welding and other Joining Methods

1.6.1 General

Authorisation for welding and other joining is required at manufacturing, installation and repair of pressure retaining and load bearing equipment or other mechanical equipment in all quality classes.

1.6.2 Authorisation requirements for manufacturers and companies that are welding

Welding and other joining shall be carried out by companies with the necessary technical resources and with staff competent in the tasks.

Companies shall be certified for quality assurance for welding according to the requirements of SS-EN ISO 3834-2. An Accredited Certification Body shall perform the certification.

A company that satisfies the requirements of ASME for the intended welding, can after approved judgement by the respective nuclear plant's welding department be regarded to fulfil the authorisation requirements. This evaluation shall where applicable be reviewed by AIB.

Companies that manufacture continuously automatic welded pipes or other welded pipes in pipe mills should have a type inspection certificate issued by an Accredited Body or a manufacturing process certified by an Accredited Certification Body.

Pipe mills fulfilling manufacturing delivery conditions according to SS-EN 10217 are not required to present a type inspection certificate in quality class 4.

Pipe mills, that manufacture welded pipes and do not have a type inspection certificate, or have been certified according to the above, shall have valid documentation and authorisation according to paragraph 1.6.2 to 1.6.4.

Manufacturer of material, which by the purchaser is permitted to carry out weld repairs at manufacturing of steel castings, shall have such competence in welding technique, that areas repaired by welding have strength properties at least equal to the relevant parent metal.

For welding repair after final heat treatment by the manufacturer, paragraph 1.6.2 to 1.6.4 applies.

1.6.3 Requirements for qualification of welding procedure

Welding procedures (WPS) shall pass procedure inspection according to applicable parts of SS-EN ISO 15614.

All welding procedure qualifications, including welding procedure qualifications as per ASME shall be supervised and assessed by an Accredited Body fulfilling the requirements in 1.4.3.4 or 1.4.3.5.

Qualification according to the requirements in SS-EN 288 3-4 and ASME III and IX can also, in some cases be accepted after assessment and approval. If the differences compared with the basic requirement in SS-EN ISO 15614 are evaluated to be too large, additional tests will be required. The additional testing shall be based upon the difference between the EN-standard in force and the performed qualification.

The following additional requirements apply for qualification according to the above:

Welding or other joining procedure shall in the following cases be qualified by corresponding procedure qualifications which are adapted to welding methods, materials, welding conditions and other circumstances:

- For welding or other joining where the standards above are not applicable.
- For welding of material combinations or with methods not covered by the mentioned standards and rules.
- For repair welding of parent metal, or when earlier qualified welding procedure for manufacturing is not representative for intended weld repair (see also TBM chapter 3.1 and 3.3).

The responsible for the welding shall have proper training and have a certificate issued by EWF/IIW according to level EWE/IWE, or other equal training and certification.

EWF =	European Welding Federation
EWE =	European Welding Engineer
IIW =	International Institute of Welding
IWE =	International Welding Engineer

1.6.4 Requirements for certification of welders

Welders and welding operators shall have passed the welding examination with approved results according to SS-EN 287-1-2 alternatively SS-EN ISO 9606 respective SS-EN 1418 alternatively SS-EN ISO 14732.

Certification of welders shall be carried out against qualified and approved welding procedure WPS.

Welders shall in the following cases be examined by corresponding examinations adapted to relevant welding methods, materials, welding conditions and other conditions:

- Welding where the above standards are not valid.
- Welding of material combinations or with methods not covered by the standards mentioned.
- Repair welding of parent metal or when earlier certification for welding is not relevant for intended repair welding (see also TBM chapter 3.1 and 3.3).

Welder is regarded approved when passed the welder qualification with approved result and the welder qualification was supervised, evaluated and approved by an Accredited Body.

Personnel joining plastic pipes and plastic pipe fittings are regarded as authorised for their task if they have passed the examination according to the Swedish Code for plastic piping (PRN 1988).

Welders in foreign companies, who have passed welder qualification according to requirements in ASME IX with approved result, can, in certain cases, be accepted after assessment and approval.

The following conditions are applicable:

- The welder qualification is valid for manufacturing.
- The welder qualification is performed and documented according to the requirements in ASME with Welder/Welding Operator Performance Qualification record. The follow-up shall demonstrate that the welding test has been performed for the relevant welding method. If this is not the case, additional performance tests shall be performed. The procedure for the additional performance test shall be approved by the licensee's welding responsible and be reviewed by an Accredited Inspection Body.
- The welder qualification is supervised and assessed by an Accredited Body.
- The welder qualification has been approved by the licensee.

1.6.5 Personnel qualification for welding at installation and repair

The following also applies for installation welding:

Welder who has not earlier demonstrated the capability to achieve the necessary quality in welding, in a nuclear plant, under realistic conditions for the intended welding, shall pass the qualification test judged necessary by the welding responsible at the respective nuclear plant.

No further qualification is required for welder that shall perform welding during installation if conditions are judged to be similar to the welder qualifications prevailing during the welder examination as per 1.6.4 above.

A welder that shall carry out welding during installation under conditions that are judged to be different from the conditions prevailing during the examination as per 1.6.4 above must in addition be qualified under realistic conditions. Adapted qualification test/training program for welding shall in this case be prepared.

The Qualification test shall be inspected and tested in a corresponding way and according to the inspection documentation (Inspection plan and WPS), which is applicable for intended installation work.

The licensee's responsible welding engineer is to determine when a welder is approved for intended work. This approval shall for quality class 1-4 be reviewed by an Accredited Inspection Body.

For welding repair of installed equipment according to SSMFS 2008:13 4th chapter, 3 §, following also applies:

The welder shall as a basis have passed welding examination with approved result according to paragraph 1.6.4 above and also through qualification tests, under realistic conditions, demonstrate ability to achieve necessary quality in welding for intended repairs.

Performance, scope, welding position geometry, the safety equipment, amount of exercise required etc, shall be evident from the program for repairs relevant to the work.

Qualification tests shall be inspected and tested according to the requirements and acceptance criteria evident from the program for repairs.

Qualification of program for repair of equipment in quality class 1 and 2 shall be supervised and evaluated by an Accredited Inspection Body.

In detail requirements and when a repair program is required, is evident from the technical regulations - TBM.

Validity:

The qualification test is valid as long as the test is relevant for intended welding and the installation inspection has shown that the welder, under realistic conditions, has achieved the necessary quality of the welding.

1.7 Licensee's approval of companies performing heat treatment at manufacture and installation

1.7.1 General

The licensee's approval of companies performing heat treatment is required at manufacturing, installation or repairs of damages in the nuclear plant's pressure retaining and load bearing equipment or other mechanical equipment made of metallic material.

The requirement is applicable for all quality classes.

1.7.2 Authorisation requirements

Heat treatment shall be carried out by companies with the necessary technical resources and by staff that have training, practice, experience and technical knowledge of the tasks.

Companies performing heat treatment of welding and material shall work under a quality system equivalent to SS-EN ISO 3834-2. For material manufacturers, heat treatment shall be part of the certified quality system according to 1.4.2.

1.7.3 Scope

The licensee's approval for heat treatment is required for stress-relief annealing, normalising, solution heat treatment or other heat treatment which, if carried out in an unsatisfactory manner, can impact the mechanical strength properties and heat-treated condition guaranteed by the material manufacturer.

Pipe mills performing heat treatment as part of the pipe welding process should possess a type inspection certificate issued by an Accredited Inspection Body.

In quality class 4, pipe mills fulfilling the current delivery standard SS-EN 10217 are not required to present a type inspection certificate.

Pipe mills not in possession of a type inspection certificate according to the above, must possess a valid qualification according to 1.7.2 above.

1.8 Authorisation for testing and inspection

1.8.1 Authorisation to act as an Accredited Laboratory, Accredited Certification or Inspection Body

See requirements under 1.4.3 "Accreditation".

1.8.2 General for authorisation for testing and inspection

Testing in the below text refers to non-destructive testing (NDT) and mechanical testing of material, so called "destructive testing".

Non-destructive testing (NDT) shall be carried out according to well proven and documented NDT-standards and procedures.

Companies that are performing testing shall possess and adhere to a quality system that controls the testing activity.

The personnel performing NDT services shall be trained, examined and certified according to SS-EN 473 or equivalent system.

Also personnel trained and examined according to the ASNT system may be accepted after approval from the purchaser and the Accredited Inspection Body.

Mechanical testing “destructive testing” shall be carried out according to reliable and documented standards.

Companies which perform other types of inspections, like visual and dimensional inspection, pressure testing etc. at manufacturing, installation and repairs of deficiencies in installed equipment shall have the necessary technical resources and personnel with the necessary training, practice, experience and technical knowledge for the tasks in question.

1.8.2.1 Description of well proven NDT system according to general recommendations to SSMFS 2008:13

Well proven non destructive examination systems is in this context such systems that are based on standard practices referred in acknowledged product standards, or in similar rules for inspection of the type of equipment in question and for which similar quality requirement are stipulated and:

- have been well proven and with documented ability to detect and discriminate , and
- their practical application is defined in technical instructions or examination procedures that include necessary calibration and- user procedures and appertaining method and technique based acceptance standards.

When such well proven examination systems are unavailable the suitability of examination procedures intended to be used shall be demonstrated through qualification in relevant extent according to the principles in chapter 3, 11§ first paragraph and evaluated by a Qualification Body according to chapter 3, 11§ second paragraph in SSMFS 2008:13

1.8.3 Authorisation for testing at manufacturing of material and shapes

Non-destructive testing carried out in conjunction with manufacturing of material and shapes such as plate, bars, beams, extruded and rolled piping along with rough forgings and castings may be carried out as in-house inspection provided that the manufacturer possess and adheres to a quality system certified by an Accredited Body.

1.8.4 Authorisation for testing at manufacture of mechanical equipment

Testing in conjunction with manufacture shall be performed by an Accredited Laboratory in the position of third party or in the form in-house inspection under random supervision by an Accredited Body A, L or K.

Personnel performing NDT services shall be trained, examined and certified according to SS-EN 473 or equivalent standard.

Personnel trained and examined according to the ASNT system may be accepted after approval from the purchaser and the Accredited Inspection Body

If the manufacturer engages an independant testing company, this company to be an Accredited Laboratory in third party position fulfilling the requirements according to 1.4.3.2 in Sweden and 1.4.3.3 in a foreign country.

If the testing is performed by the manufacturing organisation with random supervision by an Accredited Body the test service must be audited according to 1.4.4.

The Accredited Body engaged by the manufacturer shall before the testing be accepted by the purchaser and an Accredited Inspection Body according to SSMFS 2008:13.

For manufacturing of pressurized equipment in quality class 4, testing equivalent to requirements according to PED may be accepted.

1.8.5 Authorisation for NDT at installation and repairs of deficiencies in the nuclear plant

Testing laboratories performing prescribed NDT shall be accredited in the position of third party by SWEDAC for the services they perform.

The accreditation requirements are described in paragraph. 1.4.3.2.

2 GENERAL INSPECTION REQUIREMENTS AND INSPECTION PROCEDURES

2.1 Description of general inspection requirements and inspection procedures

2.1.1 General

The below is a general description of the inspection, testing and documentation requirements that are necessary for the purchaser to ensure that delivered goods and services with regard to quality and design fulfils the specified design criteria and other requirements.

The requirements also states the level, for both prescribed and other inspections and testing, required to fulfil affected authority requirements and thereby make it possible for Accredited Inspection Bodies to issue “certificate of compliance” with applicable regulations. General inspection requirements, “IP” indicate the general scope of the inspection, which the manufacturer shall consider for selection of inspection for the applicable mechanical equipment or service.

The inspection procedures, “EP”, gives in a corresponding way references and instructions regarding scope, performance, acceptance criteria and reporting of testing and inspection activities, that shall be observed by the manufacturer for application and selection of procedures.

The **general quality control requirements** and descriptions of inspection procedures form the base for preparation of **the detailed quality control documents** for the applicable manufacturing, installation or repair of installed equipment. The acceptance criteria in the detailed procedures for testing and inspection shall be adapted to experiences and design margins for the individual design case. The detailed quality control documents shall besides relevant and applicable requirements always contain the inspections and tests the manufacturer considers necessary for granting his full responsibility.

With reference to the mechanical equipment, part of equipment, system or repairs which is applicable for request for quotation or order, the purchaser shall inform the supplier/manufacturer of the relevant general inspection requirements (IP) including the inspection procedures (EP).

The manufacturer may, after permission from the purchaser, use other equal inspection and testing technique as replacement for the techniques specified in the general inspection requirements. If required, it is the purchaser's responsibility that the acceptance is approved by SSM and/or Accredited Inspection Body.

NOTE! The general inspection requirements “IP” and inspection procedures “EP” must be read together.

The detailed quality control documentation shall be adopted for each individual design case.

The required testing, inspection and extent thereof and acceptance criteria is to be judged for each individual case.

2.1.2 General inspection requirements, division and content

2.1.2.1 Division and content

The general inspection requirements (IP) have been prepared for the above types of mechanical equipment and systems in the quality classes 1-4 and 4A with the following division and content:

• Inspection prior to manufacturing, installation or repair	IP-100
• Inspection of base material and finished detail	IP-200
• Inspection at manufacturing, welding and other joining	IP-300
• Inspection of completed equipment and sub-assemblies	IP-400
• Inspection at installation, welding and other joining	IP-500
Inspection of completed installation or repairs.	IP-600

2.1.2.2 Inspection prior to manufacturing, installation or repair of installed equipment

General inspection requirements IP-100 lists the documentation for manufacturing and inspection, which, to an applicable extent, shall be reviewed and approved by the purchaser before manufacturing, installation or repairs is started.

The purchaser is responsible, that the documents approved by him also are reviewed by the Accredited Inspection Body. The extent of review is described in 2.1.7.

The documentation shall be approved by the manufacturer according to his quality assurance routines and be implemented in the detailed inspection plan applicable for the respective work.

By preparation of detailed quality control documents special consideration is to be taken to inspections of parts that are not accessible at the final inspection.

More detailed data about the required documentation and the extent of inspection that applies for the review is evident from chapter 3 "Inspection prior to manufacturing, installation or repair in installed equipment".

2.1.2.3 Inspection of base material and shapes

The inspection requirements for pressure retaining and load bearing material and shapes are normally evident from respective material standard or material specification including technical delivery and inspection regulations thereto. These usually comprise information about the visual and dimensional inspection and non-destructive testing that has to be carried out and the discrepancies and other deviations that can be accepted. The material to be used shall have well documented characteristics, necessary strength at highest design temperature, necessary impact value at lowest design temperature, high durability with regard to ageing, good resistance to ambient environment and good weldability if to be welded.

Material standard or material specification shall be selected according to the directions from the licensee's "Technical Regulations" - TBM.

In the case of standards and specifications for selected materials or delivery conditions do not contain unambiguous requirements for testing, inspection and reporting with regard to their use, the general inspection requirements “IP“ and the general descriptions of the inspection procedures “EP“ can serve as guidance.

General inspection requirements IP-200 generally state the inspection and testing required for base material i.e. material and finished product within specified group of shapes.

The inspection requirements for pressure retaining and load bearing equipment state the prescribed inspection and also include inspection of finished surfaces.

The descriptions of the inspection procedures “EP“ also state the level of inspection and testing the licensees regard suitable.

Material for details for internal parts shall be inspected and tested according to the manufacturer’s material and manufacturing standard, the general requirements of KBM, TBM and also to other in the order stated requirements.

The manufacturer’s requirements for inspection and testing shall, together with reference to the procedures, in detail be evident from the detailed documentation for manufacturing and inspection.

Testing in conjunction with manufacturing of material and shapes can, provided that the manufacturer is applying a certified quality system for control of testing activities, be performed as in-house inspection, see section 1.8.

General data regarding the required testing and inspection and extent of inspection is evident from section 4.1 “General Material Inspection Requirements “IP-200“.

2.1.2.4 Inspection at manufacturing, welding and other joining

General inspection requirements IP-300 state the general inspection and testing requirements at welding and other joining at manufacturing.

General inspection requirements IP-500 state the general inspection and testing requirements at welding and other joining in conjunction with installation and repairs of deficiencies in installed equipment.

Inspection of joining and other manufacturing processes shall be carried out in such a manner, that one makes sure, that the work is carried out by authorised personnel, that approved work documents are used for the work and that other conditions enables an optimum result to be achieved.

Non destructive examination (NDT) shall be carried out with well proven testing systems which by experience have proven ability to detect the flaws and discrepancies which can be caused from the used process for manufacturing, installation and repairs.

NDT of weld joints shall normally be carried out with testing systems and according to standards, whose ability of detection and discrimination by experience have proven capable to reliable identify, areas with discontinuities which cannot be allowed.

Acceptance criteria in standards shall be judged towards each individual design case. The necessary weld quality for steel in pressure retaining and load bearing parts is normally

regarded to meet quality level B according to SS-EN ISO 5817 or equivalent, by experience known acceptable level.

Other weld joints shall meet requirements of quality level C in SS-EN ISO 5817 or equivalent standard.

Guidelines that may apply for NDT acceptance criteria are evident from respective inspection procedure in appendix 1.

In case standardised testing procedures or well proven testing systems are missing, see 1.8.2.1, it is required to prepare qualification documents and perform the NDT qualification in applicable parts similar to the principles as for in service inspection in PBM 2.

The detailed documentation for manufacturing and inspection to be approved by the purchaser shall contain the manufacturer's selected requirements for inspection and testing with reference to the procedures.

Testing in conjunction with manufacturing shall be performed by an Accredited Laboratory in a third party position or through random inspection by Accredited Body of the manufacturer's in-house inspection, see 1.8.4.

Detailed data regarding the inspection and test requirements and the extent of inspection is evident from section 4.2 "Manufacturing/joining -IP-300" and section 5.1 "Installation or repair -IP-500".

2.1.2.5 Inspection of completed equipment or sub-assemblies

General inspection requirements IP-400 generally state the final inspection and testing requirements for completed equipment or sub-assemblies.

The inspection requirements also state requirements for cleanliness, packing, compilation and review of the final quality control documentation.

The detailed manufacture and inspection documentation, to be approved by the licensee and the Accredited Inspection Body prior to start of manufacturing, shall contain, for the equipment in question, well selected requirements for inspection and testing and also references to procedures.

After his own follow-up of the manufacture against approved documentation and review of the quality control documentation, the licensee shall approve the equipment or sub-assembly.

In the review of the quality control documentation shall also verification be performed, that the Accredited Inspection Body, if required, has performed the random supervision as per the detailed inspection plan.

The licensee shall thereafter request the Accredited Inspection Body to perform review of final quality control documentation, carry out object adopted inspection and issue a shop inspection certificate or accept certificate issued by the manufacturer or the licensee.

The final inspection and review by the licensee and Accredited Inspection Body can be performed as a receiving inspection at the nuclear plant or as a final inspection at the manufacturer's facility. Final inspection consisting of internal and external inspection carried out by an Accredited Inspection Body could be needed at manufacturing of complex

equipment, where a large part of the pressure related part will be inaccessible for inspection in conjunction with installation. The stage of the final inspection then is to be stated in the detailed inspection plan.

More detailed data regarding inspection and test requirements and the extent of inspection that applies, is evident from section 4.3 "Completed Mechanical Equipment or sub-assembly IP-400.

2.1.2.6 Inspection of completed installation or repair of installed equipment

General requirements for inspection IP-600 is generally specifying the test requirements, testing, review of inspection records, and reporting that is required for completed installation of system, system part or performed repair.

The detailed documentation for installation and/or repair, which has to be approved by the purchaser, shall contain relevant requirements for inspection and testing and also references to detailed procedures.

Operational test shall be performed at installation of a new system part or if an action has been performed that effects or may effect a system function.

The licensee shall after installation report that the operational test has been carried out, to check that safety valves and other safety equipment functions as intended and to ensure that the system or equipment in general demonstrates proper function.

The licensee shall enable the appointed Accredited Inspection Body to follow the installation work and possible operational tests, and thereby make sure that the work has been carried out according to approved installation documents.

The licensee shall thereafter request the Accredited Inspection Body to carry review the final quality control documentation and issue "Certificate of Compliance".

More detailed data regarding inspection requirements and the extent of inspection that apply is evident from chapter 5, "Inspection of Installation and Repairs".

After the installation or repair the licensee shall certify:

- That the work has been carried out according to approved inspection plan, drawings and other approved documentation for installation or repair.
- That the mechanical components and other equipment being part of the installation are approved.
- That systems, components or other mechanical equipment are provided with permanent and unique identity marking, to enable identification against the documentation for design, manufacture and inspection.
- That the quality control documentation is reviewed by an Accredited Inspection Body and that Certificate of Compliance has been issued

2.1.3 Descriptions of the inspection procedures

The general inspection procedures, EP, contain references and instructions for inspection and testing, procedures, scope, acceptance criteria and requirements for reporting of the carried out inspection or testing.

The manufacturer's selection of inspection procedures, extent of inspection and acceptance criteria shall be made with regard to how the mechanical equipment or system in question is designed, selection of material, geometrical shape, welding methods, strength margins, accessibility for testing, etc.

The inspection procedures constitute part of the purchaser's purchasing documentation for inspection and testing. The inspection procedures may be transformed or replaced by the manufacturer's own adapted instructions for inspection or procedures, when so is considered desirable. The requirements in the purchaser's inspection procedures shall then be considered.

All two-digit and certain three digit inspection procedures constitute *prescribed inspection*.

In front of the two-digit number there is one digit with the following meaning:

- 2- XX = Inspection of base material and finished part.
- 3- XX = Inspection of manufacturing, welding and other joining.
- 4- XX = Inspection of completed mechanical equipment or sub-assemblies
- 5- XX = Inspection of installation, welding and other joining.
- 6- XX = Inspection of completed installation of a system, parts of a system or repair of installed equipment.

When referring to the inspection procedures in the detailed documentation for inspection or certificate of inspection, the applicable number is given in front of the relevant inspection procedure, for instance 2-16, 3-16.

2.1.4 Designations for extent of inspection and supervision

The following designations are used to symbolise the extent of the inspection tasks.

Applicable extent of inspection is specified in the general inspection requirements "IP" and the inspection procedures "EP".

Compulsory and other inspection

The following symbols for allocation are used for extent of testing and inspection in the general inspection requirements:

- E Compulsory in-house inspection or testing, to be carried out by the manufacturer and documented by the independent inspection organisation of the manufacturer. In regulation, Code or standard imperative testing or inspection.
- L Testing to be carried out and documented by Accredited Laboratory. Testing in conjunction with manufacturing of material and shape material may be performed as in-house inspection if the requirements according to 1.8.3 are fulfilled. Testing at other manufacturing may be performed according to 1.8.4.
- K Review, inspection or supervision and certification carried out by Accredited Inspection Body with accreditation for a whole so called category 1 according to STAFS 1999:4.

(2010-09-01 Inspecta Nuclear AB and TüV Nord Sweden AB fulfil these requirements)

- A Review, inspection or supervision and certification carried out by Accredited Notified Body according to AFS 1999:4. Where applicable, also an Accredited Inspection Body (K) may be used for these assignments.
- T Other inspection or testing to be carried out and documented by the manufacturer, as per the requirements of the manufacturer or the purchaser. (Not prescribed by authority).
- B Activity to be supervised, verified, reviewed and/or approved by the licensee/purchaser.
- Q Independent review, inspection or testing to be carried out and, or approved by the inspection organisation of the licensee.

2.1.5 Scope of the inspection

2.1.5.1 Scope of prescribed inspection

The scope of the inspection stated in the purchaser's general inspection requirements and inspection procedures shall in general be taken into consideration. The scope shall serve as guidance for the supplier at the preparation of detailed inspection plans.

Depending on the quality class of the equipment, design characteristics, selected material, manufacturing methods, strength margins, function and size, alternative NDT methods may be used and in specific cases a reduction of the scope of the inspection may be used. The conditions for a reduction of NDT extent can be:

- The design is oversized in a way that the stress falls substantially below permitted limit for the material.
- The design and the method of manufacture are well proven.

In specific cases the manufacturer can already at preparation of the inspection plan, foresee that certain inspection activities cannot be carried out or be assessed meaningful from a quality and inspection technologic point of view.

In these cases alternative NDT methods or other alternative procedures shall be stated in a detailed inspection plan with the object to achieve corresponding safety.

2.1.5.2 Extension of inspection

Extension of the inspection in case discrepancies are discovered shall follow the rules stated in the inspection procedures EP 3-5-24/28. For other testing methods corresponding extension is to be applied.

2.1.5.3 Extended inspection when pressure and tightness testing are not carried out

When impossible, when big difficulties are present or when assessed unsuitable to carry out the prescribed pressure and tightness testing of the equipment-in question, the testing may be replaced by extended inspection and/or NDT after the purchaser's approval and acceptance from Accredited Inspection Body.

Welded joints with requirements for pressure and tightness testing which are not carried out shall at least pass the following inspection:

All welds:

100 % visual and dimensional inspection according to EP-13.

Butt welds and fully penetrating corner welds:

- 100 % volumetric testing with radiographic testing according to EP-28. Alternatively ultrasonic testing according to EP-24 may be carried out if considered more suitable.
- 100 % surface testing with PT or MT of completed weld according to EP-16 or EP-17.

Fillet welds:

- 100 % surface testing with PT or MT of completed weld according to EP-16 or EP-17.

The testing and the inspection above may be necessary to carry out in steps during welding in order to obtain adequate safety.

When this is required may be considered from case to case depending on the reliability in the NDT method selected, the geometry of the welded joint, quality class, weld-efficiency factor, material etc.

Acceptance Criteria:

Revision of the NDT acceptance criteria is normally not required and therefore the same acceptance criteria as stated in each inspection procedure are applicable.

The extent of the inspection and supervision is normally of the same extent as stated in the general inspection requirements.

Coupling joints:

Coupling joints, which are not pressure and tightness tested, shall be subjected to 100 % inspection (EP 5-48) of the installation.

2.1.6 Abbreviations for NDT Methods

The following abbreviations are used for testing methods in the purchaser's general inspection requirements and inspection procedures:

RT Radiographic Testing

UT Ultrasonic Testing

ET Eddy Current Testing

MT Magnetic Particle Testing

PT Penetrant Testing

LT Leak Test

VT Visual Testing

2.1.7 Certificate of Compliance

2.1.7.1 Basic regulations – Conditions for use

Before a nuclear plant, or parts of a nuclear plant, is taken into operation after major repairs, modifications or expansion works etc, a Certificate of Compliance to requirements in SSMFS 2008:13 shall be present. An Accredited Inspection Body engaged by the licensee issues the certificate.

The requirement for a Certificate of Compliance comprise work in the system or parts of the system of the quality classes 1, 2, 3, 4A and 4 inspection class A and B.

In quality class 4 inspection class C 2.1.7.3 applies

2.1.7.2 *The scope of activities to be performed by an Accredited Inspection Body according to SSMFS 2008:13, 5 chapt. 2§ in order to issue Certificate of Compliance*

By modification work in a nuclear plant according to SSMFS 2008:13 chapter 4, 4§ or change of operating conditions the licensee is obliged to ensure that an Accredited Inspection Body is engaged to review design specifications and other design documents to assess that:

- the division into quality classes is based on principles that are notified to the Swedish Radiation Safety Authority and that consideration has been taken to resolutions taken by the Inspectorate concerning the notifications made,
- the design criteria used are notified to the Swedish Radiation Safety Authority and that consideration has been taken to resolutions taken by the Inspectorate concerning the notifications made.

At changes, exchanges and other actions involved in the mechanical equipment, the licensee shall also make sure that an Accredited Inspection Body:

- reviews design loadings, strength analysis and other documents for inspection that chapter 4, 1a§, first part, has been fulfilled.
- performs inspection during and after the installation as well as supervise operational tests according to chapter 4, 11 § and check marking according to chapter 4, 12 §.

If these reviews, supervisions and inspections prove that defined requirements are fulfilled, the Accredited Inspection Body shall issue Certificate of Compliance.

2.1.7.3 *Scope of inspection in quality class 4 according to SSMFS (SSM supervising authority)*

For the scope of inspection for equipment in quality class 4 according to SSMFS 2008:13, that mainly are of importance for the safety of pressure vessels and their integrity also is of importance for the health and safety of the personnel, the division into object categories made in AFS 2005:3 is applied. The design, manufacture, installation and repairs in inspection class C, is thereby carried out as in-house inspection or other inspection. Certificate of Compliance is issued by an Accredited Inspection Body according to SSMFS 2008:13 for quality class 4A and for quality class 4 for inspection class A - C. In quality class 4 inspection class C the Certificate of Compliance is normally issued according to local routines agreed between the licensee and the Accredited Inspection Body.

Accredited Inspection Bodies shall fulfil the requirements according to SSMFS 2008:13, chapter 2 7§.

2.1.7.4 Scope of inspection outside SSMFS (Arbetsmiljöverket, AV, as supervising authority)

For inspection and testing of equipment where SSMFS 2008:13 is not applicable and SSM is not supervising authority, the requirement AFS 1999:4, AFS 1993:41 (rewritten in AFS 1994:53) and AFS 2005:2 apply for manufacturing and installation of pressure retaining equipment. Also see PBM1.

2.1.7.5 Co-operation between licensee and Accredited Inspection Body

The licensee is responsible that the engaged Accredited Inspection Body gets the correct conditions for supervision and review of documentation to be able to perform the activities it is engaged for according to the regulations above. This applies also when the licensee has requested the supplier to engage an Accredited Inspection Body.

Specific inspections that Accredited Inspection Body (AIB) must perform during installation (see SSMFS 2008:13 chapter 5 2§) shall be described in detailed installation inspection plans. The general requirement level is that AIB shall be given opportunity to take part of the installation time plan and get access to the installation sites in order to perform the inspections and monitoring based for "Certificate of Conformity". The inspection that cannot be performed at the final inspection shall be performed in an earlier stage.

2.1.8 Register of applicable regulations, codes and standards

The **latest edition** of codes and standards shall normally be applied.

The below specified regulations, codes and standards are valid by the sanction of KBM edition 6.

Swedish instructions, codes and standards:

AFS 1993:41	Simple pressure vessels
AFS 1994:53	Simple pressure vessels
AFS 1999:4	Statutes of the National Swedish Board of Occupational Safety and Health, PRESSURE RETAINING EQUIPMENT
AFS 2005:2	Statutes of the National Swedish Board of Occupational Safety and Health, MANUFACTURING OF CERTAIN PIPING AND PLANTS.
AFS 2005:3	Statutes of the National Swedish Board of Occupational Safety and Health, INSPECTION OF PRESSURISED EQUIPMENT
AFS 2006:8	Testing with over- or under pressure
PRN 1988	Plastic Piping Codes
SSMFS 2008:13	The Swedish Radiation Safety Authority's regulations about mechanical equipment in certain nuclear plants
STAFS 2009:2	the Swedish Board for Accreditation and Conformity Assessment's (SWEDAC) Regulations and General Guidelines for the Accreditation of Laboratory
STAFS 1999:4	(SWEDAC) Regulations and General Guidelines for the Accredited Inspection Bodies Type A (Inspection Bodies) for inspection of pressure retaining equipment etc.
SS-EN 287-1	Qualification test of welders - Fusion welding - Part 1: Steels

- SS-EN 1418 Welding personnel - Approval testing of welding operators for fusion welding and resistance weld setters for fully mechanized and automatic welding of metallic materials
- SS-EN 1983:2006 Industrial valves - Steel ball valves
- SS-EN 10204 Metallic products - Types of inspection documents
- SS-EN 10217 (-1-6) Welded steel tubes for pressure purposes
- SS-EN 12266-1 Industrial valves - Testing of valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements
- SS-EN 14532-1:2005 Welding consumables - Test methods and quality requirements - Part 1: Primary methods and conformity assessment of consumables for steel, nickel and nickel alloys
- SS-EN 14700:2005 Welding consumables - Welding consumables for hard-facing
- SS-EN ISO 643 Steels - Micrographic determination of the apparent grain size (ISO 643:2003)
- SS-EN ISO 3834-2 Quality requirements for fusion welding of metallic materials - Part 2: Comprehensive quality requirements (ISO 3834-2:2005)
- SS-EN ISO 5817 Welding – fusion welding joint of steel, nickel, titanium and their alloys (with exception for beam welding) – Quality levels for discontinuity and shape deviations
- SS-EN ISO 9606 (-2-5) Approval testing of welders - Fusion welding
- SS-EN ISO 15614 Specification and qualification of welding procedures for metallic materials
- SS-EN ISO/IEC 17011 Conformity assessment - General requirements for accreditation bodies accrediting conformity assessment bodies (ISO/IEC 17011:2004)
- SS-EN ISO/IEC 17020 General criteria for the operation of various types of bodies performing inspection (ISO/IEC 17020:1998)
- SS-EN ISO/IEC 17021 Conformity assessment - Requirements for bodies providing audit and certification of management systems (ISO/IEC 17021:2006)
- SS-EN ISO/IEC 17024 Conformity assessment - General requirements for bodies operating certification of persons (ISO/IEC 17024:2003)
- SS-EN ISO/IEC 17025 General requirements for the competence of testing and calibration laboratories (ISO/IEC 17025:2005)
- SS-ISO 10006 Management systems for quality – Guidelines for quality plans in project
- NDT-Standards**
- SS-EN 473 Non destructive testing - Qualification and certification of NDT personnel - General principles
- SS-EN ISO 17635 Non-destructive testing of welds - General rules for metallic materials
- Visual Inspection (VT)**
- SS-EN 970 Non-destructive examination of fusion welds - Visual examination
- Radiographic testing**
- SS-EN 444 Non-destructive testing - General principles for radiographic examination of metallic materials by X- and gamma-rays
- SS-EN 462 (-3) Non-destructive-testing of - Image quality of radiographs - Part 3: Image quality classes for ferrous metals
- SS-EN 584 (1-2) Non-destructive testing - Industrial radiographic film
- SS-EN 1435 Non-destructive examination of welds - Radiographic examination of welded joints
- SS-EN 12517 Non-destructive testing of welds

- SS-EN 12681 Founding - Radiographic examination
 SS-EN 25580 Non-destructive testing - Industrial radiographic illuminators -
 Minimum requirements (ISO 5580:1985)

Ultrasonic testing (UT)

- SS-EN 583 (1-5) Non-destructive testing - Ultrasonic examination
 SS-EN 10160 Ultrasonic testing of steel flat product of thickness equal to or greater
 than 6 mm (reflection method)
 SS-EN 10228 (-3, -4) Non-destructive testing of steel forgings UT of steel forgings
 SS-EN 10307 Testing of austenitic and austenitic-ferritic stainless steels flat products
 of thickness equal to or greater than 6 mm (reflection method)
 SS-EN 10308 Non destructive testing - Ultrasonic testing of steel bars
 SS-EN ISO11666 Testing of welded joints – Ultrasonic testing Acceptance levels
 SS-EN 12680 (-1-3) Founding - Ultrasonic examination
 SS-EN ISO 17640 Non-destructive testing of welds - Ultrasonic testing of welded joints
 SS-EN ISO 22825 Non-destructive testing of welds - Ultrasonic method - Testing of welds
 in austenitic steels and nickel-based alloys (ISO 22825:2006)

Inductive testing (ET)

- SS-EN ISO 1711 Non-destructive examination of welds - Eddy current examination of
 welds by complex plane analysis
 SS-EN 1971 Copper and copper alloys - Eddy current test for tubes
 SS-EN 10246 (-1,-3) Non destructive testing of steel tubes
 SS-EN 12084 Non-destructive Eddy current testing General principles and guidelines
 SS-EN ISO 15548 Non-destructive testing - Equipment for eddy current examination

Penetrant testing (PT)

- SS-EN 571-1 Non-destructive testing - Penetrant testing - Part 1: General principles
 SS-EN 1371(-1-2) Founding - Liquid penetrant inspection
 SS-EN ISO 3452 (-2-6) Non-destructive testing - Penetrant testing
 SS-EN ISO 23277 Non-destructive testing of welds - Penetrant testing of welds -
 Acceptance levels (ISO 23277:2006)

Magnetic particle testing (MT)

- SS-EN 1369 Founding - Magnetic particle inspection
 SS-EN ISO 9934 (-1-3) Non-destructive testing - Magnetic particle testing
 SS-EN ISO 17638 Non-destructive testing of welds - Magnetic particle testing (ISO
 17638:2003)
 SS-EN ISO 23278 Non-destructive testing of welds - Magnetic particle testing of welds -
 Acceptance levels (ISO 23278:2006)

Foreign standards:

ASNT SNT-TC-1A	American Society for Non Destructive Testing Recommended Practice No. SNT-TC-1A - Non-Destructive Testing
ISO 9712	Non-destructive testing -- Qualification and certification of personnel
ISO 14732	Welding personnel - Approval testing of welding operators for fusion welding and of resistance weld setters for fully mechanized and automatic welding of metallic materials

2.2 Listing of general inspection requirements**2.2.1 General inspection requirements prior to manufacture, installation and repair***Mechanical equipment, sub-assemblies systems*

Designation	Equipment	Quality class
IP-100	Pressure retaining and load-bearing equipment and internal parts intended to protect them ¹	1-4 and 4A
	Internal parts in reactor pressure vessel in quality class	2-4
IP-101	”Others” ²	
IP-102	Internal parts in mechanical equipment Others than intended in IP-100	1-4, 4A
IP-103	Repair. Pressure retaining and load bearing equipment and internal parts in reactor pressure vessel	1-4 and 4A

SSM is supervision authority for all safety-classified parts. Quality class is used for mechanical parts where SSMFS 2008:13 is the primary regulation.

In quality class 1-4 and 4A, the Swedish Radiation Safety Authority, SSM is supervision authority.

¹⁾ The meaning here is sleeves, agitators and similar internal parts mounted in a mechanical equipment in order to protect it towards thermal and other loads. (SSMFS 2008:13, chapter 1, 2§).

²⁾ Examples of “Others” may be:

- HVAC-equipment
- Installation of cable racks
- Flooding protection

”Others” may be used for safety-classified parts outside of SSMFS 2008:13. ”Others” may also be used for parts where SSM not is the supervising authority.

2.2.2 Pressure-retaining equipment or components

Designation	Material/shape	Quality Class
IP-201/1	Forgings and bars	1 and 2
IP-201/3		3, 4 and 4A
IP-202/1	Castings	1 and 2
IP-202/3		3, 4 and 4A

IP-203/1	Plates	1 and 2
IP-203/3		3, 4 and 4A
IP-204/1	Pipes and pipe fittings	1 and 2
IP-204/3		3, 4 and 4A
IP-205	Heat exchanger tubes	2, 3, 4 and 4A
IP-206/1	Bolts and nuts	1 and 2
IP-206/3		3, 4 and 4A
IP-207/1	Bellows for valves	1-3, 4 and 4A
IP-208/2	Bellows for pressure vessels and pipes	2, 3, 4 and 4A
IP-209/1	Valve closing devices	1-3, 4 and 4A

Load-bearing equipment or sub-assemblies

Designation	Material/shape	Quality Class
IP-221	Plates and forgings for load-bearing equipment including pipe restraints	1-3, 4 and 4A
IP-222	Material for fasteners in concrete	1-3, 4 and 4A

Internal parts according to IP 102

(In this case quality class refers to the main component and not the internal part)

Designation	Material/shape	Quality Class
IP-230	Plate, bar, pipe and forging in internal parts	1-4 and 4A

Internal parts according to IP 100 and internals in steam generators

Designation	Material/shape	Quality Class
IP-240	Plate, bar, pipe and forgings for internals	1-4 and 4A

2.2.3 General inspection requirements at manufacture, welding and other joining

Mechanical equipment or parts of devices

Designation	Quality Class
IP-301/1	1-3, 4 ic A-B and 4A
IP-301/4	4 ic C

2.2.4 General inspection requirements for completed mechanical equipment or part of device

Designation	Equipment	Quality Class
IP-401	Pipes and pipe fittings	1-4 and 4A
IP-402	Valves and other ancillaries	1-4 and 4A
IP-403	Pumps	2-4 and 4A
IP-404	Heat exchangers and pressure vessels	2-4 and 4A
IP-405	Tanks	2-4 and 4A
IP-406	Process instrumentation	1-4 and 4A
IP-407	Load bearing equipment such as: hangers, supports and pipe restraints.	1-4 and 4A

2.2.5 General inspection requirements – installation or repair

Designation	Equipment	Quality Class
IP-501	Mechanical equipment or parts thereof	1-4 and 4A

2.2.6 General inspection requirements – Installed system or part of system or repair

Designation	Equipment	Quality Class
IP-601	Mechanical equipment or parts thereof	1-4 and 4A

2.3 Listing of applicable inspection procedures

Explanations of the designation system for the inspection procedures are described in section 2.1.3.

2.3.1 Descriptions of inspection procedures – Prescribed or inspection and testing according to code

Designation	Type of inspection or testing
EP 2-00	Identity or material quality certificates
EP 2-01	Charge analysis
EP 2-02	Tensile testing
EP 2-03	Hot tensile testing
EP 2-04	Impact testing
EP 2-05	Hardness testing
EP 2-06	Other technological testing
EP 2-07	Intergranular corrosion testing
EP 2-08	Grain size test
EP X-09	Marking and identification
EP X-10	Inspection of heat treatment
EP X-11	Testing of filler material
EP X-12	Welding inspection
EP X-13	Visual and dimension inspection
EP X-14	Pressure and tightness testing
EP X-15	Inspection of fasteners in concrete
EP X-16	PT
EP X-17	MT
EP X-18	ET
EP 2-19	ET Inductive testing of heat exchanger tubes
EP 2-20	UT after manufacturing of plate
EP 2-21	UT of forging, bar and bolt material
EP 2-22	UT of pipes
EP X-23	UT of cladding or hard facing
EP X-24	UT of weld joints
EP 2-27	RT of castings
EP X-28	RT of weld joints
EP X-29	VT of weld joints
EP X-43	Bending of pipes
EP X-48	Installation of pipe couplings
EP 6-50	Operational test
EP 6-60	Inspection of installation
EP-190	Review of final quality control documentation
EP-286	Cold bending of heat exchanger tubes
EP-376	Inspection of repairs in weld joints

"X" above = Symbol for inspection procedure which has a varying figure before the identification number.

2.3.2 Descriptions of inspection procedure – Other inspection and testing

Designation	Type of inspection or testing
EP-425	Inspection of cleanliness
EP-435	Inspection of packaging and preserving
EP-441	Tightness testing – Check valves and isolation valves
EP-442	Tightness testing – Control valves without isolating function
EP-443	Tightness testing – Safety valves for liquids
EP-444	Tightness testing – Safety valves for steam and air
EP-451	Function test – Check valves, control valves and isolation valves
EP-453	Function test – Safety valves
EP-454	Function test – Centrifugal pumps
EP-457	Function test – Reciprocating pumps
EP-486	"Strip test" – pumps etc.
EP-490	Balancing
EP-560	Cleanliness inspection of systems

3 INSPECTION PRIOR TO MANUFACTURING, INSTALLATION AND REPAIR OF INSTALLED EQUIPMENT

3.1 General inspection requirements prior to manufacturing and installation IP-100 – IP-102

Pressure retaining and load bearing equipment along with internal parts intended to protect them¹ in quality class 1-3, 4A and 4³ IP-100
 Internal parts in reactor pressure vessels in quality class 1-4
 ”Others”² IP-101
 Internal parts for mechanical equipment in quality class 1-4, others than the ones intended in IP 100 IP-102

1) The meaning here is sleeves, agitators and similar internal parts mounted in a mechanical equipment in order to protect it towards thermal and other loads. (SSMFS 2008:13, chapter 1 2§).

2) Examples of “Others” may be:

- HVAC- equipment
- Installation of cable racks
- Flooding protection

”Others” may be used for safety-classified parts outside SSMFS 2008:13. “Others” may also be used for parts where SSM is not regulatory authority.

3) K (AIB) is not required in quality class 4 inspection class C and not for internal parts in quality class 4.

3.1.1 General inspection requirements prior to manufacturing and installation IP-100

**Pressure retaining and load bearing equipment along with internal parts intended to protect these in quality class 1-4 and 4A
 Internal parts in reactor pressure vessel in quality class 2-4:**

Extent of inspection	Allocation (Ch. 2.1.4)	Specification (Ch. 3.3)
1. Review of the documentation that shall be prepared and reported by the purchaser/licensee		
1.1 Description and report with criteria	B,Q	3.3.2.1
1.2 Design specification	B,Q,K ²	3.3.2.2
1.3 Design criteria	B,Q,SSM	3.3.2.2
1.4 Design loadings	B,Q,K ²	3.3.3.3
1.5 Valid assessment of suppliers	E,B,Q	3.3.2.3
1.6 Updating of flow charts	B,Q,K ²	3.3.2.4
1.7 Updating of classification lists/charts	B,Q,K ²	3.3.2.5

	Extent of inspection	Allocation (Ch. 2.1.4)	Specification (Ch. 3.3)
2	Review of the documentation that shall be prepared and reported by the supplier or manufacturer and approved by the purchaser or licensee.		
2.1	Valid supplier assessment of the subcontractors	E,B,Q	3.3.3.1
2.2	Project adapted quality assurance program for installation	E,B,Q	3.3.3.2
2.3	Design review	E,B,Q,K ²	3.3.3.3
	- Drawings		
	- Calculations		
	- Welding procedures (WPS)		
	- Welding procedure qualification records (PQR, WPAR)		
	- Heat treatment procedure ¹		
	- Qualification report for heat treatment ¹		
	- Forming procedure		
	- Qualification report for forming procedure		
	- Procedure for installation of couplings		
	- Procedure for installation of fasteners		
2.4	Review of detailed inspection documents	E,Q,K ²	3.3.3.4
	- Inspection plan		
	- NDT procedures		
	- Program for pressure and tightness testing		
2.5	Review of the company's authorisation for joining of material	E,Q,K ²	3.3.3.5
	- Licence for the field of action		
	- Certification of personnel		
	- Qualification of personnel		
2.6	Inspection of the company's authorisation for heat treatment	E,Q,K ²	3.3.3.6
2.7	Inspection of the company's NDT authorisation	E,Q,K ²	3.3.3.7
	The company's certificate of accreditation and the extent of the accreditation		
	Personal certificate of examination/diploma		
	Authorisation given by the company/laboratory		

Remarks:

At manufacturing of equipment to quality class 4, the normal inspection extent according to AFS (see 0.1) is valid and the inspection procedure according to above may be performed by A.

If additional requirements in addition to the fundamental requirements in AFS applies, these are defined by the purchaser (B).

- 1) Heat treatment is normally a part of the welding procedure.
- 2) K (AIB) is not required in quality quality class 4 inspection class C, see 2.1.7.3.

3.1.2 General inspection requirements prior to manufacturing and installation - IP-101**”Others”**

	Extent of inspection	Allocation (Ch. 2.1.4)	Specification (Ch. 3.3)
1.	Review of the documentation that shall be prepared and reported by the purchaser/licensee		
1.1	Description and report with criteria	B,Q	3.3.2.1
1.2	Design specification	B,Q	3.3.2.2
1.3	Design criteria	B,Q	3.3.2.2
1.4	Design loadings	B,Q	3.3.3.3
1.5	Valid assessment of suppliers	B,Q	3.3.2.3
1.6	Updating of flow charts	B,Q	3.3.2.4
1.7	Updating classification lists / charts	B,Q	3.3.2.5
2.	Review of the documentation that shall be prepared and reported by the supplier or manufacturer and approved by the purchaser or licensee		
2.1	Valid supplier assessment of subcontractors	T,B,Q	3.3.3.1
2.2	Project adapted quality assurance program for installation	T,B,Q	3.3.3.2
2.3	Design review	E,B,Q,A ¹	3.3.3.3
	- Drawings		
	- Calculations		
	- Welding procedures (WPS)		
	- Heat treatment procedure ²		
	- Qualification report for heat treatment ²		
	- Forming procedure		
	- Qualification report for forming procedures		
	- Procedure for installation of couplings		
	- Procedure for installation of fasteners		
2.4	Review of detailed inspection documents	E,Q,A ¹	3.3.3.4
	- Inspection plan		
	- NDT Procedures		
	- Program for pressure and tightness testing		
2.5	Review of the company’s authorisation for joining of material	E,Q,A ¹	3.3.3.5
	- Certification of line of activities		
	Certification of personnel		
2.6	Review of the company’s authorisation for heat treatment	E,Q,A ¹	3.3.3.6
2.7	Review of the company’s NDT authorisation	E,Q,A ¹	3.3.3.7

- The company's certificate of accreditation and the extent of the accreditation.
- Personal certificate of examination/diploma
- Authorisation given by the company/laboratory

Remark:

For inspection class C "E" may be replaced by "T".

- 1) The extent and performance of design review and other reviews shall for pressurised equipment fulfil the requirements in AFS.
- 2) Heat treatment is normally a part of the welding procedure.

3.1.3 General inspection requirements prior to manufacturing and installation IP-102**Internal parts for mechanical equipment, other than those referred in IP-100
Quality class 1-4 and 4A**

Extent of inspection	Allocation (Ch. 2.1.4)	Specification (Ch. 3.3)
1. Review of the documentation that shall be prepared and reported by the purchaser or licensee		
1.1 Description and report with criteria	B,Q	3.3.2.1
1.2 Design specification	B,Q	3.3.2.2
1.3 Design criteria	B,Q	3.3.2.2
1.4 Design loadings	B,Q	3.3.3.3
2. Review of the documentation that shall be prepared and reported by the supplier or manufacturer and approved by the purchaser or licensee.		
2.1 Valid supplier assessment of the subcontractors	T,B,Q	3.3.3.1
2.2 Project adapted quality assurance program for installation	T,B,Q	3.3.3.2
2.3 Design Review	T,B,Q	3.3.3.3
- Drawings		
- Calculations		
- Welding procedures (WPS)		
- Welding procedure qualification records (PQR, WPAR)		
- Heat treatment procedure ¹		
- Qualification report for heat treatment		
- Forming procedure		
- Qualification report for forming procedure		
2.4 Review of detailed inspection documentation	T,Q	3.3.3.4
- Inspection plan		
- NDT Procedures		
- Program for pressure and tightness testing		

2.5	Review of the company's authorisation for joining of material	T,Q	3.3.3.5
	- Certification of line of activities or similar		
	- Certification of personnel		
	- Qualification of personnel		
2.6	Review of the company's authorisation for heat treatment	T,Q	3.3.3.6
2.7	Review of the company's NDT authorisation	T,Q	3.3.3.7
	- The company's certificate of accreditation and the extent of the accreditation		
	- Personal certificate of examination/diploma		
	- Authorisation given by the company/laboratory		

Remarks:

In general, the above requirements are valid in applicable parts depending on type of equipment or part.

As an example when deemed appropriate well proven mechanical equipment may then be accepted with the standard testing and inspection applied by the manufacturer for respective quality class and type of equipment.

¹⁾ Heat treatment is normally a part in the welding procedure.

3.2 General inspection requirements prior to repairs of mechanical equipment - IP-103

Valid for repair of deficiencies in installed mechanical equipment induced by plant operation.

3.2.1 General inspection requirements prior to repair of deficiencies induced by plant operation - IP-103

Pressure retaining and load bearing mechanical equipment and internal parts intended to protect them.

Internal parts in reactor pressure vessel

Quality class 1-4 and 4A

	Extent of inspection	Allocation (Ch. 2.1.4)	Specification (Ch. 3.3)
1.	Review of the documentation that shall be prepared and reported by the purchaser or licensee		
1.1	Description and report with criteria	B,Q	3.3.2.1
1.2	Design specification	B,Q,K ³	3.3.2.2
1.3	Design criteria	B,Q,SSM	3.3.2.2
1.4	Design loadings	B,Q,K ³	3.3.3.3
1.5	Valid assessment of the supplier	E,B,Q	3.3.2.3
1.6	Safety review and notification to SSM by removal of deficiencies without repair	B,Q,SSM	3.3.2.6
2	Review of the documentation that shall be prepared and reported by the supplier or manufacturer and approved by the purchaser or licensee		
2.1	Valid assessment of the subcontractors	E,B,Q	3.3.3.1
2.2	Project adapted quality assurance program for repairs	E,B,Q	3.3.3.2
2.3	Machining	E,B,Q,K ^{2,3}	3.3.3.8
	- Machining procedures		
	- Qualification program		
	- Qualification report		
	- Qualification of staff		

2.4	Repairs (normally welding) - Repair procedure - Qualification program - Qualification report - Qualification of staff	E,B,Q, K ^{2,3}	3.3.3.9
2.5	Design review - Drawings - Calculations - Welding procedures (WPS) - Welding procedure qualification records (PQR, WPAR) - Heat treatment procedure - Qualification report for heat treatment - Forming procedure - Qualification report for forming procedure	E,B,Q,K ³	3.3.3.3
2.6	Review of detailed inspection documentation - Inspection plan - NDT Procedures - Program for pressure and tightness testing	E,Q,K ³	3.3.3.4
2.7	Review of the company's welding authorisation - Certification of the line of activities - Certification of welders - Qualification of welders	E,Q,K ³	3.3.3.5
2.8	Review of the company's authorisation for heat treatment	E,Q,K ³	3.3.3.6
2.9	Review of the company's NDT authorisation - The company's certificate of accreditation and the extent of the accreditation - Personal certificate of examination/diploma - Authorisation given by the company/laboratory	E,Q,K ³	3.3.3.7

Remarks:

- 1) The repair of equipment belonging to any of the quality classes 1 or 2 must not be initiated until probable reason for the failure is clarified.
- 2) The qualification shall be supervised and evaluated by an Accredited Inspection Body.
- 3) K (AIB) is not required in quality class 4 inspection class C

3.3 Inspection specification – Inspection prior to manufacturing, installation or repair of installed equipment.

3.3.1 Introduction

Below describes the requirements for manufacturing, installation and repair documentation that shall be prepared and approved before the work may be started. The documentation shall be reviewed and approved by the manufacturer and the purchaser in accordance with the quality assurance program of the companies in question, and shall whenever applicable also be reviewed by an Accredited Inspection Body.

Verification of performed inspection shall be part of the final inspection documentation.

Copies of reports, authorisations, certificates and other documents mentioned below, shall be part of the final inspection documentation.

3.3.2 Documentation to be prepared by the purchaser or licensee

3.3.2.1 *Description and/or report, with conditions for action to be taken*

Project report, modification memorandum, general maintenance instruction or equivalent shall be prepared including a description of the work to be carried out, how this shall be done and the conditions for the work planned.

Example of contents:

- Documentation needed for the evaluation of effects on the existing nuclear plant.
- Clarification of effects on safety, availability and protection.
- Clarification that the modification, maintenance work or repair satisfies prescribed requirements.
- Clarification of prescribed requirements according to code, function and other requirements.
- Clarification of classification and design specification.
- Documentation serving as a basis for detailed design.

3.3.2.2 *Design specifications*

The design criteria, based on valid safety analysis report (SAR), shall be specified according to the principles in TBM for the respective nuclear plant. For modification work according to SSMFS 2008:13, chapter 4, 4§, a design criteria according to the principles in TBM shall be prepared.

The design specifications and included design criteria and design loadings, shall be specified by the purchaser in conjunction with purchase of replacement equipment, installation work or repair.

The design criteria included in the design specifications shall be safety reviewed and notified to SSM.

For modifications or changes in operation conditions where the design criteria will be **changed**, the new **valid** design criteria shall be safety reviewed and notified to SSM.

For modifications where the design criteria have **not been changed** the **valid** design criteria shall be presented.

The design criteria and possible decision from SSM shall be enclosed to the documentation to be reviewed by the appointed Accredited Inspection Body. For the extent of the review of the Accredited Inspection Body, see section 2.1.7.

For further details concerning design specifications and design criteria, see Technical Regulations - TBM.

3.3.2.3 Supplier assessment

Suppliers and their subcontractors shall possess and adhere to a quality assurance system that meets applicable parts of the requirements of SS-ISO 9000, or other equivalent acknowledged standard.

The licensee shall perform supplier assessment.

Further details concerning assessment of suppliers, see section 1.4.

3.3.2.4 Updating of flow charts

Flow charts, inter-locking lists and records of the set pressure for the safety valves shall be kept up-to-date.

3.3.2.5 Updating of classification lists

Classification lists shall be kept up-to-date.

3.3.2.6 Basic repair documentation

Prior to removal of cracks and other defects, which can endanger the future safety in a device, the following shall be clarified:

- The necessary strength margins must be maintained and all necessary geometric conditions and surface structures can be achieved.
- A probable reason for the incident shall be determined and necessary actions shall be taken to prevent the forming of new deficiencies.

The licensee shall report the results of the above calculations and analyses.

Repairs of equipment must not be started until a probable cause to the incident has been found and clarified. Qualification of method for machining and/or repairs intended for equipment belonging to any of the quality classes 1 or 2 shall be supervised and evaluated by an Accredited Inspection Body.

Work or repairs in parts of barriers and/ or mechanical equipment that is of importance for the defence-in-depth shall be safety reviewed. More in detail concerning structural integrity and repair, see Technical Regulations - TBM.

3.3.3 Documentation to be prepared by the supplier or manufacturer

3.3.3.1 Supplier assessment of sub-contractors

On the purchaser's demand, the supplier shall report the results of his assessment of sub-contractors.

3.3.3.2 Quality plan for installation and repairs of installed equipment

Works concerning equipment important for safety and operational availability must be carried out under well controlled conditions. A quality assurance program shall cover the activities. In case the manufacturer lacks an approved quality assurance program a project adapted quality plan to be prepared. The plan shall follow the guidelines of SS-ISO 10006 "Quality management – Guidelines for quality plans" and be adapted to the particular work and the need for control so that performance and documentation is carried out in accordance with the applicable requirements.

The quality plan shall give a description of:

- The manufacturer's organisation and a plan for the performance of the work
- Assessment of sub-contractors
- Document control
- Material control
- Control and performance of inspection and testing
- Co-operation and reporting to the purchaser
- Documentation turn over, deviations and documentation

3.3.3.3 Design review

The design review shall assure that the documentation stated below is coherent with the design criteria stated by the purchaser, the requirements in TBM, KBM and other specifications valid for the equipment issued by the purchaser.

Drawings

The review shall comprise drawings for design, welding and adherent material specifications. The review shall verify that the documentation contains the data of importance for the pressure vessel safety, function, manufacture, inspection, installation and in-service inspection and also verify that they are correctly specified. For external purchasing of equipment, the manufacturer may due to proprietary reasons be unwilling to disclose data about e. g. fit and tolerances to other companies, this will normally be accepted.

Drawing shall to an applicable extent, comprise or refer to at least the following information:

- Nuclear plant, unit, system and component number
- Design pressure and design temperature and data of test pressure
- Quality classification
- Inspection plan

- Material specification and material grade
- Dimensional standard and pressure rating-of parts and components
- Dimensions and measurements shall be detailed to the extent required for the design calculations
- Welding specification

Design loadings

In the design criteria events and combinations of events to be considered for mechanical equipment, are defined. Events including the event class unlikely event shall be considered in the design loadings.

Calculations

The review of strength calculations shall be carried out to an extent stated in the respective mechanical design criteria (KFM).

The calculation report shall contain references to design loadings, drawings, methods used for calculations and other information important for the verification of the result. The review shall verify that strength calculations have been carried out and that the results meet the specific requirements.

Manufacturing and installation procedures

Review of manufacturing and installation procedures and qualification reports shall verify the fulfilment of the requirements in TBM and KBM and other requirements stated by the purchaser.

Procedure for installation of fasteners in concrete and for installation of pipe couplings shall comprise instructions to ensure a safe and satisfactory installation.

Examples of procedures and procedure qualification reports, which to applicable extent shall be presented:

- Welding procedures WPS
- Welding procedure qualification report (WPAR/WPQR)
- Heat treatment procedure
- Heat treatment procedure qualification report
- Forming procedure
- Forming procedure qualification report
- Procedure for installation of couplings
- Procedure for installation of fasteners
- Procedure for cleanliness inspection
- Procedure for function inspection

3.3.3.4 Review of detailed inspection documentation

Detailed inspection plan

The review shall verify that the detailed inspection plans include the adopted inspection and testing required according to KBM.

Detailed inspection plans shall also include:

- Reference to detailed drawing
- Quality class
- Type and extent of tests and inspections at different stages, before, during and after manufacturing, installation or repair.
- Allocation of inspection assignments - "Extent/ Supervision".
- Reference to the detailed inspection documentation, which the manufacturer intends to use for the inspection and testing activity.
- Reference to the manufacturer's detailed procedures for NDT.
- Reference to the purchaser's inspection procedure KBM-EP in case these are used as a detailed inspection basis.
- The tests and inspections the manufacturer considers needed for his full responsibility for the device.
- The added inspection, which is required when no pressure and tightness test is intended to be made.

NDT Procedures

The review shall verify that the detailed NDT procedures fulfil the requirements of applicable inspection procedure KBM-EP, and applies to all the procedures that according to the inspection procedure require preparation of procedure.

NDT procedures shall contain all necessary data for performance of the testing, evaluation and reporting of the result. The procedures shall comply with the requirements of the purchaser's inspection procedures. Requirements on the content of the NDT procedures are specified in the applicable KBM-EP inspection procedures.

For the testing with well proven and well suited methods there is normally not a requirement to prepare a detailed procedure providing that this is not stipulated by the standard in question. As an example UT of plate according to SS-EN 10160, the result reported in a test certificate as per SS-EN 10204-3.1 is in this case regarded as sufficient.

NDT procedure for testing of machined surfaces in conjunction with repairs of operational induced deficiency shall in applicable extent be qualified and evaluated according to chapter 3, 11§ in SSMFS 2008:13.

Pressure and tightness test program

The manufacturer shall in conjunction with the manufacturing prepare a program for pressure and tightness testing.

The manufacturer or, in certain cases the licensee, prepares a program for pressure and tightness test for installation or repair. Requirements of the content in the program are defined in the inspection procedure.

The program shall be reviewed and approved by the licensee according to his routines. The review shall verify compliance with the applicable inspection procedure. The review shall also verify compliance with other requirements from the licensee such as among other things the line-up for operation and isolation of the affected system or parts thereof.

3.3.3.5 *Review of the company's welding authorisation*

A valid certificate of welding license or certificate, issued by an Accredited Certification Body against SS-EN 3834-2 or ASME certificate shall be presented.

Authorisation for the above mentioned welding shall comprise all the welding methods, combinations of materials and geometry's required for the welding to be performed.

The requirements are stated in 1.6.2.

Certification of welders

Copies of valid certificates for welder qualification shall be presented.

The requirements are stated in 1.6.4.

Qualification of staff

Certificates of qualification tests according to requirements in qualification program shall be presented.

The requirements are stated in 1.6.5.

3.3.3.6 *Review of the company's heat treatment authorisation*

Heat treatment of welding shall be part of the welding procedure qualification according to 1.6.3.

Other requirements for heat treatment are stated in 1.7.

3.3.3.7 *Review of the company's NDT authorisation*

The following records shall be available for review during the testing and also be included in the final inspection records:

- The company's certificate of accreditation and the extent of the accreditation.
- Personal certificate of examination or diploma
- Authorisation given by the company/laboratory

The requirements are stated in 1.8.

3.3.3.8 Review of documentation for removal of service induced deficiencies

Service induced deficiencies in installed equipment may be removed without repair of the material or weld material if, at least, below defined documents are safety reviewed and approved by the licensee and reviewed by an Accredited Inspection Body:

- Machining procedure
- Qualification program for machining procedure
- Qualification report

Qualification of method for machining intended for use in equipment belonging to quality class 1 or 2 shall be supervised and assessed by an Accredited Inspection Body.

In addition to the above mentioned machining documents design specifications, design criteria, design loadings and strength analysis shall be prepared to the extent required for the intended measure. This type of measure is by SSM considered to be a nuclear plant modification and shall be reviewed by an Accredited Inspection Body to the extent specified in 2.1.7.2.

3.3.3.9 Review of documentation for repair of service induced deficiencies, normally welding

Repairs of installed equipment shall be carried out according to repair program qualified for the specific purpose, which can restore the required properties by safe margin for the equipment to meet the basic requirements for proper use.

Work or repairs in parts of barriers or mechanical equipment that is of importance for the defence-in-depth shall be safety reviewed. More in detail concerning durability and repairs, see Technical Regulations - TBM.

Qualification of a method for machining and repair intended for equipment belonging to either of the quality classes 1 or 2, shall be supervised and evaluated by an Accredited Inspection Body.

The manufacturer shall supply the licensee/purchaser with detailed repair documentation for review and approval as stated below:

- Repair procedure
- Qualification program for the repair
- Qualification report
- Qualification of staff and equipment

In detail, when documentation according to the above is required see Technical Regulations- TBM.

4 MANUFACTURE INSPECTION**4.1 General requirements for material inspection IP-200**

- | | |
|--|---------------|
| 1. Pressure retaining equipment or parts of equipment | IP-201 to 209 |
| 2. Load bearing equipment or parts of equipment | IP-221 to 222 |
| 3. Internal parts in mechanical equipment | IP-230 |
| 4. Internal parts in reactor pressure vessels and Steam Generators | IP-240 |

4.2 General inspection requirements – Manufacturing and assembling IP-300

- | | |
|--|--------|
| 1. Mechanical equipment or parts thereof | IP-300 |
|--|--------|

4.3 General inspection requirements – Finished mechanical equipment or parts thereof IP-400

- | | |
|---|--------|
| 1. Finished mechanical equipment or parts thereof | IP-400 |
|---|--------|

NOTE ! The general inspection requirements “IP” and inspection procedures “EP” must be read together.

The detailed quality control documentation shall be adopted for each individual design case.

The required testing, inspection and extent thereof and acceptance criteria is to be judged for each individual case.

4.1 General material inspection requirements IP-200**4.1.1 Pressure retaining equipment or parts thereof – IP 201 to 209****General material inspection requirement for pressure retaining equipment****IP 201/1
Page 1/1****Material and product type: Forgings and Bars****Quality Class 1 and 2*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁵	2-01
Tensile test	E ⁵	2-02
Hot tensile test ³	E ⁵	2-03
Impact test ¹	E ⁵	2-04
Intergranular corrosion test ²	E ⁵	2-07
Grain size ²	E ⁵	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
UT ⁴	E ⁵	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Inspection of base material and finished detail with OD. $\leq 25 / 1''$ NPS may be reported with and identity or quality certificate according to SS-EN 10204-2.1, 2.2 or equivalent. The material shall be marked according to material standards.

Remark:

- 1) Applies to ferritic materials
- 2) Applies to austenitic stainless materials
- 3) Applies to quality class 1 when the design temperature is > 250 °C.
- 4) Procedure for UT shall be prepared.
- 5) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 201/3
Page 1/1****Material and product type: Forgings and Bars****Quality Class 3, 4 and 4A*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁴	2-01
Tensile test	E ⁴	2-02
Impact test ¹	E ⁴	2-04
Intergranular corrosion test ²	E ⁴	2-07
Grain size ²	E ⁴	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
UT ³	E ⁴	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Inspection of base material and finished detail with OD $\leq 25 / 1$ "NPS may be reported with an identity or quality certificate according to SS-EN 10204-2.1, 2.2 or equivalent. The material shall be marked according to material standard.

Materials for equipment in quality class 4 and "other" systems shall at least be reported and marked in the extent and according to the requirements stated by AFS.

Remark:

- 1) Applies to ferritic materials.
- 2) Applies to austenitic stainless materials.
- 3) If required according to the EP-inspection procedure, a procedure description for UT shall be prepared.
- 4) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 202/1****Page 1/1****Material and product type:** **Castings****Quality Class 1 and 2*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁴	2-01
Tensile test	E ⁴	2-02
Hot tensile test ¹	E ⁴	2-03
Impact test ²	E ⁴	2-04
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
RT ³	E ⁴	2-27

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Remarks:

- 1) Applies to quality class 1 when the design temperature is > 250° C.
- 2) Applies to ferritic materials.
- 3) Extent as in ASME III, see Inspection Procedure.
- 4) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 202/3****Page 1/1****Material and product type: Castings****Quality Class 3, 4 and 4A*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ³	2-01
Tensile test	E ³	2-02
Impact test ¹	E ³	2-04
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
RT ²	E ³	2-27

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material for equipment in quality class 4 and "Other" shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to ferritic materials.
- 2) Extent depending on the material usage factor, see Inspection Procedure.
- 3) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 203/1**
Page 1/1**Material and product type:** Plate**Quality Class 1 and 2***Inspection of base material*

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁵	2-01
Tensile test	E ⁵	2-02
Hot tensile test ¹	E ⁵	2-03
Impact test ²	E ⁵	2-04
Intergranular corrosion test ³	E ⁵	2-07
Grain size ³	E ⁵	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
UT ⁴	E ⁵	2-20

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Remarks:

- 1) Applies to quality class 1 when the design temperature is > 250° C.
- 2) Applies to ferritic materials.
- 3) Applies to austenitic stainless materials.
- 4) Applies to plate with a thickness \geq 6 mm. See Inspection Procedure for further information.
- 5) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 203/3****Page 1/1****Material and product type:** Plate**Quality Class 3, 4 and 4A***Inspection of base material*

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁴	2-01
Tensile test	E ⁴	2-02
Impact test ¹	E ⁴	2-04
Intergranular corrosion test ²	E ⁴	2-07
Grain size ³	E ⁴	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
UT ³	E ⁴	2-20

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material for equipment in quality class 4 and “Others” shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to ferritic materials.
- 2) Applies to austenitic stainless materials.
- 3) Applies to plate with a thickness ≥ 6 mm. See Inspection Procedure for further data.
- 4) In house testing, E, under the condition that the manufacturer’s quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for Pressure retaining equipment**IP 204/1
Page 1/1****Material and product type: Pipes and fittings****Quality Class 1 and 2***Inspection of base material*

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁶	2-01
Tensile test	E ⁶	2-02
Hot tensile test ¹	E ⁶	2-03
Impact test ²	E ⁶	2-04
Other technological testing	E ⁶	2-06
Intergranular corrosion test ⁴	E	2-07
Grain size ⁴	E ⁶	2-08
Marking and identification	E	2/4-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2/4-13
Pressure testing ³	E ⁶	2-14
PT or MT of final surface	E ⁶	2/4-16/17
ET/UT ⁵	E ⁶	2/4-22

Welded pipes and welded pipe fittings shall also be inspected as per IP-301 and IP-401.

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Remarks:

- 1) Applies to quality class 1 when the design temperature is > 250 °C.
- 2) Applies to ferritic materials.
- 3) Pressure testing may be replaced with ET or UT according to applicable material standards or technical delivery conditions.
- 4) Applies to austenitic stainless materials.
- 5) Procedure for UT shall be drawn up when required in the inspection procedure.
- 6) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 204/3****Page 1/1****Material and product type:** **Pipes and fittings****Quality Class 3, 4 and 4A*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁵	2-01
Tensile test	E ⁵	2-02
Impact test ¹	E ⁵	2-04
Other technological testing	E ⁵	2-06
Intergranular corrosion test ³	E	2-07
Grain size ³	E ⁵	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
Pressure testing ²	E ⁵	2-14
PT or MT of final surface	E ⁵	2-16/17
UT ⁴	E ⁵	2-22

Welded pipes and welded pipe fittings shall also be inspected as per IP-301 and IP-401. In quality class 4 pipes manufactured as per SS-EN 10217 are accepted.

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material for equipment in quality class 4 and "Others" shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to ferritic materials.
- 2) Pressure testing may be replaced with ET or UT according to applicable material standards or technical delivery conditions.
- 3) Applies to austenitic stainless materials.
- 4) Procedure for UT shall be prepared, scope and technique see the inspection procedure.
- 5) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 205****Page 1/1****Material and product type: Heat exchanger tubes****Quality Class 2, 3, 4 and 4A*****Inspection of base material***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁵	2-01
Tensile test	E ⁵	2-02
Impact test ¹	E ⁵	2-04
Other technological testing	E ⁵	2-06
Intergranular corrosion test ³	E	2-07
Marking and identification	E	2/4-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2/4-13
Pressure testing ²	E ⁵	2-14
ET of tubes ⁴	E	2/4-19
PT or MT of final surface	E ⁵	2/4-16/17
ET/UT ⁴	E ⁵	2-22
Cold bending of HEX tubes	E, B	286
Qualification report		

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material for equipment in quality class 4 and "Others" shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to ferritic materials.
- 2) Pressure testing may be replaced with ET or UT according to applicable material standards or technical delivery conditions.
- 3) Applies to austenitic stainless materials.
- 4) Procedure shall be prepared, for extent and technique, see the Inspection Procedure.
- 5) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 206/1
Page 1/1****Material and product type: Bolts and Nuts****Quality Class 1 and 2*****Inspection of base material for bolts and nuts, "Special"***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁴	2-01
Tensile test	E ⁴	2-02
Hot tensile test ¹	E ⁴	2-03
Impact test ²	E ⁴	2-04
Hardness testing	E ⁴	2-05
Marking and identification	E	2/4-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2/4-13
PT or MT of final surface	E ⁴	4-16/17
UT of material to > M 24 ³ / 1"	E ⁴	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

2. Inspection of base material and finished bolts and nuts, "Standard"

Testing, inspection and marking shall be carried out and documented in accordance with the material standard chosen or the specification of material including the technical delivery and inspection requirements.

Requirements in addition to standard:

Surface crack indication PT/MT > M24 / 1"	E ⁴	2-16/17
Marking and identification	E	2/4-09

Certificate requirement:

Inspection certificate according to SS-EN 10204-2.1 or equivalent.

For carbon steel bolts and nuts marked with the manufacturer's name and strength class no certificate will be required.

For stainless material marked with the manufacturer's name, strength class and the material designation e.g. A2, A4 and 660, no certificate will be required.

Remarks:

- 1) Applies to quality class 1 when the design temperature is > 250 °C.
- 2) Applies to ferritic materials.
- 3) Procedure shall be prepared for UT.
- 4) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 206/3
Page 1/1****Material and product type: Bolts and nuts****Quality Class 3, 4 and 4A*****Inspection of base material and finished bolts and nuts, "Special"***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ²	2-01
Tensile test	E ²	2-02
Impact test	E ²	2-04
Hardness testing	E ²	2-05
Marking and identification	E	2/4-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2/4-13
PT or MT of final surface	E ²	4-16/17
UT of material till > M 24 ¹ / 1"	E ²	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent

2. Inspection of base material and finished bolts and nuts, "Standard"

Testing, inspection and marking shall be carried out and documented in accordance with the material standard chosen or the specification of material including the technical delivery and inspection requirements.

Marking and identification	E	2-00
----------------------------	---	------

Certificate requirement:

Inspection certificate according to SS-EN 10204-2.1 or equivalent.

For carbon steel bolts and nuts marked with the manufacturer's name and strength class no certificate will be required.

For stainless material marked with the manufacturer's name, strength class and the material designation e.g. A2, A4 and 660, no certificate will be required.

Remarks:

- 1) Procedure shall be prepared for UT.
- 2) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of section 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 207****Page 1/1****Material and product type:** **Bellows for valves****Quality Class 1-4 and 4A***Inspection of base material for bellow element to valve*

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ²	2-01
Intergranular corrosion test ¹	E ²	2-07
Marking and identification	E	2/4-09
Visual and dimensional inspection	E	2/4-13

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1.

Welds for valve bellows can be accepted without detailed welding documentation as per IP-100.

Material for equipment in quality class 4 and "Others" shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to austenitic stainless materials.
- 2) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of section 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 208****Page 1/1****Material and product type: Bellows for pressure vessels and pipes****Quality Class 2-4 and 4A***Inspection of base material and finished bellow element – pressure vessel and pipes*

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ²	2-01
Tensile test	E ²	2-02
Intergranular corrosion test ¹	E ²	2-07
Grain size ¹	E ²	2-08
Marking and identification	E	2/4-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2/4-13

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material identity certificate according to SS-EN 10204-2.1 or equivalent may normally be accepted for rubber bellow element.

Material for equipment in quality class 4 and “Others” shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- 1) Applies to austenitic stainless materials.
- 2) In house testing, E, under the condition that the manufacturer’s quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material inspection requirements for pressure retaining equipment**IP 209****Page 1/1****Material and product type:** **Valves closing devices****Quality Class 1-4 and 4A*****Guidelines for inspection of base material for valve closing devices***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ¹	2-01
Marking and identification	E	2/4-09
Visual and dimensional inspection	E	2/4-13

Inspection of material and shapes shall generally be performed and reported according to the extent specified in the applicable material standard and the belonging technical delivery and inspection conditions.

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Material identity certificate according to SS-EN 10204-2.1 or equivalent, can normally be accepted for small bore valves $DN \leq 50$ ($\leq 2''$ NPS) in quality class 1 and 2 and for valves in quality class 3 and 4.

Material for equipment in quality class 4 and "Others" shall be documented and marked at least to the extent and the requirements stated in AFS.

Remarks:

- ¹⁾ In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

4.1.2 Load bearing equipment and equipment parts – IP 221 to 222

General material control requirements for load bearing parts

IP 221

Page 1/1

Material and product type: Material for load bearing equipment incl. pipe rupture restrains

Quality Class 1-4 and 4A (pipe rupture restrains are always quality class 3)

Inspection of base material for load bearing equipment

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification as in approved material standard ¹	E	2-00/09
UT ²	E ⁴	2-20/2-21

Certificate requirement:

Inspection certificate according to S S-EN 10204-2.1 or equivalent.

Material for equipment in quality class 4 and “Others” shall be documented and marked at least to the extent and the requirements stated in AFS.

Inspection of other load bearing equipment or equipment details

Test requirements	Extent/ Supervision	Inspection Procedure No
Marking and identification as in approved material standard ³	E	2-00/09

Remarks:

- 1) Material identity and quality certificate can in certain cases be replaced by marking of the material with manufacturer and material quality. The manufacturer shall make this marking.
- 2) The requirement applies for details transmitting lateral loads where the thickness of the material is ≥ 6 mm. Procedure for UT shall be drawn up, extent and technique see the inspection procedure.
- 3) The material for anchoring elements such as spring assemblies, constant load hangers and snubbers for dynamic loads, shall be inspected and tested to the extent stated in the manufacturer's approved product specifications for the element in question. The documentation shall be reviewed by the purchaser and whenever required, also by Accredited Inspection Body (see IP-100).
- 4) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives.

General material control requirements for load bearing parts**IP 222****Page 1/1****Material and product type:** **Material for fasteners in concrete****Quality Class 1-4 and 4A*****Inspection of base material for fasteners in concrete***

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis ¹	E ³	2-01
Inspection of marking and identification ¹	E	2/4-09
UT of forgings and bars ²	E ³	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1

Material for equipment in quality class 4 and “Others” shall be documented and marked at least to the extent and the requirements stated in AFS. .

Remarks:

- 1) For expanding fasteners, which are type approved by the National Swedish Board of Buildings / SITAC (Swedish Institute for Technical approval in construction, Svenskt Byggodkännande AB) or corresponding body e.g. within European Organisation for Technical Approvals (EOTA), the material testing prescribed in the type approval certificate will be accepted.
- 2) UT shall be carried out when the material in grouting bolts, expander bolts etc is a design factor for the grouting element. The UT requirement applies when OD. ≥ 25 mm / 1”.
- 3) In house testing, E, under the condition that the manufacturer’s quality system fulfils the requirements of 1.8 that also gives possible alternatives.

4.1.3 Internal parts in mechanical equipment – IP 230

General material inspection requirement for internal parts

IP 230

Page 1/1

Material and product type: Internal parts in mechanical equipment according to IP 102

Quality Class 1-4 and 4A

Inspection of base material

Extent of inspection	Allocation	Inspection Procedure No
Material testing and inspection as per method and extent suggested by the manufacturer ¹	T	Manufacturer's requirement

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 for “piece production” and identity certification according to SS-EN 10204-2.1 or equivalent for series produced equipment.

Remarks:

- 1) The material standard and tests and inspections included in this standard, as suggested by the manufacturer, shall be documented for “piece production”.
The documentation shall also comprise all the tests and inspections the manufacturer considers necessary for taking full responsibility.
The documentation shall be reviewed and approved by the purchaser, together with all other basic documentation for manufacturing.

4.1.4 Internals in reactor pressure vessels and Steam Generators – IP 240

General material inspection requirements for above internals

IP 240

Page 1/1

Material and product type: Material for internals according to IP 100

Quality Class 1-4

Guidelines for inspection of base material

Extent of inspection	Allocation	Inspection Procedure No
Charge analysis	E ⁴	2-01
Tensile test	E ⁴	2-02
Hot tensile test	E ⁴	2-03
Impact test ¹	E ⁴	2-04
Intergranular corrosion test ²	E ⁴	2-07
Grain size ²	E ⁴	2-08
Marking and identification	E	2-09
Heat treatment	E	2-10
Visual and dimensional inspection	E	2-13
UT	E ⁴	2-20
UT ³	E ⁴	2-21

Certificate requirement:

Inspection certificate according to SS-EN 10204-3.1 or equivalent.

Inspection of base material and finished detail with OD $\leq 25 / 1''$ may be reported with an identity or quality certificate as in SS-EN 10204-2.1 or equivalent. The material shall be marked according to material standard.

Remarks:

- 1) Applies to ferritic materials.
- 2) Applies to austenitic stainless materials.
- 3) Procedure shall be prepared for UT.
- 4) In house testing, E, under the condition that the manufacturer's quality system fulfils the requirements of 1.8 that also gives possible alternatives

4.2 General inspection requirements – Manufacture/Joining – IP 300**4.2.1 Mechanical equipment and parts thereof – IP 300****General inspection requirements for manufacturing****IP 301/1
Page 1/2****Mechanical equipment and parts thereof****Quality Class 1-3, and 4 inspection class A-B as well as 4A*****Prescribed testing and inspection at welding***

Extent of Inspection	Insp. proc.	Butt weld	Fillet weld	Corner weld	T-joint weld	Surfacing weld	Weld Buttering	Seal weld	Welds valves bellow elem.	Welds valve closing device
Inspection of heat treatment	3-10	E	E	E	E	E	E	E	E	T
Test of weld filler metal	3-11	E	E	E	E	E	E	E	E	E
Inspection of welding	3-12	E	E	E	E	E	E	E	E	T
Visual and Dimensional Inspecc	3-13	E	E	E	E	E	E	E	E	E
PT or MT of weld ⁷	3-16 3-17	L	L	L	L	L	L	L	L	L
UT of surfacing weld ^{2, 4, 7}	3-23					L				T
UT of welded joint ^{1, 4, 7}	3-24	L		L	L		L			
RT of welded joint ^{1, 4, 7}	3-28	L		L			L			
Review of radiographs ⁷	3-28	L		L			L			
Inspection of weld repair ³	376									
Other testing and inspection	T	T	T	T	T	T	T	T	T	T

Other inspections in conjunction with manufacturing

Extent of inspection	Allocation	Inspection Procedure No
Inspection of pipe bending ⁸	E	3-,5-43
Inspection of installation of couplings ⁸	E	3-,5-48

General inspection requirements for manufacture**IP 301/1**
Page 2/2**Mechanical equipment and parts thereof****Quality Class 1-3, and 4 inspection class A-B along with 4A****Remarks:**

- 1) For weld in ferrite steel with a thickness of the material > 12 mm, UT is applicable according to inspection procedure 3-24 or RT according to inspection procedure 3-28. For other welds RT according to inspection procedure 3-28. For UT of longitudinal tubes testing and requirements according to inspection procedure 2-22 are applicable regardless of the thickness of the material.
- 2) Low alloy steel, which is not documented resistant to re-heating cracks, shall be further tested for cracks in cladding material and heat affected zone (see inspection procedure 2-23).
- 3) The original extent of inspection and supervision of inspection is valid.
- 4) Does not apply to welded joints in valves and armatures with $DN \leq 25$ /1" NPS
- 7) The authorisation for testing is described in 1.8.
- 8) The inspection shall be performed according to approved procedure.

General inspection requirements for manufacture**IP 301/4****Page 1/2****Mechanical equipment or parts thereof****Quality Class 4 inspection class C*****Prescribed testing and inspection at welding***

Extent of Inspection	Insp. proc.	Butt weld	Fillet weld	Corner weld	T-joint weld	Surfacing weld	Weld Buttering	Seal weld	Welds valves bellow elem.	Welds valve closing device
Inspection of heat treatment	3-10	T	T	T	T	T	T			
Test of weld filler metal	3-11	T	T	T	T	T	T			
Inspection of welding	3-12	T	T	T	T	T	T			
Visual and Dimensional Inspection	3-13	T	T	T	T	T	T	T		
PT or MT of weld ²	3-16 3-17	L	L	L	L	L	L	L		
UT of surfacing weld	3-23					T				
UT of welded joint ^{1, 2}	3-24	L		L	L		L			
RT of welded joint ^{1, 2}	3-28	L		L			L			
Review of radiographs	3-28	L		L			L			
Inspection of weld repair ³	376									
Other testing and inspection		T	T	T	T	T	T	T	T	T

Other inspections in conjunction with manufacturing

Extent of inspection	Allocation	Inspection Procedure No
Inspection of pipe bending ⁴	T	3-,5-43
Inspection of installation of couplings ⁴	T	3-,5-48

General inspection requirements for manufacture**IP 301/4****Page 2/2****Mechanical equipment or parts thereof****Quality Class 4 inspection class C****Remarks:**

- 1) For weld in ferritic steel with a thickness of the material > 12 mm, UT is applicable according to inspection procedure 3-24 or RT according to inspection procedure 3-28. Other welds, RT according to inspection procedure 3-28.
- 2) NDT of weld joints in inspection class C is normally not required.
- 3) The original extent of supervision for inspection is valid.
- 4) The inspection shall be performed in accordance with approved procedure.

4.3 General inspection requirements – Finished mechanical equipment or subassembly IP 400**4.3.1 Finished mechanical equipment or subassembly – IP 400****General inspection requirements for finished equipment****IP 401****Page 1/1****Pipes, pipe parts and tubes****Quality Class 1-4 and 4A**

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Pressure and tightness testing ¹	E,Q	4-14
PT or MT, of final surface	L ⁵	4-16/17
Final inspection ³	K	4
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ²	E,Q,K	190
--	-------	-----

Remarks:

- 1) May be performed at the manufacturer or licensee's workshop with the approval of the purchaser.
- 2) A review of the quality control documentation may normally be performed as a receipt inspection at the purchaser/licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 3) Is not required in quality class 4 inspection class C.
- 4) According to the Accredited Inspection Body routines.
- 5) See 1.8.

General inspection requirements for finished equipment**IP 402****Page 1/1****Valves and other ancillaries****Quality Class 1-4 and 4A**

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Pressure and tightness testing	E,Q	4-14
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of tightness over closing device	T	441-444
Function test	T	451-453
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

General inspection requirements for finished equipment**IP 403****Page 1/1****Pumps****Quality Class 2-4 and 4A**

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Pressure and tightness testing	E,Q	4-14
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of tightness over closing device	T	441-444
Function test	T	454-457
Balancing	T	490
"Strip test"	T	486
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class. C
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

General inspection requirements for finished equipment**IP 404****Page 1/1****Heat Exchangers, Pressure vessels****Quality Class 1-4 and 4A**

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Pressure and tightness testing	E,Q	4-14
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

General inspection requirements for finished equipment**IP 405**
Page 1/1**Tanks****Quality Class 2-4 and 4A**

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Tightness testing	E,Q	4-14
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

General inspection requirements for finished equipment**IP 406****Page 1/1****Process Instrumentation****Quality Class 1-4 and 4A*****In-line instrument***

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
Pressure and tightness testing	E,Q	4-14
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of cleanliness	T	425
Inspection of packing	T	435

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Off-line instrument

Test requirements	Extent/ Supervision	Inspection Procedure No
According to the manufacturer's product standard approved by the purchaser	T	Manufacturer

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

General inspection requirements for finished equipment**IP 407****Page 1/1****Load bearing equipment such as hangers, supports and pipe rupture restrains****Quality Class 1-4 and 4A*****Piping***

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	4-09
Visual and dimensional inspection	E,Q	4-13
PT or MT of final surface	L ⁴	4-16/17
Final inspection ²	K	3
Inspection of cleanliness	T	425

Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
--	-------	-----

Remarks:

- 1) Inspection of the equipment and review of quality control documentation can normally be carried out as final inspection at the purchaser or licensee. The inspection can also, be carried out as final inspection at the supplier's shop, if the purchaser deems this necessary or practical. K is not required in quality class 4 inspection class C.
- 2) Is not required in quality class 4 inspection class C.
- 3) According to the Accredited Inspection Body routines.
- 4) See 1.8.

5 INSTALLATION AND REPAIR INSPECTION**5.1 General requirements – Installation or repair IP-500**

Pressure retaining, load bearing and internal equipment or parts thereof IP-500

General inspection requirements at installation or repair

IP 501
Page 1/2

Mechanical equipment or parts thereof**Quality Class 1-4 and 4A****5.1.1 Testing and inspection at welding**

Extent of inspection⁶	Inspection procedure	Butt weld	Fillet weld	Corner weld	T-joint weld	Surfacing weld	Buttering weld	Seal weld
Inspection of heat treatment	5-10	E	E	E	E	E	E	E
Test of weld filler metal	5-11	E	E	E	E	E	E	E
Inspection of welding	5-12	E	E	E	E	E	E	E
Visual and dimensional inspection	5-13	E	E	E	E	E	E	E
PT or MT of weld	5-16 5-17	L	L	L	L	L	L	L
UT of surfacing weld ^{2,4}	5-23					L		
UT of weld joint ^{1,4}	5-24	L		L	L		L	
RT of weld joint ^{1,4}	5-28	L		L			L	
Review of radiograph	5-28	L		L			L	
Inspection of weld repair ³	376							

5.1.2 Other inspection at installation

Extent of inspection⁶	Allocation	Inspection Procedure No
Inspection of fasteners	E	5-15
Inspection of coupling installation ⁴	E	5-48
Bending of pipes ⁵	E	5-43

General inspection requirements for installation or repair**IP 501**
Page 2/2**Mechanical equipment or parts thereof****Quality class 1-4 and 4A****Remarks:**

- 1) ¹For welds in ferritic steel with thickness > 12 mm, UT is applicable according to inspection procedure 5-24 or RT according to inspection procedure 5-28. Other welds, RT according to inspection procedure 5-28. For UT of longitudinally welded pipes, testing and requirements according to inspection procedure 2-22 are applicable, regardless of the thickness of the material.
- 2) Low alloy steel, which is not documented as being resistant to re-heating cracks, shall in addition be tested for cracks in cladding and heat affected zones. See inspection procedure 2-23.
- 3) The original allocation of inspection is valid.
- 4) The testing shall be carried out according to a procedure approved by the purchaser.
- 5) Bending of pipes shall be carried out according to a procedure approved by the purchaser.
- 6) In general, the licensee's inspection organisation follows and supervises tests and inspections.

In quality class 4 with inspection class C, the extent of inspection "E" can be replaced by "T".

5.2 General inspection requirements – Installed system or part of system or repair IP-600

Installed system, part of system or repair IP-600.

General inspection requirements for installation or repair

IP 601
Page 1/1

Mechanical equipment or parts thereof

Quality Class 1-4 and 4A

5.2.1 Pipes and piping

Extent of inspection	Allocation	Inspection Procedure No
Marking and identification	E,Q	6-09
Visual and dimensional inspection	E,Q	6-13
Pressure and tightness testing	E,Q,K	6-14
Final inspection ¹	K	2
Inspection of cleanliness	T	425/560

5.2.2 Load bearing equipment in pipe systems

Hangers for piping systems	E,Q	6-09/13
Inspection of cleanliness	T	425
Final inspection ¹	K	2
Inspection of installation	B,Q,K ¹	6-60
Operation test	B,Q,K ¹	6-50

5.2.3 Quality Control Documentation

Review of final quality control documentation ¹	E,Q,K	190
Certificate of Compliance ¹	K	2

Remarks:

- 1) K is not required in quality class 4, inspection class C see 2.1.7.3. E can be replaced by T.
- 2) According to the Accredited Inspection Body's routines.

APPENDIX 1

DESCRIPTION OF INSPECTION PROCEDURES (COMPULSORY INSPECTION)

MATERIAL

If nothing else is stated, proven material according to ASME or EN standard is assumed.

**MATERIAL WITH REQUIREMENTS ON IDENTITY
OR QUALITY CERTIFICATES**

**EP 2- 00
PAGE 1/1****APPLICATION**

Inspection and marking for verification of the material quality or compliance with an order.

SCOPE

All material according to the specified material standard, specification or detailed inspection plans.

TEST REQUIREMENTS

--

ACCEPTANCE CRITERIA

The material must comply with given material standards and specifications and shall conform to relevant technical requirements regarding delivery and inspection.

The supplied goods shall also comply with other requirements specified in the purchase order.

The above shall be evident from the certificate.

CERTIFICATION

Identity or quality certificate according to SS-EN 10 204-2.1, alternatively 2.2 or corresponding e.g. Certificate of Conformity.

On certain occasions the *manufacturer's* marking of the material or the product can replace the certificate requirement.

CHARGE ANALYSIS

EP 2-01
PAGE 1/1

APPLICATION

Chemical analysis regarding alloying elements, residual elements and impurities in materials.

SCOPE

All materials according to the material standard or specification shall be tested.

TEST REQUIREMENTS

According to SS-EN 10204 or equivalent.

ACCEPTANCE CRITERIA

The chemical composition of the material must comply with requirements according to the detailed material specification or standard. The limitations of analysis and restrictions in TBM section 3.1 "Materials" must be followed.

CERTIFICATION

The results shall be reported in an inspection certificate, no lower than 3.1 according to SS-EN 10 204 or equivalent.

There must be a connection to the material charge number. The certificate may be part of the certificate issued for the mechanical testing.

TENSILE TEST AT ROOM TEMPERATURE

EP 2-02
PAGE 1/2

APPLICATION

Tensile testing of metallic material concerning:

- ultimate tensile strength R_m
- yield point, R_{eL} or R_{eH} (or $R_{p0,2}$ if the material is not characterised by a distant yield zone)
- elongation, A_5 or A_{10} (for malleable cast iron A_3 is applicable) ej lika i svensk utg
- contraction, Z (applies only to test pieces with round cross section)

The material shall be tested in its final heat treated condition.

- a) Well proven pressure vessel steel standardized according to ASME or EN.
e.g. "P235GH" and "316L"
- b) Not standardized material with clearly defined requirements from the manufacturer. E.g. 254 SMO, Inconel
- c) Material with special requirements. E.g. shaft material with requirement on specific minimum and maximum values for yield point, standard material with requirements for higher mechanical properties values than the minimum values of the standard, material where purchaser/supplier have requirements above the requirements of the material standard.

SCOPE

All material according to the material standard or specification shall be tested. Samples shall be selected:

- a) according to the requirements in the respective material standard.
- b) according to the manufacturers recommendations defined in the material specification or in the inspection plan.
- c) according to the purchasers/suppliers requirements defined in the material specification or in the inspection plan. Normally these materials require a higher level of verification e.g. one sample per plate, verified tests performed by Accredited Laboratory in third party position, extended supervision of the manufacturer's testing.

TENSILE TEST AT ROOM TEMPERATURE**EP 2-02****PAGE 2/2**

TEST REQUIREMENTS

- a) according to requirements in the respective material standard.
- b) according to the manufacturer's recommendations defined in the material specification or in the inspection plan.
- c) according to purchasers/suppliers requirements defined in the material specification or in the inspection plan.

ACCEPTANCE CRITERIA

- a) according to requirements in the respective material standard.
- b) according to the manufacturer's recommendations defined in the material specification or in the inspection plan.
- c) according to purchasers/suppliers requirements defined in the material specification or in the inspection plan.

CERTIFICATION

The results shall be reported in a test certificate, no lower than 3.1 according to SS-EN 10204 or equivalent. The certificate shall include data such as test method, charge or identity marking and the heat treatment condition of the material, location of test specimens for forgings and castings and the test temperature.

The certificate may be part of a certificate issued for other mechanical testing or chemical analysis.

For material according to c), the certification is defined in the material specification or in the inspection plan.

HOT TENSILE TEST

EP 2-03
PAGE 1/2

APPLICATION

Hot tensile testing of metallic material to determine:

- ultimate tensile strength R_m
- yield point, R_{eL} or R_{eH} (or $R_{p0,2}$ if the material is not characterised by a distant yield zone)
- elongation, A_5 or A_{10} (for malleable cast iron A_3 is applicable)
- contraction, Z (applies only to test pieces with round cross section)

The material shall be tested in the final heat treated condition.

SCOPE

For pressure retaining equipment of quality class 1 and with a design temperature of > 250 °C and for internal parts in reactor tanks with quality class 2 or 3, a tensile test per charge and heat treated unit shall be tested.

Other extent according to EP 2-02.

HOT TENSILE TEST

EP 2-03
PAGE 2/2

TEST REQUIREMENTS

If nothing else has been required, the hot tensile test shall be performed at 300°C. Other requirements according to EP 2-02.

ACCEPTANCE CRITERIA

- a) According to requirements in the respective material standard, however, for "316L-material according to ASME" $R_{p0,2} \min 105 \text{ N/mm}^2$ at 300°C.
- b) according to the manufacturer's recommendations defined in the material specification or in the inspection plan.
- c) according to purchasers/suppliers requirements defined in the material specification or in the inspection plan.

CERTIFICATION

The results shall be reported in a certificate, no lower than 3.1 according to SS-EN 10204 or equivalent. The certificate shall contain data of the test method, charge- or identity marking, the heat treated condition of the material, location of test samples for forgings and castings and test temperature.

The certificate may be part of a certificate issued for other mechanical testing or chemical analysis.

For material according to c) the certification is defined in the material specification or in the inspection plan.

IMPACT TEST

EP 2-04
PAGE 1/1

APPLICATION

Impact testing with ISO-V-test sample concerning the ductility of ferritic materials.

The material shall be tested in its final heat treated condition.

SCOPE

The following ferritic materials shall be tested:

- d) Material for pressure retaining equipment of a thickness ≥ 6 mm in quality class 1 and material for the reactor containment buildings.
- e) Material for pressure retaining and load bearing equipment that shall be welded and with a thickness of >25 mm in the welded part.
- f) Material for pressure retaining equipment of a thickness ≥ 6 mm which can be exposed for operating temperatures lower than $+10$ °C.

Material according to EN or ASME standard is tested according to each material standard. For other material and material lacking defined impact test requirements for constructions according to A-C above, the testing shall be performed according to reviewed material specification or inspection plan.

TEST REQUIREMENTS

According to each material standard if nothing else has been prescribed.

ACCEPTANCE CRITERIA

According to each material standard if nothing else has been prescribed.

CERTIFICATION

According to each material standard if nothing else has been prescribed.

HARDNESS TESTING

EP 2-05
PAGE 1/1

APPLICATION

Testing of the hardness of metallic materials.

SCOPE

Material for special bolts and nuts shall be hardness tested.

All material where the requirement for hardness testing is stated in the material standard, material specification or the detailed inspection plan shall be tested.

Testing and selection of specimens for other materials shall follow applicable material standard. Possible restrictions issued by the purchaser to be considered.

TEST REQUIREMENTS

Testing shall be performed according to the method of the standard corresponding to the type of hardness value given in the material standard.

ACCEPTANCE CRITERIA

Measured-hardness values must comply with the requirements of the material standard or the purchaser's requirements.

CERTIFICATION

The results shall be recorded in a certificate, no lower than 3.1 according to SS-EN 10204 or equivalent. The certificate shall contain data of the testing procedure, the location of the test locations, the charge- or identity marking and the heat-treated condition of the material.

The certificate may be part of a certificate issued for other mechanical testing or chemical analysis.

OTHER TECHNOLOGICAL TESTING OF PIPES AND TUBES

**EP 2-06
PAGE 1/1**

APPLICATION

Other technological testing means:

- Flanging test
- Flattening test
- Ring expansion test
- Ring tensile test
- Stress corrosion test (for pipes/tubes made of copper alloys for heat exchangers and condensers)

SCOPE

Quality Class 1:

At least one test per pipe/tube.

Others:

Testing and selection of test specimens for other material shall be carried out according to applicable material standard. Possible restrictions issued by the purchaser-to be considered.

TEST REQUIREMENTS

Selection of test specimens, testing and requirements for pipes and tubes of other materials shall be carried out and evaluated according to applicable material standard, alternatively, according to the requirements of the purchaser.

ACCEPTANCE CRITERIA

According to respective standard, alternatively according to the purchaser's requirements.

CERTIFICATION

The results shall be reported in a certificate, no lower than 3.1 according to SS-EN 10 204. The certificate shall contain data of the charge- or identity marking, technical delivery conditions, standard of testing and the heat-treated condition of the material.

The certificate may be part of a certificate issued for other mechanical testing or analysis of material.

INTERGRANULAR CORROSION TESTING

EP 2-07
PAGE 1/1

APPLICATION

Testing concerning the susceptibility of intergranular corrosion in austenitic stainless steels.

SCOPE

All plastic formed austenitic stainless steels for wetted systems with design temperature $>100\text{ °C}$ and other stainless steels if required by the purchaser. The selection shall be performed according to applicable standards alternatively according to the purchaser's requirements.

TEST REQUIREMENTS

The material shall be tested in its final heat treated condition. Test specimens shall be sensitised at times and temperatures specified in standards below. If no other time and temperature is specified then $700\text{ °C} \pm 10\text{ °C}$ for 30 minutes to be used.

The testing shall be performed according to SS-EN ISO 3651-2 or ASTM A 262 Practice E. For material where mainly resistance to marine environment is desired (e. g. sea water systems of materials like Avesta 254 SMO) the intergranular corrosion test will be replaced by a corrosion test according to ASTM G 48. Specific temperature requirements shall be stated in the purchase order or corresponding.

ACCEPTANCE CRITERIA

If there are no specific requirements from the purchaser:

For austenitic stainless manganese steel according to SS-EN ISO 3651-2 or ASTM A 262 Practice E.

For "254 SMO-material" testing according to ASTM G48:

For welded structures ASTM G 48A is applied, test temperature 50 °C , no pitting is allowed. For weight loss and edge attack no requirements are given.

For structures with crevice conditions ASTM G48F is applied, test temperature 50 °C , no pitting is allowed. For weight loss and edge attack no requirements are given.

CERTIFICATION

The results shall be recorded in inspection certificates, no lower than 3.1 according to SS-EN 10204 or equivalent. The certificate shall contain data of the charge- or identity marking and the standard of the testing.

The certificate may be part of a certificate issued for other mechanical testing or chemical analysis of the material.

GRAIN SIZE**EP 2-08**
PAGE 1/1**APPLICATION**

- a) Austenitic stainless steel e.g. “316L”.
- b) Other material with specific requirements defined in the material specification, contract or agreement.

SCOPE

- a) Quality Class 1: All material for pressure retaining equipment including pipes and pipe fittings
- Quality Class 2: As per requirements from the respective material standard. All bars for manufacturing of pressure retaining devices >DN/50/2” NPS and all plates > 12 mm for manufacturing of pressure retaining devices.
- Quality Class 3-4: According to requirements of material standard.
- b) Quality Class 1-4: As per specific requirements defined in material specification, contract or agreement.

TEST REQUIREMENTS

- a) According to SS-EN-ISO 643, ASTM E112 or other specific test standard accepted by the purchaser.
- b) According to specific test standard accepted by the purchaser.

ACCEPTANCE CRITERIA

- a) Quality class 1-2: ASTM 4 or finer grain according to ASTM E112. Quality class 3-4 According to requirements in selected material standard.
- b) According to specific test standard accepted by the purchaser.

CERTIFICATION

The results shall be recorded in inspection certificates, no lower than 3.1 according to

SS-EN 10204 or equivalent. The certificate shall contain data of the charge- or identity marking and the standard of the testing.

The certificate may be part of a certificate issued for other mechanical testing or chemical analysis of the material.

MARKING AND IDENTIFICATION

EP 2-,4-,6-09**PAGE 1/1**

APPLICATION

Marking of mechanical equipment for identification with regard to material, type of equipment and traceability to certificate for performed inspection and testing. The marking shall at least fulfil the requirements of the respective standard.

SCOPE

Material and other mechanical equipment that requires a test certificate shall be marked to enable identification against the certificate for performed inspection and testing.

Where an identification or quality certificate is required the material shall be marked to enable material type/grade identification. Standard nuts and bolts do not normally require certification if marked with brand name and strength class. For stainless nuts and bolts material code marking is also required.

ACCEPTANCE CRITERIA

Materials and other parts of equipment shall be marked in such a way that they can be unambiguously-traced to the inspection documentation before and after installation. A method approved by the purchaser must be used for the marking. If no specific marking requirements from the purchaser, the equipment to be marked as per below:

Displayed at a well visible location, all vessels shall have a manufacturer's plate or other permanent marking with data such as manufacturer, year of manufacture, volume, serial number, design pressure and design temperature.

In addition to the plate with actual performance, pumps shall also be marked with, serial number, rotation direction, flow direction and pump material.

Ancillaries (valves and process instrumentation etc) shall be marked, serial number, flow direction, material and pressure rating. In addition to the above, relief valves shall be marked with their opening pressure.

Pipes, pipe fittings, flanges, plates and bars shall be marked with:

- identification number

CERTIFICATION

Identification shall be performed and stated in a certificate from the manufacturer.

The manufacturer is responsible for verifying that the material or equipment part complies with the data stated in the Quality Control Documentation.

For identification of the base material, the certificate may be part of certificates issued for mechanical testing.

INSPECTION OF HEAT TREATMENT

EP 2-, 3-, 5-10**PAGE 1/1**

APPLICATION

Inspection of heat treatment to ensure the application of requirements according to procedure, welding specification or material standard.

SCOPE

According to the procedure for heat treatment or material standard.

TEST REQUIREMENTS

According to the procedure for heat treatment or material standard

ACCEPTANCE CRITERIA

According to the procedure, welding specification or material standard.

CERTIFICATION

The inspection shall be reported in a certificate stating:

- Heat treated material or weld joint
- Applied procedure
- Duration of the heat treatment
- Date for the heat treatment and name of inspector

If the recording equipment is used, the temperature diagram to be attached to the record.

The heat treatment certificate of stock/shapes in steel mill may be documented as a heat treatment condition and be part of a certificate issued for the chemical analysis and mechanical testing.

TEST OF WELD FILLER MATERIAL

EP 3-, 5-11
PAGE 1/2

APPLICATION

Testing concerning mechanical properties and analysis of the chemical composition.

SCOPE

All filler material used for welding or weld repairs shall be tested.

TEST REQUIREMENTS

Filler material for the welding of pressure vessels of quality class 1, as well as pumps, valves and piping with DN > 100 / 4" NPS of quality class 1 shall be "check-in tested" according to the following:

- A specimen weld in compliance with approved welding procedures for actual application shall be tested according to ASME III, sub article NB-2420 and sub article NB-2430. In austenitic material the content of delta ferrite in the weld deposit must also be determined by direct magnetic measurement or by means of Schaeffler-Delong diagram.

Filler metals for welding of other equipment shall be tested according to the following:

- Coated electrodes shall be tested according to, SS-EN 14532-1:2005 or equivalent standard for corresponding material group.
- Weld wire shall be tested according to ASME II, SFA-5.9 and SFA-5.18 or other equivalent codes for the corresponding material group.
- Filler material for deposition welding (hard facing) shall be tested according to SS-EN-ISO 14700:2005

ACCEPTANCE CRITERIA

Filler material shall meet the requirements of the standard specified.

CERTIFICATION

Weld filler material that requires check-in test:

The result shall be reported in inspection certificate, no lower than 3.1 according to SS-EN 10204 or equivalent. The certificate shall contain data of the charge number and test method.

The delta ferrite content of the weld deposit shall also be reported for austenitic material.

Other filler material:

The weld filler material shall be reported according to SS-EN 10 204 2.1 alternatively 2.2, the certificate shall contain principle analysis and reference to code.

The supplier shall state that the filler material meets the requirements s of applicable standard.

TEST OF WELD FILLER MATERIAL**EP 3-, 5-11****PAGE 2/2**

The filler material shall be traceable against the certificate.

A certificate is not required for annually tested approved filler material listed by The Swedish Welding Commission Elektroportalen © (www.svets.se) or equivalent foreign standard.

INSPECTION OF WELDING

EP 3-, 5-12
PAGE 1/1

APPLICATION

All welding subjected to inspection according to a detailed inspection plan shall be supervised by regularly inspection.

SCOPE

Welding according to the detailed inspection plan.

TEST REQUIREMENTS

Regular inspection of welding in order to ensure:

- That the welding is performed in an environment where good result can be achieved.
- Examples of factors to be inspected are: cleanliness, dry work area without draught.
- That the filler material is stored and handled in an appropriate way.

Examples of factors to be inspected are:

- That electrodes are stored in unopened containers or in heated cabinets, that dryers are used at the working site, that TIG wires are marked for prevention of mix up.
- That welding methods, filler material, welding equipment, welding parameters and working temperature are correct and are according to the approved welding procedure and drawing.
- That applicable welding procedures always are available while welding.
- That joint configuration and material surfaces after preparation of weld edge and alignment after tack welding is acceptable in terms of edge misalignment requirements.
- That a person with valid authorisation performs the welding.
- That all welding is unambiguously traceable to the specific welder.

ACCEPTANCE CRITERIA

Welding shall be performed in accordance with approved drawings and welding procedures by authorised welders and in accordance with the above requirements.

CERTIFICATION

The inspection shall be reported in a certificate verifying that the weld preparation is inspected and that the welding is supervised and performed in a correct manner.

VISUAL AND DIMENSIONAL INSPECTION**EP 2-, 3-, 4-, 5-, 6-13****PAGE 1/1**

APPLICATION

Visual and dimensional inspection of material, stock shapes, manufacturing of equipment including parts thereof and installation or repairs.

SCOPE

All materials, stock shapes, equipment parts and weld joints specified in the detailed inspection plans, material standards or specifications shall be inspected.

TEST REQUIREMENTS

Materials, stock shapes and equipment parts shall comply with the dimensions, tolerances, configuration and surface finish specified on the valid drawing or standard.

Welds are to be examined according to SS-EN 970.

ACCEPTANCE CRITERIA

Welded joints must not have external discontinuities or deviations of shape larger than permitted by quality class "B", i. e. high, according to SS-ISO 5817.

Requirements of freedom from oxides on stainless welded surfaces shall be maintained in accordance with KBM-EP 425.

Equipment, equipment parts and assemblies shall correspond to the measurements, tolerances, performance and surface quality according to valid order and manufacturing document.

CERTIFICATION

For material and shapes, the results shall be recorded in an inspection certificate, no lower than 3.1 according to SS-EN 10 204 or equivalent.

The certificate may be part of a certificate issued for mechanical testing or chemical analysis.

For welded joints and finished units the result shall be recorded in a separate certificate.

At the purchaser's request the inspected dimensions, shapes and position tolerances shall be stated in the certificate.

PRESSURE AND TIGHTNESS TESTING

EP 2-, 4-, 6-14
PAGE 1/3

APPLICATION

Testing concerning the tightness and pressure retaining capability of pressure retaining equipment and parts thereof.

Testing in Sweden shall fulfil the requirements in AFS 2006:8.

The testing shall be carried out after manufacturing and / or after finished installation. Equipment that cannot be pressure tested after installation shall be tested separately prior to installation.

For the manufacture of new parts or a new installation, the area to be inspected shall be tested for tightness and possible deformations prior to possible surface treatment.

SCOPE

All pressure retaining equipment or parts thereof shall be tested. The extent of pressure testing in inspection class 4bkC follows each nuclear plant's internal routines.

In case of great difficulties or when pressure testing of a particular equipment or part thereof, is considered unsuitable, pressure testing may be replaced by extended non-destructive testing. (Normally PT/MT according to EP 3/5-16/17 and RT/UT according to EP 3/5-28/24).

The test method and the extent of the replacing method shall be approved by the purchaser and in applicable cases also be reviewed by an Accredited Inspection Body.

TEST REQUIREMENTS

Testing after manufacturing shall normally be carried out with liquid.

If liquid is unsuitable, the testing may be carried out with gas, provided proper precautions against bursting or damages to the equipment are taken.

For testing in Sweden, permission must be obtained according to regulations stated by the Swedish Board for Occupational Safety and Health.

Pipes and pipe fittings, either seamless or continuously automatically welded:

- Pressure tested according to technical delivery and inspection requirements for material standard approved for the actual application. The pressure shall be maintained during a sufficiently long time to detect leakage.

Pipes and pipe fittings shall in addition normally be tested with regard to tightness while testing of pre-fabrication or testing of installed system.

PRESSURE AND TIGHTNESS TESTING**EP 2-, 4-, 6-14****PAGE 2/3****Open tanks:**

By water filling and with a holding time of at least 30 minutes.

Other pressure retaining equipment or parts thereof:

Pressure testing as per approved design drawing. In case this information is lacking on the drawing, the test pressure shall normally be 1.5 times the design pressure for equipment made of steel castings and 1.3 times the design pressure for equipment made of other metallic materials.

The pressure shall be maintained for a sufficiently long period of time to detect leakage.

At design and manufacturing of new pressure retaining equipment according to the requirements in AFS 1999:4 (PED), the pressure testing shall be performed with 1,43 x the design pressure or other higher prescribed value.

Pressure testing of installation:

The testing of a finished installation shall follow an approved pressure and tightness-testing program.

Normally the test pressure is 1.3 times the design pressure with the necessary holding time to disclose leaks and other deficiencies. The minimum holding time is 15 minutes.

The program for pressure and tightness test shall contain data regarding:

- Drawings and inspection plan
- Boundaries for the extent of the pressure test (to be specified on drawings or system flowcharts).
- Test pressure, test medium and holding time at full test pressure
- Connection points, valve positions (closed/open) and blindings.
- Parts to be protected during the pressure test.
- Venting procedure.
- Location for pressure gauges and location for verification gauge.
- Method and extent of inspection.
- Restoration of the system after the pressure test (requires sign off after restoration)
- Possible risk analyses
- At manufacturing and installation in quality class 4, the pressure and holding times according to AFS 1999:4 are valid for new equipment and assemblies. For parts connecting to existing parts in the nuclear plant, the pressure according to the second section above applies.

PRESSURE AND TIGHTNESS TESTING**EP 2-, 4-, 6-14**
PAGE 3/3

Exemptions:

Pressure test is normally not required for the following:

- replacement of bolts and nuts
- buttering at nominal wall thickness
- replacement of blind flanges
- welding of details such as lugs, lifting ears etc, against pressure retaining parts
- Weld repairs replacing less than 20% of the nominal wall thickness of the base material for $T \leq 25$ mm and less than 10% of the nominal wall thickness for $T > 25$ mm
- plugging of heat exchanger tubes
- replacement of a small number ($< 10\%$) of heat exchanger tubes
- seal welds
- compression or swage ring couplings, providing that inspection of ring installation was carried out

ACCEPTANCE CRITERIA

Leakage or permanent deformities are not allowed.

CERTIFICATION

The result of the testing shall be reported in a record stating the test of:

- Device, part of device or extent of the test
- Reference to drawing and inspection plan
- Identity marking
- Test medium
- Test pressure, temperature and holding time
- Result of the testing

The test certificate for pressure and tightness testing of pipes in pipe mills may be part of a certificate issued for other tests.

INSPECTION OF GROUTED AND BOLTED FASTENERS IN CONCRETE

EP 5-15
PAGE 1/1

APPLICATION

Installation inspection of grouted bolts, fastening elements like expansion bolts and chemical anchors in concrete.

Scope of inspection:

- Bore depth, hole diameter and cleanliness of concrete
- Visual inspection of installation
- Tightening torques

SCOPE

All fasteners for pipe hangers belonging to quality class 1.

Random inspection of fasteners for pipe hangers in quality class 2, 3 and 4.

TEST REQUIREMENTS

Applicable brands for fasteners shall be type approved by SITAC or corresponding organisation e.g within European Organisation for Technical Approvals (EOTA)

Fasteners that are type approved SITAC or corresponding organisation shall be installed in accordance with instructions in the type approval.

In case of uncertainty concerning the concrete quality, the assured load shall be verified by random load tests.

ACCEPTANCE CRITERIA

According to instruction or procedure.

CERTIFICATION

The results of the inspection shall be stated in a report containing details of:

- Fasteners inspected
- Extent of the inspection
- References to drawing
- Result of the inspection

LIQUID PENETRANT TESTING

EP 2-, 3-, 4-, 5-16
PAGE 1/5

APPLICATION

The testing applies to surface breaking discontinuities in weld joints, surface welds, sealing surfaces and other surfaces of mechanical equipment or parts thereof.

The inspection shall be carried out on the final surface, after forming, heat treatment and machining.

SCOPE

At manufacturing, installation and repair the following shall be tested:

Weld bevels, surfaces to be welded, welded joints including heat affected zones, buttering welds, surface welds and surfaces machined to final surface.

The applicable inspection plan shall give the detailed extent of the testing.

The below is the **principle** for application and extent of testing:

1. Pressure retaining equipment or parts thereof

1.1 Details of forgings and bars

Quality class 1 and 2:

- Accessible surfaces and weld bevels as well as special surfaces according to section 2.

Quality class 3-4:

- Special surfaces according to section 2.

1.2 Castings

Quality class 1-2:

- Assessible surfaces and weld bevels as well as special surfaces according to section 2.

Quality class 3-4:

- Weld ends
- Special surfaces according to section 2.

1.3 Plate details

Quality class 1-2:

- Weld bevels and special surfaces according to section 2.

Quality class 3-4:

- Special surfaces according to section 2.

LIQUID PENETRANT TESTING

EP 2-, 3-, 4-, 5-16
PAGE 2/5

1.4 *Pipes and pipe fittings*

Quality class 1 and 2:

- Cold worked sections after bending of pipes and pipe fittings as follows:

Stainless pipes and pipe fittings where $R < 2,5x OD$.

Ferritic pipes and pipe fittings where $R < 6x OD$.

R = mean bending radius

OD. = nominal outside diameter

Weld edges and special surfaces according to section 2.

Quality class 3 and 4:

- Special surfaces according to section 2.

1.5 *Bolts and nuts, special*

Quality class 1-4

- Accessible surfaces

1.6 *Bolts and nuts, standard*

Quality class 1, 100% and quality class 2, random test:

- Accessible surfaces with a thread diameter $> M 24 / 1"$.

1.7 *Bellows, pressure vessels and pipes*

Quality class 1 and 2:

- Accessible surfaces, weld bevels and special surfaces according to section 2.

1.8 *Bellows for valves and valve closing devices*

Quality class 1 and 2:

- Accessible surfaces

Quality class 3 and 4:

- Accessible surfaces for valves $DN > 150 / 6"$ NPS.

Quality class 1-4:

- Surfaces to be surfaces welded.

LIQUID PENETRANT TESTING**EP 2-, 3-, 4-, 5-16**
PAGE 3/5**2. Weld bevels and special surfaces****2.1 *Weld bevels***

Quality class 1-4:

- All weld bevels in castings, other weld bevels in quality class 1 and 2 where the nominal thickness of the material is > 10 mm

2.2 *Special surfaces*

Quality class 1-4:

- All surfaces where temporary welds have been removed.

Quality class 1 and 2:

- Surfaces to be surface welded.
- Cold deformed areas.
- Surfaces where a visual inspection indicates the necessity.

3. Weld joints in pressure retaining and load bearing parts**3.1 *Vessels, pipelines, welded pipes and fittings***

Butt weld:

Quality class 1: Full extent

3.2 *Other weld joints and dissimilar welds:*

Inspection class 1-4: Full extent

(for class 4 ic C a normal visual inspection according to EP 3/5-13 is sufficient)

Surfaces where a visual inspection indicates the necessity.

3.3 *Welds in supports for piping DN>50 / 2" NPS*

Quality class 1: 10%

Quality class 2-4: Surfaces where a visual inspection indicates the necessity.

3.4 *Pipe rupture restraints*

Weld joints: 10%

LIQUID PENETRANT TESTING**EP 2-, 3-, 4-, 5-16**
PAGE 4/5**3.5 Pumps, valves and in-line instruments**

Butt weld:

Quality class 1-2: Full extent

Quality class 3-4: Surfaces where a visual inspection has indicated the necessity.

Other weld joints:

Quality class 1-4: Full extent

(For class 4 ic C a normal visual inspection according to EP 3/5-13 is sufficient.)

3.6 Surfacing of valve closing devices and of pressure retaining valve seats

Quality class 1-4: Full extent for valves DN > 25 / 1" NPS

TEST REQUIREMENTS

The testing shall be performed according to one of the following alternatives:

- SS-EN 571-1 "Non-destructive test - Liquid penetrant testing Part1 General principles"
- ASME V article 6 "Liquid Penetrant examination"

Other equivalent foreign standard for testing can be used only after approval of the purchaser.

Penetrant fluids used for testing austenitic stainless steel, titanium alloys or nickel alloys shall be analysed and meet the requirements in ASME V, paragraph T-641.

The analysis shall be carried out on every lot of penetrant fluids. Every package must be marked with the lot number and be traceable to its certificate of analysis.

ACCEPTANCE CRITERIA***Tested surfaces must not have cracks or any other surfacing discontinuities, which can cause indications to a larger extent than stated below.*****1. General requirements****1.1 Sealing surfaces and seal welds**

No indications accepted.

1.2 Weld joints and adjoining heat-affected zone, single-run, pressure retaining part

No indications accepted.

LIQUID PENETRANT TESTING**EP 2-, 3-, 4-, 5-16**
PAGE 5/5**1.3 Other weld joints and adjoining heat-affected zone**

Acceptance level 1 according to SS-EN ISO 23277.

1.4 Surface deposit material (not sealing surfaces)

Acceptance level 2 according to SS- EN ISO 23277.

1.5 Other surfaces including weld bevels

Acceptance level 1 according to SS-EN ISO 23277.

1.6 Castings excluding weld bevels

Acceptance level 2 according to SS-EN ISO 23277.

1.7 Bolts and nuts

Linear indications are not accepted. Acceptance level 1 for non-linear indications.

Type of indication	Acceptance level		
	1	2	3
Linear indication l = length of indication	$l \leq 2$	$l \leq 4$	$l \leq 8$
Non-linear indication d = major axis dimension	$d \leq 4$	$d \leq 6$	$d \leq 8$
Acceptance levels 2 and 3 may be specified with a suffix "X" which denotes that all linear indications detected shall be evaluated to level 1.			

Table 1 Acceptance levels according to SS-EN-ISO-23277**CERTIFICATION**

The results of the inspection shall be reported in a test report containing a minimum of information according to SS-EN 571-1 chapter 9.

MAGNETIC PARTICLE TESTING

EP 2-, 3-, 4-, 5-17
PAGE 1/5

APPLICATION

The inspection concerns surface breaking discontinuities in weld joints, surface welds, sealing surfaces and other surfaces of mechanical equipment or parts thereof made of ferromagnetic material.

The inspection shall be carried out on the final surface, after forming, heat treatment and machining.

SCOPE

At manufacturing, installation and repair, the following shall be tested:

Weld bevels, surfaces to be welded, welded joints including heat-affected zones, buttering welds, surface welds and surfaces machined to final surface.

The applicable inspection plan shall give the detailed extent of the testing.

The principle for the application and extent of testing the following applies:

1. Pressure retaining equipment or parts thereof

1.1 *Details of forgings and bars*

Quality class 1 and 2:

- Accessible surfaces and weld bevels as well as special surfaces according to section 2.

Quality class 3-4:

- Special surfaces according to section 2.

1.2 *Castings*

Quality class 1 and 2:

- Accessible surfaces and weld bevels as well as special surfaces according to section 2.

Quality class 3-4:

- Weld ends
- Special surfaces according to section 2

MAGNETIC PARTICLE TESTING**EP 2-, 3-, 4-, 5-17
PAGE 2/5****1.3 Plate and sheet**

Quality class 1 and 2:

- Weld bevels and special surfaces according to section 2.

Quality class 3-4:

- Special surfaces according to section 2.

1.4 Pipes and pipe fittings

Quality class 1, 100% and quality class 2, random test.

- Cold worked sections following bending of pipes and pipe fittings as follows:

Ferritic pipes and pipe fittings where $R < 6xOD$.

R = mean bending radius

OD. = nominal outside diameter

Weld edges and special surfaces according to section 2.

Quality class 3-4:

- Special surfaces according to section 2.

1.5 Bolts and nuts, special

Quality class 1-4

- Accessible surfaces

1.6 Bolts and nuts, standard

Quality class 1, 100% and quality class 2, random test:

- Accessible surfaces with a thread diameter $> M 24 / 1"$.

1.7 Bellows, pressure vessels and pipes

Quality class 1-2:

- Accessible surfaces and weld bevels as well as special surfaces according to section 2.

MAGNETIC PARTICLE TESTING**EP 2-, 3-, 4-, 5-17**
PAGE 3/5**1.8 *Bellows for valves and valve closing devices***

Quality class 1-2:

- Accessible surfaces

Quality class 3-4:

- Accessible surfaces for valves DN > 150 / 6" NPS.

Quality class 1-4:

- Surfaces to be surface welded.

2. Weld bevels and special surfaces**2.1 *Weld bevels***

Quality class 1-4:

- All weld bevels in castings, other weld bevels in quality class 1 and 2 where the nominal thickness of material is > 10 mm.

2.2 *Special surfaces*

Quality class 1-4:

- All surfaces where temporary welds have been removed.

Quality class 1-2:

- Surfaces to be surfaces welded.
- Cold deformed areas.
- Surfaces where a visual inspection has indicated the necessity.

3. Weld joints in pressure retaining and load bearing parts**3.1 *Vessels, pipelines, welded pipes and fittings***

Butt weld:

Quality class 1: Full extent

Other weld joints:

Quality class 1-4: Full extent

(For class 4 ic C normally a visual inspection according to EP 3/5-13 is sufficient).

Surfaces where a visual inspection has indicated the necessity.

MAGNETIC PARTICLE TESTING**EP 2-, 3-, 4-, 5-17
PAGE 4/5****3.2 Welds in supports for piping DN>50 / 2" NPS**

Quality class 1: 10%

Quality class 2-4: Surfaces where a visual inspection has indicated the necessity.

3.3 Pipe rupture restraints

Weld joints: 10%

3.4 Pumps, valves and in-line instruments

Butt weld:

Quality class 1-2: Full extent

Quality class 3-4: Surfaces where a visual inspection has indicated the necessity.

Other weld joints:

Quality class 1-4: Full extent

(For class 4 ic C normally a visual inspection according to EP 3/5-13 is sufficient).

TEST REQUIREMENTS

The testing shall be performed according to one of the following alternatives:

- SS-EN ISO 17638 "Non-destructive testing of welds -.Magnetic particle testing
- SS-EN 1369 "Founding – Magnetic particle testing"

ASME V article 7 "Magnetic Particle Examination"

Other equivalent foreign standard for testing can be used only after approval of the purchaser.

Magnetic particle examination shall be done in two opposite perpendicular directions. Contrast aid shall be used if needed.

Sealing surfaces and surface welds shall be tested by penetrant testing according to inspection procedure KBM EP-16.

MAGNETIC PARTICLE TESTING**EP 2-, 3-, 4-, 5-17**
PAGE 5/5**ACCEPTANCE CRITERIA**

Tested surfaces must not have cracks or other surface breaking discontinuities, which will cause indications to a larger extent than specified below.

1. General requirements**1.2 Weld joints and adjoining heat-affected zone, single-run, pressure retaining parts:**

No indications accepted.

1.3 Other weld joints and adjoining heat-affected zone.

Acceptance level 1 according to SS-EN ISO 23278.

1.5 Other surfaces including weld bevels

Acceptance level 1 according to SS-EN ISO 23278.

1.6 Castings excluding weld bevels

Acceptance level 3 according to SS-EN 1369.

1.7 Bolts and nuts

Linear indications are not accepted. Acceptance level 1 for non-linear indications.

Type of indication	Acceptance level		
	1	2	3
Linear indication l = length of indication	$l \leq 1,5$	$l \leq 3$	$l \leq 6$
Non-linear indication d = major axis dimension	$d \leq 2$	$d \leq 3$	$d \leq 4$
Acceptance level 2 and 3 may be specified with a suffix "X" which denotes that all linear indications detected shall be evaluated to level 1.			

Table 2 Acceptance levels according to SS-EN ISO 23278

CERTIFICATION

The results of the inspection shall be reported in a test report comprising at least information according to SS-EN-ISO 17638, for castings SS-EN 1369.

**INDUCTIVE TESTING OF MATERIAL
AND WELDS**

**EP 2-, 3-, 4-, 5-18
PAGE 1/1**

APPLICATION

As an alternative for PT and MT according to KBM-EP 2-, 3-, 5-16 or –17 inductive testing (ET) can be used.

SCOPE

According to KBM-EP 2-, 3-, 5-16 or –17.

TEST REQUIREMENTS

The testing shall be performed according to:

- SS-EN 1711 "Inductive testing of welds by complex plane analysis".
- and one for the application prepared detailed examination procedure.

ACCEPTANCE CRITERIA

The evaluation shall be performed based upon the requirement for the object in question as per the detailed testing procedure.

CERTIFICATION

The results of the inspection shall be reported in a test report containing at a minimum the information according to SS-EN 1711 chapter 7.

IN-PROCESS INDUCTIVE TESTING OF TUBES FOR HEAT EXCHANGERS

EP 2-19
PAGE 1/1

APPLICATION

Testing for detection of discontinuities oriented longitudinally and laterally to the circumference of the tubes.

A procedure for testing the tubes in question shall be drawn up and approved by the purchaser.

The testing shall be carried out on the finished surface after forming, heat treatment and machining.

SCOPE

Quality class 1-3:

Material for heat exchanger tubes with an outside diameter OD < 25 mm / 1", and wall thickness $t < 1,5$ mm, shall be fully tested.

TEST REQUIREMENTS

Depending on the tube material, the testing shall be carried out according to an approved procedure, meeting the requirements of the standards in table 3.

ACCEPTANCE CRITERIA

See table "Test standards".

CERTIFICATION

The results of the test shall be recorded in a report with details of the test object, procedure, extent, equipment, results and date as well as name and qualification level of the operator conducting the test.

Material	Standard
Ferromagnetic steel	ASME V SE-309
Austenitic steel	ASME V SE-426
Copper alloys	ASME V SE-243
Nickel based alloys	ASME V SE-571
"Steel pipes" SS/CS	SS-EN 12084

Table 3 Test standards

EN-standards such as SS-EN 10246 and SS-EN 1971 and similar may also be used.

POST PRODUCTION ULTRASONIC TESTING OF PLATE

EP 2-20
PAGE 1/2

APPLICATION

Testing concerning lamination in plate and lamination or incomplete bonding in compound materials. Compound material means plating applied by rolling or explosive cladding.

The testing shall be performed after forming and heat treatment.

SCOPE

Plate of thickness ≥ 6 mm shall be tested according to extent of table 4.

TEST REQUIREMENTS

Ultrasonic testing shall be carried out according to paragraph 4 and 5 of ASME V SA 578, where the test equipment is calibrated by means of bottom echo method.

Alternatively testing may be performed according to SS-EN 10160 or SS-EN 10307.

If other equivalent method is preferred, it must prior to the test be approved by the purchaser.

For testing of plate for welding plates and plate exposed to local lateral loads, the test equipment shall be calibrated towards reference blocks with flat-bottom holes, alternatively AVG scales, AVG diagrams or equivalent aids.

As an alternative the testing could be carried out according to SS-EN 10160.

ACCEPTANCE CRITERIA

Lamination is not accepted in the following areas:

1. Plate and compound materials

- Each area with lamination which causes a complete loss of the bottom echo and which cannot be inscribed in a circle with a diameter of 36 mm or half of the plate thickness, whichever is larger.
- Each area where two or more laminations larger than or equal to 50 % of the original bottom echo and simultaneously a decrease of the bottom echo to 50% or more which cannot be inscribed in a circle with a diameter of 36 mm or half of the plate thickness, whichever is larger.
- Two or more adjacent areas with lamination smaller than the above mentioned, shall be regarded as one area if the distance between them is less than the inscribed diameter of the larger area.

Complete loss of the bottom echo means that the bottom echo is less than 5% of calibrated amplitude on the screen.

Alternative acceptance level according to SS-EN 10160 class S2 or SS-EN 10307 class S2. For edge zones SS-EN 10160 table 5 class E3 applies to both ferritic and austenitic plates.

POST PRODUCTION ULTRASONIC TESTING OF PLATE

EP 2-20
PAGE 2/2

2. Areas exposed to lateral loads and plate for welding plats

- Lamination with indications larger than a flat bottom hole with a diameter of 8 mm are not acceptable.

The number of indications producing echoes corresponding to flat bottom holes with diameters between 5 and 8 mm must not exceed 3 per dm². Alternative acceptance level according to SS-EN 10160 table 5 class E4 for both feritic and austenitic plates.

CERTIFICATION

Test reports shall be prepared and contain at least the following:

- Complete identification of the tested item.
- The condition of the test surface.
- Test method, equipment, type, model, and device number.
- Probe, type, model, frequency and size of crystal.
- Reference amplification.
- Scanning method and coupling agent.
- Calibration method, possible reference blocks.
- Corrections, if any.
- Reference to applied test standards and KBM inspection procedures or detailed procedures.
- Test results and extent of inspection.
- Name and date and the operator's level of qualification.

Alternatively test report according to SS-EN 10160.

t i mm	Plate for pressure retaining equipment Quality Classes 1 2	Plate for pressure retaining and load bearing equipment exposed to lateral loads	Plate for welding plates
6 – (15)	100 mm ¹ 100 mm ^{1,4}	100 % ²	100 % ³
15 -	100 % 100 mm ¹	100 % ²	100 % ³

Table 4 Extent of inspection, UT, - Plate and Compound material

- 1) Testing of the plate across a 100 mm square grid.
- 2) For local lateral load the width of the test area must be the highest value of 50 mm or the load engagement plus twice the thickness of the connecting plate. The area around holes will be tested only if DN > 50 / 2" NPS (diameter of hole larger than 50 mm).
- 3) Plate tested according to SS-EN 10160 class S3/S4 or SS-EN 10307 S3/E4 is accepted.
- 4) For base material to welded pipes and piping DN>100 / 4" NPS and PN>40 bar g.

ULTRASONIC TESTING OF FORGING AND BAR STOCK AND MATERIAL FOR BOLTS AND NUTS

EP 2-21
PAGE 1/5

APPLICATION

Testing concerning internal discontinuities in equipment or parts thereof made from forgings or bars with OD>25 mm, and bolts and nuts with a nominal thread diameter larger than M 24 / 1".

Specific correction measuring applies to austenitic stainless materials. This does not apply for bolts and nuts.

The testing shall be performed after final forming and heat treatment, but before threading. The testing may be carried out before final forming provided **no** further heat treatment is required.

The testing shall be performed according to:

- SS-EN 10228-3 for ferritic and martensitic steel forgings
- SS-EN 10228-4 for austenitic and ferritic-austenitic forgings in stainless steel
- SS-EN 10308 for steel bars
- or other between purchaser and manufacturer agreed code/standard

Procedure to be prepared based upon the respective standard and the procedure to be approved by the purchaser. When agreed a detailed procedure for testing of the actual details (DUP) shall be prepared and approved by the purchaser.

SCOPE

The test object shall be examined to an extent stated in the detailed inspection plan for the equipment or component in question, and if applicable to the detailed procedure (DUP).

As a **principle** for the extent of test, the following is applicable:

1. Forgings and bars for pressure retaining and load bearing equipment

Quality class 1:

- All to full extent if OD of the completed equipment is > DN 25 / 1" NPS

Quality class 2:

Pressure retaining equipment:

- To full extent if OD of the completed equipment is > DN 100/ 4" NPS and design pressure > 4 Mpa
- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.

**ULTRASONIC TESTING OF FORGING AND BAR
STOCK AND MATERIAL FOR BOLTS AND NUTS**

**EP 2-21
PAGE 2/5**

Load bearing equipment:

- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.
- If required due to the design with regard to loads and strength margins.
- If required by the purchaser.

Quality class 3-4:

Pressure retaining equipment:

- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.

Load bearing equipment:

- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.
- If required with regard to loads and strength margins.
- If required by the purchaser.

2. Material for bolts and nuts, "special"

Quality class 1-2:

- All to full extent if $OD > M 24 / 1$ ".
- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.

3. Material for bolts and nuts, "standard"

All quality classes:

- Whenever required in the material standard with the applicable technical, delivery and inspection conditions.

**ULTRASONIC TESTING OF FORGING AND BAR
STOCK AND MATERIAL FOR BOLTS AND NUTS****EP 2-21
PAGE 3/5****TEST REQUIREMENTS**

Material to be tested as per the requirements of the respective standard in section “application”. As an alternative the testing may be performed as agreed between the purchaser and the supplier, this then to be reflected in the detailed inspection plan and the detailed test procedure (DUP).

In addition the following applies to manual scanning unless otherwise agreed:

- The test shall be performed with impulse echo equipment with calibrated gain control.
- Ultrasonic probe crystal size and type of sound wave shall be chosen with regards to the test object.
- The sound frequency shall be between 2 and 4 MHz.
- The test equipment shall be calibrated to reference block with reference reflector of type flat bottom hole.
- The reference block material shall have equivalent features, belong to the same material group and heat treatment state as well as having equivalent surfaces as the test objects.
- The diameter of the reference reflector shall be 5% of the nominal thickness of the test object at its final condition, but still no less than 3 mm or no larger than 5 mm.
Alternatively, AVG scales or AVG diagrams may be used for testing of carbon steel.

In certain cases AVG scales could also be permitted for testing of austenitic stainless materials and ferritic-austenitic materials. In these cases the sound attenuation conditions must correspond to the requirements of the respective AVG scale.

If the indications are manually registered, the signal to noise level proportion within the operating range must not be less than 3:1 during the scanning.

The sensitivity adjustment shall be checked before and after testing each test object.

If the sensitivity has decreased by more than 4 dB, results from testing after the latest check shall be cancelled and the actual areas shall be re-examined when the reason for the decrease in sensitivity has been established and required actions have been taken.

ULTRASONIC TESTING OF FORGING AND BAR STOCK AND MATERIAL FOR BOLTS AND NUTS**EP 2-21
PAGE 4/5****Specific correction measurements of sound attenuation:**

In order to determine the testability for further in service inspection of austenitic stainless materials, specific correction measurements of sound attenuation shall be taken on forgings with weld ends in quality class 1 and also in other quality classes if agreed between the purchaser and the manufacturer.

These examinations to be performed according to SS-EN 583-2 section 6.5.3 and also in compliance with the stipulations of the section Test requirements above.

Scanning

The scanning direction must be adapted to the geometry of the test object and the possible defects the manufacturing process in question might cause. The whole volume of the test object shall be scanned with a normal scanner in two directions approximately perpendicular to each other.

As an alternative, or, if required by the purchaser, forged material shall be scanned with an angle probe if the total volume cannot be tested with standard probe.

When testing is performed prior to the final machining e.g. solid forgings for valves, T-pieces etc. the material volume to be removed can be disregarded at testing and calibration.

Detailed procedure description (DUP)

The detailed procedure, if agreed, shall contain at least the following data:

- Description of the test object
- Reference to the inspection plan
- Standard for test / procedure
- Reference reflector
- Probe
- Ultrasonic test apparatus
- Description of method for measuring of sound attenuation
- Description of certain measurements of sound attenuation
- Scanning area and scanning directions
- Couplant
- Acceptance criteria

ULTRASONIC TESTING OF FORGING AND BAR STOCK AND MATERIAL FOR BOLTS AND NUTS

EP 2-21
PAGE 5/5

ACCEPTANCE CRITERIA

Unless other agreed between purchaser and supplier, below acceptance criteria apply.

The following applies to discontinuities:

Stainless forgings according to SS-EN 10228 quality class 3

Ferritic forgings according to SS-EN 10228 quality class 4

Stainless bar material SS-EN 10308 quality class 3

Ferritic bar material SS-EN 10308 quality class 4

For specific correction measurements of stainless steel forgings the below acceptance criteria applies:

When $\Delta V_t \geq 10\text{dB}$ the purchaser to be contacted for decision and further action.

Note that high attenuation and/or significant variations in attenuation in forgings may be caused due to coarse grain size. Examination of grain size then to be considered as per KBM EP 2-08.

CERTIFICATION

A test report shall be prepared and contain at least the following:

- Complete identification of the test object.
- The condition of the test surface.
- Test method.
- Test apparatus, type, model, and apparatus number.
- Probe, type, model, frequency and size of crystal.
- Reference amplification.
- Scanning method and coupling agent.
- Calibration method, possible reference blocks.
- Corrections, if any.
- References to applied testing standard, KBM inspection procedure or detailed procedure.
- Result and reporting of specific correction measurements and signal/noise conditions
- Name and date and the operator's qualification level.

IN-PROCESS ULTRASONIC TESTING OF PIPES

EP 2-22

PAGE 1/3

APPLICATION

Testing to detect discontinuities oriented longitudinally and laterally to the circumference direction of the pipes.

The plate raw material for welded pipes with a thickness of ≥ 6 mm in quality classes 1 and 2 shall be tested and meet the requirements in KBM EP 2-20.

SCOPE

The material in pipes shall be tested to the full extent with regard to longitudinal and transversal defects.

As a **principle** for the testing the following is applicable:

1. Pipes

Quality class 1:

- All pipes to full extent

Quality class 2:

- Pipes with DN > 100 / 4" NPS with a design pressure > 4 MPa shall be tested to full extent.
- Weld seams in longitudinally welded pipes shall be tested in full extent regardless of dimension and design pressure. Alternative testing according to EP 3-28.
- Whenever required in material standard with applicable technical-, delivery- and inspection requirements.

Quality class 3-4

- Weld seams in longitudinally welded pipes with a weld joint efficiency factor (z) = 1,0 shall be tested to full extent. Alternative testing according to EP 3-28.
- Whenever required in material standard with applicable technical-, delivery- and inspection requirements.

TEST REQUIREMENTS

Tests shall be performed according to an approved detailed procedure. The procedure shall be based on a well proven standard that, through experience, has shown the ability to detect manufacturing defects that may occur during the manufacturing process.

IN-PROCESS ULTRASONIC TESTING OF PIPES**EP 2-22****PAGE 2/3**

In the cases where unambiguously technical and delivery conditions do not exist or are incomplete, the procedure can be based on SS-EN 583-1 with reference reflectors according to the following:

- length to be ≤ 25 mm.
- width to be ≤ 1.5 mm.
- depth to be 5% of the wall thickness of the reference pipe, however, no less than 0,1 mm or no deeper than 1,5 mm.

At testing of welded joints in austenitic steel the frequency and type of sound waves of the ultrasonic probe must be selected in a way that a necessary signal - noise level proportion of 3:1 will be achieved and that uncontrolled refraction of the sound waves is avoided.

The test can be performed either manually or mechanically in an automatic pipe testing rig.

Such mechanically controlled testing shall be carried out with continuous automatic recording of the results.

Detailed procedure description (DUP)

The detailed procedure shall as a minimum contain the following data:

- Description of the test object,
- Reference to the inspection plan
- Standard for test / inspection requirements / procedure
- Reference reflector
- Probe
- Ultrasonic test apparatus
- Scanning area and scanning directions
- Couplant
- Acceptance criteria
- Description of sound attenuation measurements.

ACCEPTANCE CRITERIA

Discontinuities producing indications larger than the echo from the reference reflector will not be accepted.

IN-PROCESS ULTRASONIC TESTING OF PIPES**EP 2-22**
PAGE 3/3**CERTIFICATION**

A test report shall be prepared and contain at least the following:

- Complete identification of the test object.
- The condition of the test surface.
- Test method.
- Test apparatus, type, model, and apparatus number.
- Probe, type, model, frequency and size of crystal.
- Reference amplification.
- Scanning method and coupling agent.
- Calibration method, possible reference blocks.
- Corrections, if any.
- Reference to applied inspection standard, KBM inspection procedure or detailed procedure.
- Test results and extent of inspection.
- Name and date and the operator's qualification level.

ULTRASONIC TESTING AFTER SURFACE WELDING EP 3-, 5-23

PAGE 1/3

APPLICATION

Testing concerning slag inclusions lack of fusion and cracks in surface weld deposit and heat affected zones.

Surface weld deposit denotes weld metal for protection against corrosion and abrasion.

The test shall be performed on final heat-treated condition.

When testing for cracks, the surface finish of the weld material must not exceed Ra 10 (µm).

A detailed procedure for testing of the surface weld in question shall be prepared by the supplier and approved by the purchaser.

SCOPE

The following parts of equipment shall be tested for lack of fusion, slag inclusions and cracks.

The principle for the test extent is:

Quality class 1 and 2:

Pressure retaining and load bearing equipment parts which have been surface welded.

Quality class 3 and 4:

Equipment parts where the surface weld metal is pressure retaining or load bearing.

In addition, low alloy steel without a documented resistance to re-heating cracks shall be tested for cracks in the surfacing and heat affected zone.

The following empirical relationship may serve as a guideline for evaluating the susceptibility of the material to cracking.

$$\Delta G = Cr + 3,3xMo + 8,1xV - 2$$

Where, Cr is the content of chromium, Mo content of molybdenum and V content of vanadium. If $\Delta G \geq 0$, the steel is considered as sensitive to cracking.

ULTRASONIC TESTING AFTER SURFACE WELDING EP 3-, 5-23

PAGE 2/3

TEST REQUIREMENTS

The test shall be performed with an impulse echo apparatus with calibrated amplification control.

The standard probe shall be of either single or dual crystal type.

Angle probes shall be of the dual crystal type with the crystals matched to ensure that the sensitivity is at maximum in the transition zone between surface weld and base material.

The refraction angle and the beam exit point of the angle probe shall be checked by means of a calibrating block that has equivalent acoustic properties of the test object. The sensitivity of the test apparatus and the reference level shall be calibrated against a reference body with cylindrical hole \varnothing 2,0 mm drilled in the transition area between the surface weld and the base material.

The material of the reference body shall have equal properties, belong to the same category of material and heat treatment condition and also have equal surfaces as the test object.

The sensitivity adjustment shall be checked before and after testing every test object.

If the sensitivity has decreased by more than 4 dB, the results from the testing after the last check shall be cancelled and applicable areas shall be re-examined when the reason for the decrease in sensitivity has been determined and the required action has been taken.

Scanning

Testing of lack of fusion and slag inclusions is made with a standard probe.

Testing concerning cracks is made with a 70° angle probe.

Scanning with a standard probe is made from either the surface deposit side or the base material side.

Scanning with a 70° angle probe shall be made from the surface deposit side. Scanning is made in the direction of the surfacing and also at the angle of 45° to it.

Recording and evaluation

All discontinuities giving indications above 50% of the reference level shall be evaluated to determine the causes.

For evaluating crack like indications, at least two opposite directions must be scanned.

The longitudinal propagation of discontinuities shall be stated in terms of the probe displacement where the amplitude exceeds 50% of the reference level.

ULTRASONIC TESTING AFTER SURFACE WELDING **EP 3-, 5-23** **PAGE 3/3**

Detailed procedure description (DUP)

The detailed procedure description shall contain at least following data:

- Description of the test object
- Reference to the inspection plan
- Standard for test / procedure description
- Reference reflector
- Probe
- Ultrasonic test apparatus
- Scanning area and scanning directions
- Couplant

ACCEPTANCE CRITERIA

Cracks and crack-like defects will not be accepted.

Lack of fusion defects and slag inclusions giving indications larger than the reference level are not accepted.

The number of lack of fusion defects and slag inclusions giving indications with echoes equivalent to 50 to 100 % of the reference level must not exceed 15 per m².

The maximum acceptable dimension is 25 mm.

CERTIFICATION

A test report shall be prepared and contain at least the following:

- Complete identification of the test object.
- The condition of the test surface.
- Test method.
- Test apparatus, type, model, and apparatus number.
- Probe, type, model, frequency and size of crystal.
- Reference amplification.
- Scanning method and coupling agent.
- Calibration method, possible reference blocks.
- Corrections, if any.
- Reference to applied inspection standard and KBM inspection procedure or detailed procedure.
- Test results and extent of inspection.
- Name and date and the operator's qualification level.

ULTRASONIC TESTING OF WELDED JOINTS DURING EP 3-, 5-24 MANUFACTURE AND INSTALLATION

PAGE 1/2

APPLICATION

Ultrasonic testing to identify welding defects in full penetration butt welds, T-joints and corner joints in ferritic steels as an alternative for RT according to EP 3- 5-28.

The testing shall also include weld metal in buttering welds.

The testing shall be carried out after heat treatment and possible machining.

The testing of the fusion zone between the buttering weld and the base material may be carried out prior to other welding.

A detailed procedure for testing the weld joint in question shall be prepared by the supplier and approved by the purchaser.

SCOPE

Quality class 1 and 2:

All weld joints with a nominal wall thickness > 8 mm to be tested to full extent with regard to longitudinal or transversal defects.

Quality class 3-4:

Weld joints with a weld joint efficiency factor $z > 0,8$ shall be tested to full extent.

The extent of testing in quality class 3 shall correspond to ASME III-ND and for class 4 valid AFS.

The extent for austenitic stainless material and carbon steel is normally 10%. (For class 4 bk C normally a visual inspection according to EP 3/5-13 is sufficient).

Testing shall be extended as follows if defects are found and the weld fails to be approved:

A further 800 mm weld made by the same welder and adjoining the location where the defects were detected, shall be tested.

If the weld in question is less than 800 mm in length, the full welded joint shall be tested. In case of special reasons, the additional testing shall also be carried out on other parts of the equipment.

If any part of the extended testing is unacceptable the weld where the defect was discovered shall be tested to its full extent. Further 10% of the not earlier tested joints of the equipment, made by the same welder, shall be tested.

If then, any part is found unacceptable the weld joints shall be tested to full extent.

ULTRASONIC TESTING OF WELDED JOINTS DURING EP 3-, 5-24 MANUFACTURE AND INSTALLATION

PAGE 2/2

TEST REQUIREMENTS

The testing shall be carried out according to approved procedure meeting the requirements in section SS-EN ISO17640 level B, SS-EN ISO 22825 or corresponding requirements in equivalent foreign standard.

Detailed procedure description (DUP)

The detailed procedure shall contain at least the following data.

- Description of the test object
- Reference to the inspection plan
- Standard for test / procedure description
- Reference reflector
- Probe
- Ultrasonic test apparatus
- Scanning area and scanning directions
- Couplant
- Acceptance criteria

ACCEPTANCE CRITERIA

Acceptance level 2 according to SS-EN ISO 11666.

CERTIFICATION

The test report shall be prepared and contain at least the information according to SS-EN ISO17640 chapter13.

RADIOGRAPHIC TESTING FOR PRODUCTION OF CASTINGS

**EP 2-27
PAGE 1/2**

APPLICATION

Testing concerning internal discontinuities in parts of equipment made of steel and aluminium casting and nodular iron.

Testing shall be performed after finished forming and heat treatment.

If appropriate, for production or test reasons, the testing can be performed at an earlier stage on the following conditions:

- that the thickness of the material at the test occasion may exceed the final thickness with a maximum of 20% if it is less than 150 mm.
- if the final thickness is larger than 150 mm, the thickness at the test occasion must not exceed the final with more than 10%.
- evaluation of the result shall regardless of the thickness at the test occasion be made against the standard valid for final thickness according to table 5.
- required supplementary testing will be made after final forming and heat treatment.

SCOPE

Quality class 1-2:

All castings shall be tested to the extent specified in ASME III, sub-paragraphs NB-2575.2 and NC-2575.2, respectively.

The film coverage shall be shown as a film map.

Quality class 3-4:

Highly stressed parts shall be tested. ASME III, paragraph ND-2571 is valid for design according to ASME.

Weld ends for pipe connections for equipment in quality class 3 shall be tested. The film coverage shall be shown as a film map.

For quality class 4 the extent according to applicable AFS is valid.

TEST REQUIREMENTS

Testing shall be carried out according to SS-EN 12681 class A.

Image quality according to SS-EN 462-3 class A.

Radiograms shall be interpreted according to SS-EN 25580.

If corresponding equivalent foreign standards for testing and interpretation are desired to be used, these to be approved by the purchaser.

RADIOGRAPHIC TESTING FOR PRODUCTION OF CASTINGS

EP 2-27
PAGE 2/2

ACCEPTANCE CRITERIA

Depending on the final material thickness and the test object, the test shall be evaluated according to standards in table 5 subject to the following:

- Defects in category D, E, F, and G will not be accepted.
- Casting for equipment in quality class 1 with a thickness of less than 25 mm must meet the requirements according to "Severity Level 1".
- Weld ends of casting for equipment of in quality class 1-3 must meet the requirements according to "Severity Level 1" provided the material is of even thickness, from the final joint surface up to a distance of 20 mm.
- Other castings shall fulfil the requirements of "Severity Level 2". However "Severity Level 3" can be applied for gas bubbles and non-metallic inclusions.

CERTIFICATION

A test report shall be prepared and contain at least the following data:

- Complete identification of the test object and test area.
- Dimensions and material of the test object.
- Marking.
- Test method and class.
- Radiation source and exposure time.
- Position of radiation source relative the test object, film, intensifying screens and filter, if any.
- The films location on the test object – Film plan.
- Image quality indicator and image quality.
- Phase of production.
- Reference to applied inspection standard and KBM inspection procedure or detailed procedure.
- Test results.
- Name, date and qualification level of the operator and the radiograph interpreter

Standard	Thickness, t in mm
ASTM E 446	$t \leq 50$
ASTM E 186	$50 < t \leq 115$
ASTM E 280	$t > 115$
ASTM E 155	Aluminium
ASTM E 689	Nodular-iron

Table 5 STANDARDS FOR EVALUATION OF RADIOGRAMS

RADIOGRAPHIC TESTING OF WELDED JOINTS DURING MANUFACTURE AND INSTALLATION

**EP 3-, 5-28
PAGE 1/2**

APPLICATION

Testing to detect defects in penetrating butt welds and corner joints as well as in weld deposit in buttering welds

The testing shall be carried out after finished forming, heat treatment and possible machining.

SCOPE

Quality class 1 and 2:

All welded joints shall be completely tested.

Quality class 3-4:

Weld joints with a weld joint efficiency factor $z > 0,85$ shall be tested to full extent. The extent of testing for quality class 3 shall follow ASME III-ND and for class 4 valid AFS.

The extent for austenitic stainless materials and carbon steel is normally 10%.
(For class 4 ic C normally a visual inspection according to EP 3/5-13 is sufficient)

Corner welds:

Interpretation of the extent of 100% radiographic test of corner welds between nozzles and branches on pipes and components.

OD = Nominal outside diameter in mm for nozzle or branch at connection to pipe or component.

OD \geq 125	In agreement with the purchaser and the Accredited Laboratory, placement of films can be performed with partial coverage (e.g. 4 exposures equally distributed at 90° around the circumference). In addition, internal and external surface crack testing shall be performed. The agreed testing shall be specified in the detailed inspection plan.
70 \leq OD < 125	As a minimum one film, the purchaser and the Accredited Laboratory shall decide extent and location. In addition, internal and external surface crack tests shall be performed. The agreed testing shall be specified in the detailed inspection plan.

RADIOGRAPHIC TESTING HAVE WELDED JOINTS EP 3-, 5-28
DURING MANUFACTURE AND INSTALLATION PAGE 2/2

If any such defect is found which render the welding unacceptable, the testing shall be extended as follows:

A further 800 mm length of weld made by the same welder, adjoining the location where the defects were detected, shall be tested.

If the length of the welded joint in question is less than 800 mm, the joint shall be tested completely. In case of special reasons, the additional testing shall also be extended to other parts of the equipment.

If any part of the extended test cannot be approved, the entire welding in which the defect was discovered shall be tested at full length. Furthermore, 10% of the welded joints on the equipment made by the same welder, which have not earlier been tested, to be tested if thereafter any part cannot be approved, all weld joints in question to be tested.

TEST REQUIREMENTS

Testing shall be carried out according to an approved procedure meeting the requirements of SS-EN 1435 class B.

If corresponding equivalent foreign standards for testing and interpretation are desired to be used, these to be approved by the purchaser.

ACCEPTANCE CRITERIA

Acceptance level 1 according to SS-EN 12517.

CERTIFICATION

The test report shall be prepared and contain at least the information according to SS-EN 444 chapter 7.

VISUAL TESTING OF MATERIAL AND WELDS EP 2-, 3-, 5-29PAGE 1/1

APPLICATION

As an alternative to PT and MT according to EP 2-, 3-, 5-16 respective –17 testing with visual technique, VT, may be used.

SCOPE

See EP 2-, 3-, 5-16 respective –17.

TEST REQUIREMENTS

The test shall be performed according to:

- SS-EN 970
Within this standard the special developed procedure for in-service inspections may be used:
- P2VT190306-RAM-VT11, Edition 1, Revision 11 "General Procedure for Moulding VT of Surface Breaking Defects in Metallic Materials, Detection, Characterisation and Length Sizing of Defects"

A detailed test procedure alternatively a Technique sheet shall be prepared and reviewed.

ACCEPTANCE CRITERIA

According to the detailed test procedure. The acceptance level shall correspond to the one for MT according to EP 2-, 3-, 5-17.

CERTIFICATION

A test certificate shall be prepared according to the requirements in the detailed test procedure and at least contain the information corresponding to the requirements in EP-2-, 3- 5- 17.

BENDING OF PIPES

EP 3-, 5-43
PAGE 1/1

APPLICATION

Inspection of cold bending of pipes including inspection of the equipment used, performed through test bending. Cold bending shall be performed in compliance with a procedure that is prepared by the manufacturer and approved by the purchaser. The procedure shall fulfil the requirements in TBM section “Forming and straightening”.

SCOPE

At a minimum one test prior to installation, thereafter tests under the installation phase on random basis.

ACCEPTANCE CRITERIA

According to the purchaser approved procedure.

Cold formed sections shall in quality class 1-2 be examined by liquid penetrant- or magnetic particle test, as per extent specified in EP 2-16/17.

CERTIFICATION

The certificate that shall be prepared by the manufacturer, shall at least state/contain the following data:

- Inspected parts/extent
- Procedure applied
- Results and conclusions
- Date and name of the inspector

If a surface crack test (PT or MT) is performed, the result is to be reported in a separate report attached to the certificate for the inspected bend.

INSTALLATION OF PIPE COUPLINGS**EP 3-, 5-48****PAGE 1/1**

APPLICATION

Visual inspection of installation of couplings furnished with cutting / compression ring.

SCOPE

Inspection shall be carried out to verify.

- That the prescribed approved installation procedure or instruction has been followed.
- The qualifications of the installation staff.

ACCEPTANCE CRITERIA

Couplings shall be installed according to installation procedures or instructions approved by the purchaser.

CERTIFICATION

Performed inspections shall be documented in the form of an inspection report.

OPERATION TEST

EP 6-50
PAGE 1/1

APPLICATION

Operation tests and periodic operation tests with regard to pressure vessel safety shall be executed at installations of new parts of the system or after operations affecting or possibly affecting a system function.

SCOPE

After installation the licensee shall perform operation tests to check that safety equipment functions as intended and to make sure the system or equipment works satisfactory.

At the operation test the following shall be inspected:

- The function of pipe supports and fix points and their interaction due to thermal expansion,
- Vibrations in the system,
- Tightness of the system or equipment,
- Pressure relief,
- Functions of other equipment of important for the pressure vessel safety,
- that interlockings of importance for the pressure vessel safety are properly adjusted.

Safety valves, snubbers and other equivalent equipment can be tested in bench.

ACCEPTANCE CRITERIA

The function must correspond with drawings and specifications. Safety equipment shall meet the requirements in instructions and test procedures.

CERTIFICATION

Operating tests shall be documented by the licensee and be supervised by an Accredited Inspection Body.

INSPECTION OF INSTALLATION

EP 6-60
PAGE 1/1

APPLICATION

Inspection of the installation (final inspection) with regard to pressure vessel safety shall be performed at the installation of a new system part or if action is performed that can have an influence on the function of the system.

SCOPE

After installation or repair the licensee shall perform an inspection to ensure that the equipment is installed or repaired in accordance with approved documents.

The following shall be verified at the inspection:

- that the installation of the equipment is in compliance with approved drawings and valid system flow sheets or concept to a new system flow sheet,
- that the equipment has a permanent identification marking that can be tied to the documentation,
- that safety equipment has been function tested and proved to function satisfactory,
- that interlocks essential for the safety are correctly set,
- that the installation or repair is finally judged to satisfy safety related requirements.

ACCEPTANCE CRITERIA

The installation shall comply with drawings and specifications, the installation shall also be confirmed to satisfy safety related requirements. Safety related equipment shall fulfil requirements and test procedures.

CERTIFICATION

The licensee shall document the inspection.

At inspection of equipment in quality class 1-3, 4 with inspection class A-B, the inspection shall be performed under supervision of Accredited Inspection Body.

REVIEW OF FINAL QUALITY CONTROL DOCUMENTATION

**EP 190
PAGE 1/1**

APPLICATION

The review of the final quality control documentation shall verify that the prescribed inspection and testing is carried out according to the detailed inspection plan, with approved results.

SCOPE

All certificates and records required according to the detailed inspection plan.

ACCEPTANCE CRITERIA

In case the supplier prepares the inspection record, his own review of the quality control documentation shall always have been performed with approved result, prior to the purchaser's review.

CERTIFICATION

Up dated document index to be included in the final quality control documentation.

The final quality control documentation shall be organised with the applicable inspection plan as an index.

The quality control documentation shall include all certificates and records according to the requirements of the detailed inspection plan. The certificates shall be identified towards the inspection plan and the relevant detail.

Certificates and records shall verify that all requirements are fulfilled according to the detailed inspection plan.

Certificates and records shall be signed according to the requirements of the respective KBM Inspection Procedure.

Deviations shall be reviewed and the decision of required corrective action shall be issued by an authorised organisation. The corrective action shall be completed, inspected, documented and approved by the authorised organisation.

The delivery must not be released if there are open deviations or if the quality control documentation is rejected. Exemptions are only allowed with the purchaser's written permission.

Certificate to be issued that verifies that the final quality control documentation is reviewed and approved by the authorised organisation.

The certificate shall be included in the final quality control documentation.

COLD BENDING OF HEAT EXCHANGER TUBES**EP 286****PAGE 1/1**

APPLICATION

Before starting the manufacturing the procedures for bending and cleaning of heat exchanger tubes must be qualified. Procedure qualification shall be carried out on tubes from the lot that is to be used for the manufacturing. The bending procedure must be identical with the procedure used at manufacturing.

After bending, the tubes must be cleaned according to the cleaning procedure, which applies to the manufacturing.

The cleaned tubes shall be cut up in small test samples, the bent portions shall be included in the test sample. The test samples shall be inspected concerning cleanliness, surface finish and dimensions.

SCOPE

The testing shall comprise at least 5 test samples of the smallest radius to be used.

ACCEPTANCE CRITERIA

According to the purchaser's approved procedure.

CERTIFICATION

A certificate prepared by the manufacturer shall state:

- Date of inspection
- Used procedure
- Result
- Material certificate and identity of test samples

INSPECTION OF REPAIRS IN WELDS

EP 376**PAGE 1/1**

APPLICATION

Visual and dimensional inspection and non-destructive testing of weld repairs in conjunction with manufacturing and installation.

Removal of defects by for instance grinding

Inspection of the dimension of remaining material thickness of the weld and visual inspection of ground surface according to KBM EP-X-13.

Penetrant or magnetic particle inspection of the surface according to KBM EP-X-16/17.

Repair by welding

Before the weld repair can be started, the manufacturer to prepare a repair procedure. The procedure shall be reviewed and approved by the purchaser.

Prior to the welding, a visual inspection and possible non-destructive testing shall have been carried out.

Prior to the weld repair, the prescribed conditions for the repair shall be verified.

Visual and dimensional inspection as well as the non-destructive testing, prescribed for the original weld shall be repeated for the repaired weld area.

SCOPE

All repairs of unacceptable defects in welds.

TEST REQUIREMENTS

According to the original requirements for the weld.

ACCEPTANCE CRITERIA

All requirements in TBM concerning repairs shall be fulfilled. After the repair, the original acceptance criteria for the weld shall be fulfilled.

CERTIFICATION

The manufacturer shall document all weld repairs and the inspector must verify the data. The documentation must comprise:

- Reason for rejection with reference to existing test records
- Size, depth and location of defect
- Repair procedure
- Inspection reports
- Other reports required by the inspection plan for the original weld

APPENDIX 2 INSPECTION PROCEDURES (OTHER INSPECTIONS)

INSPECTION OF CLEANLINESS

EP 425

PAGE 1/1

APPLICATION

Inspection of the surfaces of the units ready for delivery or receipt inspection is performed through visual inspection of the surfaces.

This inspection can if agreed also be a part of the installation inspection.

SCOPE

All surfaces.

ACCEPTANCE CRITERIA

The cleanliness of the finalised components shall meet the following requirements and/or equivalent requirements stated in the manufacturer's specifications and approved by the purchaser.

Weld Surfaces: Stainless weld surfaces in components for systems for process water shall fulfil the purchasers weld requirements with regard to reference No. 17 concerning oxides. Reference No. 18 can be approved by the purchaser in exceptional cases provided there is no risk for corrosion damage.

Other Surfaces: See General Requirements for Mechanical Equipment, ABM, chapter 3.6.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector. The certificate shall state:

- Date of the inspection
- Detail inspected
- Methods used for the inspection
- Inspection results

INSPECTION OF PACKING AND PRESERVATION**EP 435**
PAGE 1/1

APPLICATION

Visual inspection of component packing and preservation when required by the purchaser.

SCOPE

Random inspection in connection with packing and preservation.

ACCEPTANCE CRITERIA

Compliance with the regulation under the heading "Transport" in current TBM or with specification prepared by the supplier approved by the purchaser.

CERTIFICATION

A certificate shall be issued by the manufacturer and be verified by the inspector with data of the inspected component, the results and the date of the inspection.

TIGHTNESS TEST OF CHECK VALVES AND ISOLATION VALVES

EP 441
PAGE 1/1

APPLICATION

Tightness testing of closing devices.

The valves must not be exposed to abnormal bending or compressive stresses during the test.

When testing isolation valves, the pressure must be applied on the correct side of the closing device according to instructions in the valve specification. Valves equipped with actuators shall be tested as complete units on the purchaser's explicit demand. Testing shall be performed and meet the requirements as per SS-EN 12266-1 or according to the procedure prepared by the manufacturer and approved by the purchaser.

SCOPE

All check and isolation valves where prescribed according to the detailed inspection plan.

TEST REQUIREMENTS

According to SS-EN 12266-1.

The air used as pressure medium shall be clean and dry.

The cleanliness before testing, water quality for testing (if water is used) and treatment after testing shall meet the requirements of the purchaser.

ACCEPTANCE CRITERIA

According to SS-EN 12266-1.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector.
The certificate shall state:

- Procedure/standard
- Test method
- Test pressure and holding time
- Test result
- Date of testing

TIGHTNESS TESTING OF CONTROL VALVES WITH NO CLOSING FUNCTION

EP 442
PAGE 1/1

APPLICATION

Inspection of seat leakage

The test shall be made with water at room temperature. Normal operating data for the actuator must not be exceeded during the test.

Test pressure: Specified pressure upstream and atmospheric pressure downstream the unit.

SCOPE

All control valves where prescribed in the detailed inspection plan.

ACCEPTANCE CRITERIA

The leakage across the seat must not exceed the following value, calculated as a percentage of the valve flow coefficient K_{VS} .

Definition: K_{VS} is the flow of water in m^3 per hour at 5 -30 °C passing through a fully open valve when the differential pressure across the valve is 0.1 MPa.

Single seat valves: $0,05 \% \times K_{VS}$.

Twin seat valves: $0,5 \% \times K_{VS}$.

If the differential pressure deviates by 1 bar, the maximum allowed leakage across the seat shall be calculated as the above percentage of K_{VS} multiplied by the square root of the actual differential pressure.

Cleanliness before testing, water quality during testing and treatment after testing shall meet the requirements of the purchaser.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector.
The certificate shall state:

- Procedure/standard
- Test method
- Test pressure and holding time
- Date for testing

TIGHTNESS TESTING – SAFETY VALVES FOR LIQUIDS

EP 443
PAGE 1/1

APPLICATION

Inspection of tightness of the sealing device

Safety valves in liquid born systems shall be tested for tightness according to below, or according to the procedure prepared by the manufacturer and approved by the purchaser.

Testing with water

Testing shall be carried out with water to which a wetting agent has been added.

1. Increase the pressure to 0.1 MPa below the opening pressure.
2. Lower the pressure to operating pressure.
3. When conditions have become stable, the leakage shall be measured for one hour.
4. Inspection and and if needed adjustment of the opening pressure.
5. Lower the pressure to operating pressure.
6. Measure the leakage for 15 minutes when stable conditions are reached.

SCOPE

All safety valves when prescribed in the detailed inspection plan.

ACCEPTANCE CRITERIA

Tightness requirements to be specified by the purchaser.

Cleanliness before testing, water quality for testing and treatment after testing shall meet the requirements of the purchaser.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector.
The certificate shall state:

- Procedure/standard
- Test method
- Test pressure and holding time
- Test result
- Date of testing

**TIGHTNESS TESTING – SAFETY VALVES
FOR STEAM OR AIR**

**EP 444
PAGE 1/1****APPLICATION****Inspection of the sealing device tightness**

Safety valves for steam, air or other gaseous media shall be tested for tightness according to requirements below or according to a procedure prepared by the manufacturer and approved by the purchaser.

Testing with air

Test performed according to SS-EN 1983:2006.

SCOPE

All safety valves for steam air or other gas.

ACCEPTANCE CRITERIA

According to SS-EN 1983:2006.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector.
The certificate shall state:

- Procedure/standard
- Test method
- Test pressure and test time
- Test result
- Date of testing

**FUNCTIONAL TESTING CHECK VALVES
AND ISOLATING VALVES**

**EP 451
PAGE 1/1****APPLICATION**

In compliance with the purchaser's specification or the specification prepared by the manufacturer and approved by the purchaser.

SCOPE

As prescribed in the detailed inspection plan.

TEST REQUIREMENTS

Cleanliness before testing, test water quality (if water is used) and treatment after testing shall meet the requirements of the purchaser.

ACCEPTANCE CRITERIA

In compliance with actual specification from the purchaser or the specification prepared by the manufacturer and approved by the purchaser.

CERTIFICATION

A certificate with the results from the functional test and reference to applied specifications/standards shall be issued by the manufacturer and be verified by the inspector.

FUNCTIONAL TESTING – SAFETY VALVES**EP 453**
PAGE 1/1

APPLICATION

In compliance with the purchaser's specification or the specification prepared by the manufacturer and approved by the purchaser.

SCOPE

All safety valves where prescribed according to detailed inspection plan.

TEST REQUIREMENTS

The test equipment for each respective pressure range to be equipped with calibrated pressure gauges satisfying class 0,6 as per standard SMS 1554, or similar requirements of foreign standard. The test equipment is to be furnished with a control valve.

Cleanliness before testing, test water quality (if water is used) and treatment after testing shall meet the requirements of the purchaser.

ACCEPTANCE CRITERIA

In compliance with actual specification from the purchaser or the specification prepared by the manufacturer and approved by the purchaser. Requirements of ISO 4126 shall be fulfilled.

CERTIFICATION

Certificates shall be issued by the manufacturer and be verified by the inspector. The certificate shall state:

- Measured opening pressure
- Measured pressure increase in %
- Measured blow down in %
- Reference to prevailing specification or standard
- Date of testing

FUNCTIONAL TESTING – CENTRIFUGAL PUMPS
TEST CLASS: 1

EP 454
PAGE 1/1**APPLICATION**

In compliance with the specification prepared by the manufacturer and approved by the purchaser.

SCOPE

Example of tests:

- A. Measuring of pump characteristics
 - Delivery head
 - Flow
 - Efficiency
 - Power requirement
- B. Measuring of delivery head at zero flow.
- C. Cavitation test at NPSH when the pressure is reduced by 3 %. For one pump of each type, there shall be a five-point measurement, including the duty point, on the pump graph.
- D. Measuring of the rotation speed and power consumption.
- E. Measuring of the starting current for pump motor units.
- F. Measuring of bearing temperatures, vibration level, leakage etc.

TEST REQUIREMENTS

The cleanliness before testing, water quality for testing and the treatment after testing shall meet the requirements of the purchaser.

ACCEPTANCE CRITERIA

All pump data given in the purchaser's pump specification must fall within the limits of tolerance limits stated in the specification or in the agreed test procedure.

CERTIFICATION

Certificate with the results of the function tests according to the pump specification/test procedure.

FUNCTIONAL TESTING – RECIPROCATING PUMPS**EP 457****PAGE 1/1****APPLICATION**

Testing shall be carried out according to standards prescribed by the purchaser. The manufacturer shall prepare a test program to be approved by the purchaser.

Testing shall be carried out with water at the manufacturer's test rig.

SCOPE

Example of tests:

A. Measuring of pump characteristics:

- Delivery head
- Capacity
- Efficiency
- Power requirement

B. Cavitation test on one pump of each type.

C. Measurement of the rotation speed and power consumption.

D. Measurements of bearing temperatures, oils pressure and oil temperature, vibration level, noise level, leakage, pulsation at inlet and outlet etc.

TEST REQUIREMENTS

Cleanliness before testing, test water quality and treatment after testing shall correspond to the purchaser's requirements.

ACCEPTANCE CRITERIA

The pump data given in the purchaser's pump specification must be fulfilled.

CERTIFICATION

A certificate with the results of the function tests according to the pump specification / test procedure.

“STRIP TEST” – PUMPS**EP 486**
PAGE 1/1**APPLICATION**

The test shall be performed in compliance with the specification prepared by the manufacturer and approved by the purchaser.

SCOPE

Inspection of:

- All bearings
- Shafts
- Impellers
- Wear surfaces
- Stator (wet pump-motor units)
- Rotor (wet pump-motor units)
- Coupling
- Mechanical seal, stuffing box and glands
- Static seal
- Diffuser
- Sealing surfaces, gaskets and O-rings

ACCEPTANCE CRITERIA

All pump data stated in the purchaser's pump specification, shall be within the tolerance limits stated in the specification or in agreed test procedure.

CERTIFICATION

Certificate with the results from the tests according to the pump specification / test procedure.

BALANCING**EP 490**
PAGE 1/1

APPLICATION

Balancing shall be carried out according to the purchaser's requirements or a standard or procedure used by the manufacturer and approved by the purchaser.

SCOPE

All rotating parts as prescribed in the detailed inspection plan.

ACCEPTANCE CRITERIA

According to the purchaser's requirements, or according to the standard/procedure used by the manufacturer, approved by the purchaser.

CERTIFICATION

Certificate with the results of the inspection, according to the pump specification / test procedure.

INSPECTION OF SYSTEM CLEANLINESS

EP 560
PAGE 1/1

APPLICATION

Prior to taking installed systems into operation, they shall be vacuum cleaned, blown/flushed with air and/or water according to the applicable instruction for each system. The result shall be checked in the discharge by:

- inspection of the quantity of mechanical impurities by filtering
- measuring the electric conductivity

SCOPE

All systems stated in a detailed instruction, or otherwise as prescribed in the detailed inspection plan.

ACCEPTANCE CRITERIA

According to ABM chapter 3.6 or special instruction.

CERTIFICATION

Certificate shall be issued by the manufacturer and be signed by the responsible individual, stating at least:

- Date of flushing
- System flushed
- Valid procedure
- Whether totally demineralised water has been used or not
- Possible additives to the water used for flushing
- Where, when and how the analysed samples were selected
- Conductivity and temperature of the sample
- Solid particles at filtering